



ADVISORY REVIEW BOARD'S VARIANCE AGENDA

DATE: November 14, 2018 MEETING LOCATION: DOH-Orange County, Orlando



RECOMMENDATIONS
BOARD MOTION DOH FINAL ACTION

AP #	APPLICANT'S NAME AND ADDRESS	COUNTY OF PROJECT	SECTION OF LAW OR RULE AND SPECIFIC VARIANCE(S) REQUESTED	T a b l e	A P P r o p r i e	D E N Y	Y E S	N O	A P P r o p r i e	D E N Y	PROVISOS RECOMMENDED BY BOARD	PROVISOS REQUIRED BY DOH	DATE LETTER MAILED
3179	Woodlands Section Seven Pool 5700 Mulberry Drive Tamarac, FL 33319	Broward	<p>454.1.6.1.3 FBC: Floors of sanitary facilities shall be, slip-resistant finish, and shall slope to floor drains.</p> <p>454.1.6.1.4 FBC: A hose bibb with vacuum breaker shall be provided in or within 25 feet (7620 mm) of each restroom to allow for ease of cleaning.</p> <p>454.1.3.1.3 FBC: Pool wet decks shall have a minimum unobstructed width of 4 feet (1219 mm) around the perimeter of the pool, pool curb, ladders, handrails, diving boards, diving towers and slides.</p> <p>454.1.6.5.9 FBC: Wall inlets shall be installed a minimum of 12 inches (305 mm) below the normal operating water level unless precluded by the pool depth or intended for a specific acceptable purpose.</p>										
3180	The Lumin Pool 5500 Broken Sound Blvd Boca Raton	Palm Beach	454.1.3.1.7 FBC: Food or drink service facilities shall not be located within 12 feet (3658 mm) of the water's edge.										

ADVISORY REVIEW BOARD'S VARIANCE AGENDA

DATE: November 14, 2018 MEETING LOCATION: DOH-Orange County, Orlando

RECOMMENDATIONS
BOARD MOTION DOH FINAL ACTION

AP #	APPLICANT'S NAME AND ADDRESS	COUNTY OF PROJEC T	SECTION OF LAW OR RULE AND SPECIFIC VARIANCE(S) REQUESTED	T a b l e	A P P r o p r i e	D E N Y	Y E S	N O	A P P r o p r i e	D E N Y	PROVISOS RECOMMENDED BY BOARD	PROVISOS REQUIRED BY DOH	DATE LETTER MAILED
3191	Project 801/Dock Side Hotel Pool 7125 Universal Blvd Orlando, Florida 32819	Orange	454.1.9.6.7 FBC: Those portions of the zero depth entry pool, where the water depth will not allow for the proper installation of underwater lighting, shall be provided with 6 footcandles of lighting on the deck and the water.										
3192	Project 370/Surf Side Hotel 7000 Universal Blvd Orlando, Florida 32819	Orange	454.1.9.6.7 FBC: Those portions of the zero depth entry pool, where the water depth will not allow for the proper installation of underwater lighting, shall be provided with 6 footcandles of lighting on the deck and the water.										
3193	Mavida Senior Living Main Pool 7650 Gladiolus Drive Fort Myers, FL 33908	Lee	454.1.6.5.3.1.3 FBC: All tile used on the flat, horizontal part, or the leading edge of an open-type gutter, must be slip resistant.										
3194	Mavida Senior Living West Pool 7650 Gladiolus Drive Fort Myers, FL 33908	Lee	454.1.6.5.3.1.3 FBC: All tile used on the flat, horizontal part, or the leading edge of an open-type gutter, must be slip resistant.										

ADVISORY REVIEW BOARD'S VARIANCE AGENDA

DATE: November 14, 2018 MEETING LOCATION: DOH-Orange County, Orlando

RECOMMENDATIONS
BOARD MOTION DOH FINAL ACTION

AP #	APPLICANT'S NAME AND ADDRESS	COUNTY OF PROJECT	SECTION OF LAW OR RULE AND SPECIFIC VARIANCE(S) REQUESTED	T a b l e	A P P r o p r i e	D E N Y	Y E S	N O	A P P r o p r i e	D E N Y	PROVISOS RECOMMENDED BY BOARD	PROVISOS REQUIRED BY DOH	DATE LETTER MAILED
------	------------------------------	-------------------	---	-----------------------	---	------------------	-------------	--------	---	------------------	-------------------------------	--------------------------	--------------------

3195 Cont.			<p>FS (Florida Statue) 514.011(2) (Public Pool Definition) "Public swimming pool" or "public pool" means a watertight structure of concrete, masonry, or other approved materials which is located either indoors or outdoors, used for bathing or swimming by humans, and filled with a filtered and disinfected water supply, together with buildings, appurtenances, and equipment used in connection therewith.</p> <p>FBC 454.1.9.2.3.1 Pump Reservoir Volume: The minimum reservoir volume shall be equal to 3 minutes of the combined flow rate in gallons per minute of all filter and slide pumps.</p> <p>FBC 4541.9.2.6.2 Filter Area: Minimum filter area requirements shall be twice the filter areas specified for the recirculation rates stipulated in Section.</p> <p>454.1.6.5.5.1. The filtration system shall be capable of returning the pool water turbidity to 5/10 NTU within 8 hours or less after peak bather load.</p>										
---------------	--	--	--	--	--	--	--	--	--	--	--	--	--

ADVISORY REVIEW BOARD'S VARIANCE AGENDA

DATE: November 14, 2018 MEETING LOCATION: DOH-Orange County, Orlando

RECOMMENDATIONS
BOARD MOTION DOH FINAL ACTION

AP #	APPLICANT'S NAME AND ADDRESS	COUNTY OF PROJECT	SECTION OF LAW OR RULE AND SPECIFIC VARIANCE(S) REQUESTED	T	A	D	Y	N	A	D	PROVISOS RECOMMENDED BY BOARD	PROVISOS REQUIRED BY DOH	DATE LETTER MAILED
				a	P	E	S	O	P	E			
				b	R	N			V	N			
				l	V	Y			V	Y			
				e									
3195 Cont.			454.1.6.5.10.5 FBC: The main drain outlet shall be connected to a collector tank. The capacity of the collector tank shall be at least 1 minute of the recirculated flow unless justified by the design engineer.										
3196	Horizon Waterpark Tube Slide 3230 Inspiration Drive Kissimmee, FL 34747	Osceola	<p>454.1.9.2.3.1 FBC: The minimum reservoir volume shall be equal to 3 minutes of the combined flow rate in gallons per minute of all filter and slide pumps.</p> <p>454.1.9.2.6.2 FBC: Minimum filter area requirements shall be twice the filter areas specified for the recirculation rates stipulated in Section 454.1.6.5.5.1.</p> <p>454.1.6.5.3.1 FBC: Gutters may be eliminated along pool edges for no more than 15 feet (4572mm) and this shall not exceed 10 percent of the perimeter (at least 90 percent of the perimeter shall be guttered).</p>										

ADVISORY REVIEW BOARD'S VARIANCE AGENDA

DATE: November 14, 2018 MEETING LOCATION: DOH-Orange County, Orlando

RECOMMENDATIONS
BOARD MOTION DOH FINAL ACTION

AP #	APPLICANT'S NAME AND ADDRESS	COUNTY OF PROJECT	SECTION OF LAW OR RULE AND SPECIFIC VARIANCE(S) REQUESTED	T a b l e	A P P r o p o s i t i o n	D E N Y	Y E S	N O	A P P r o p o s i t i o n	D E N Y	PROVISOS RECOMMENDED BY BOARD	PROVISOS REQUIRED BY DOH	DATE LETTER MAILED
------	------------------------------	-------------------	---	-----------------------	---	------------------	-------------	--------	---	------------------	-------------------------------	--------------------------	--------------------

3196 Cont.			<p>454.1.2.1 FBC: A minimum 4-inch (102 mm) tile line, each tile a minimum size of 1 inch (25 mm) on all sides, shall be installed at the water line, but shall not exceed 12 inches (305 mm) in height if a dark color is used. Gutter-type pools may substitute 2-inch (51 mm) tile, each a minimum size of 1 inch (25 mm) on all sides, along the pool wall edge of the gutter lip.</p> <p>454.1.6.5.9.4 FBC: Pools with floor inlets only shall have a number of floor inlets provided such that the spacing between adjacent inlets does not exceed 20 feet (6096 mm) and the spacing between inlets and an adjacent wall does not exceed 10 feet (3048 mm).</p> <p>454.1.6.5.9.6 FBC: The flow rate through each inlet shall not exceed 20 gpm.</p> <p>454.1.6.5.8 FBC: Main drain systems and surface overflow systems which discharge to collector tanks shall be sized with a maximum flow velocity of 3-feet per second (914 mm/s).</p>										
---------------	--	--	---	--	--	--	--	--	--	--	--	--	--

ADVISORY REVIEW BOARD'S VARIANCE AGENDA

DATE: November 14, 2018 MEETING LOCATION: DOH-Orange County, Orlando

RECOMMENDATIONS
BOARD MOTION DOH FINAL ACTION

AP #	APPLICANT'S NAME AND ADDRESS	COUNTY OF PROJECT	SECTION OF LAW OR RULE AND SPECIFIC VARIANCE(S) REQUESTED	T a b l e	A P P r o p r i e	D E N Y	Y E S	N O	A P P r o p r i e	D E N Y	PROVISOS RECOMMENDED BY BOARD	PROVISOS REQUIRED BY DOH	DATE LETTER MAILED
------	------------------------------	-------------------	---	-----------------------	---	------------------	-------------	--------	---	------------------	-------------------------------	--------------------------	--------------------

3199 Cont			<p>454.1.2.2.3 FBC: Multiple floor levels in pools are prohibited, however, an area meeting all of the requirements of a sun shelf shall not be considered a violation of this requirement.</p> <p>454.1.3.1.6 FBC: Twenty percent of the deck along the pool perimeter may be obstructed as long as any one obstruction does not exceed 10 percent of the pool perimeter or 20 feet (6096 mm), whichever is less, in any one area where water depth is 5 feet (1524 mm) or less.</p> <p>454.1.3.3.6 FBC: Floating and climb-on devices, objects or toys that are not a part of the approved pool design shall not be tethered in the pool or installed without an engineering alterations application.</p> <p>454.1.6.5.3.1 FBC: Gutters may be eliminated along pool edges for no more than 15 feet (4572mm) and this shall not exceed 10 percent of the perimeter (at least 90 percent of the perimeter shall be guttered).</p>										
--------------	--	--	--	--	--	--	--	--	--	--	--	--	--

ADVISORY REVIEW BOARD'S VARIANCE AGENDA

DATE: November 14, 2018 MEETING LOCATION: DOH-Orange County, Orlando

RECOMMENDATIONS
BOARD MOTION DOH FINAL ACTION

AP #	APPLICANT'S NAME AND ADDRESS	COUNTY OF PROJECT	SECTION OF LAW OR RULE AND SPECIFIC VARIANCE(S) REQUESTED	T a b l e	A P P r o v i s o	D E N Y	Y E S	N O	A P P r o v i s o	D E N Y	PROVISOS RECOMMENDED BY BOARD	PROVISOS REQUIRED BY DOH	DATE LETTER MAILED
------	------------------------------	-------------------	---	-----------------------	---	------------------	-------------	--------	---	------------------	-------------------------------	--------------------------	--------------------

3200 Cont			<p>454.1.6.5.3.1 FBC: Gutters may be eliminated along pool edges for no more than 15 feet (4572mm) and this shall not exceed 10 percent of the perimeter (at least 90 percent of the perimeter shall be guttered).</p> <p>454.1.2.1 FBC: A minimum 4-inch (102 mm) tile line, each tile a minimum size of 1 inch (25 mm) on all sides, shall be installed at the water line, but shall not exceed 12 inches (305 mm) in height if a dark color is used. Gutter-type pools may substitute 2-inch (51 mm) tile, each a minimum size of 1 inch (25 mm) on all sides, along the pool wall edge of the gutter lip.</p> <p>454.1.6.5.9.4 FBC: Pools greater than 30 feet (9144 mm) in width shall have either floor inlets only, or a combination of floor inlets and wall inlets. Pools with floor inlets only shall have a number of floor inlets provided such that the spacing between adjacent inlets does not exceed 20 feet (6096 mm) and the spacing between inlets...</p>										
--------------	--	--	--	--	--	--	--	--	--	--	--	--	--

ADVISORY REVIEW BOARD'S VARIANCE AGENDA

DATE: November 14, 2018 MEETING LOCATION: DOH-Orange County, Orlando

RECOMMENDATIONS
BOARD MOTION DOH FINAL ACTION

AP #	APPLICANT'S NAME AND ADDRESS	COUNTY OF PROJECT	SECTION OF LAW OR RULE AND SPECIFIC VARIANCE(S) REQUESTED	T	A	D	Y	N	A	D	PROVISOS RECOMMENDED BY BOARD	PROVISOS REQUIRED BY DOH	DATE LETTER MAILED
				a	P	E	S	O	P	E			
				b	R	N			R	N			
				l	V	Y			V	Y			
				e									
3200 Cont			454.1.6.5.9.6 FBC: The flow rate through each inlet shall not exceed 20 gpm (1 L/s).										
3201	Horizon Waterpark Adult Pool 3230 Inspiration Drive Kissimmee, FL 34747	Osceola	454.1.6.5.9.6 FBC: The flow rate through each inlet shall not exceed 20 gpm (1 L/s). 454.1.6.5.8 FBC: Main drain systems and surface overflow systems which discharge to collector tanks shall be sized with a maximum flow velocity of 3-feet per second (914 mm/s).										

