

# STATE OF FLORIDA DEPARTMENT OF HEALTH



## PURPOSE: MIGRANT LABOR CAMP OR RESIDENTIAL MIGRANT HOUSING INSPECTION REPORT

- |  |  |
|--|--|
| <input type="checkbox"/> ROUTINE       | <input type="checkbox"/> REINSPECTION    |
| <input type="checkbox"/> CONSTRUCT.    | <input type="checkbox"/> CHANGE OF OWNER |
| <input type="checkbox"/> COMPLAINT     | <input type="checkbox"/> CONSULTATION    |
| <input type="checkbox"/> QI SURVEY     | <input type="checkbox"/> EPIDEMIOLOGY    |
| <input type="checkbox"/> INVESTIGATION | <input type="checkbox"/> PRE-LICENSING   |
| <input type="checkbox"/> OTHER _____   |  |

- TYPE:**
- MIGRANT LABOR CAMP
- RESIDENTIAL MIGRANT HOUSING
- FIELD SANITATION
- OTHER

NAME OF FACILITY _____	
ADDRESS _____	CITY _____
OWNER _____	ZIP _____
PERSON IN CHARGE _____	PHONE _____

### RESULTS

Satisfactory

Incomplete

Unsatisfactory

Citation Issued

Correct Violations by:

Next Inspection

8:00 AM on:

DATE		
0	0	05
1	1	06
2	2	07
3	3	08
4	4	09
5	5	10
6	6	11
7	7	12
8	8	13
9	9	14

OUT OF BUSINESS

CLOSED FOR SEASON

BEGIN	END	DATE			POSITION #				PERMIT NUMBER				# UNITS		
1:00	1:00														
2:05 AM	2:05 AM								-	5	2	-			
3:10 PM	3:10 PM	0	0	05	0	0	0	0	0	0	0	0	0	0	0
4:15	4:15	1	1	06	1	1	1	1	1	1	1	1	1	1	1
5:20	5:20	2	2	07	2	2	2	2	2	2	2	2	2	2	2
6:25	6:25	3	3	08	3	3	3	3	3	3	3	3	3	3	3
7:30	7:30	4	4	09	4	4	4	4	4	4	4	4	4	4	4
8:35	8:35	5	5	10	5	5	5	5	5	5	5	5	5	5	5
9:40	9:40	6	6	11	6	6	6	6	6	6	6	6	6	6	6
10:45	10:45	7	7	12	7	7	7	7	7	7	7	7	7	7	7
11:50	11:50	8	8	13	8	8	8	8	8	8	8	8	8	8	8
12:55	12:55	9	9	14	9	9	9	9	9	9	9	9	9	9	9

*Items marked below are not in compliance with the requirements of Chapter 64E-14, Florida Administrative Code and must be corrected. Continued operation of this facility without making these corrections is a violation of Chapter 64E-14, Florida Administrative Code, and Chapters 381 and 386 of the Florida Statutes. Violations must be corrected by the date and time indicated in the Results section above or a citation, an administrative fine or other legal action will be initiated.*

<p><b>SITES</b></p> <p><input type="checkbox"/> 1. Access Roads</p> <p><input type="checkbox"/> 2. Location</p> <p><input type="checkbox"/> 3. Drainage</p> <p><b>BUILDING STRUCTURES</b></p> <p><input type="checkbox"/> 4. Safe Egress</p> <p><input type="checkbox"/> 5. Utilities Operable/Electrical</p> <p><input type="checkbox"/> 6. Occupant Space</p> <p><input type="checkbox"/> 7. Clean/Painting</p> <p><input type="checkbox"/> 8. Windows/Screening</p> <p><input type="checkbox"/> 9. Ventilation</p> <p><input type="checkbox"/> 10. Ceiling/Floor/Wall</p> <p><input type="checkbox"/> 11. Construction/Repair</p> <p><input type="checkbox"/> 12. Heating</p> <p><input type="checkbox"/> 13. Lighting</p>	<p><b>WATER SUPPLY</b></p> <p><input type="checkbox"/> 14. Approved System</p> <p><input type="checkbox"/> 15. Operation</p> <p><input type="checkbox"/> 16. Hot &amp; Cold Supply</p> <p><b>GARBAGE &amp; REFUSAL DISPOSAL</b></p> <p><input type="checkbox"/> 17. Container/Storage</p> <p><input type="checkbox"/> 18. Cleaned</p> <p><b>VECTOR CONTROL</b></p> <p><input type="checkbox"/> 19. Extermination</p> <p><input type="checkbox"/> 20. Harborage</p> <p><b>SEWAGE WASTE DISPOSAL</b></p> <p><input type="checkbox"/> 21. Plumbing</p> <p><input type="checkbox"/> 22. Approved</p> <p><input type="checkbox"/> 23. Operation/Maintenance</p>	<p><b>TOILETS/URINALS</b></p> <p><input type="checkbox"/> 24. Approved</p> <p><input type="checkbox"/> 25. Ratios</p> <p><input type="checkbox"/> 26. Location</p> <p><input type="checkbox"/> 27. Operation/Maintenance</p> <div style="border: 1px solid black; padding: 5px; margin: 5px 0;"> <p><b>FIELD SANITATION FACILITIES</b></p> <p><input type="checkbox"/> 28. Handwashing</p> <p><input type="checkbox"/> 29. Toilets</p> <p><input type="checkbox"/> 30. Drinking Water</p> </div> <p><b>BATHING/LAUNDRY</b></p> <p><input type="checkbox"/> 31. Clean</p> <p><input type="checkbox"/> 32. Ratios</p> <p><input type="checkbox"/> 33. Laundry Tubs/Washers</p> <p><input type="checkbox"/> 34. Soap/Towels</p>	<p><input type="checkbox"/> 35. Operation/Maintenance</p> <p><b>FOOD SERVICE</b></p> <p><input type="checkbox"/> 36. Facilities Provided</p> <p><input type="checkbox"/> 37. Refrigeration/Freezer</p> <p><input type="checkbox"/> 38. Operation/Maintenance</p> <p><b>BEDS/BEDDING</b></p> <p><input type="checkbox"/> 39. Available/Condition</p> <p><input type="checkbox"/> 40. Separation Sexes/Spacing</p> <p><b>MISCELLANEOUS</b></p> <p><input type="checkbox"/> 41. Fire Protection</p> <p><input type="checkbox"/> 42. Supervision</p> <p><input type="checkbox"/> 43. Telephone Availability</p> <p><input type="checkbox"/> 44. Permit Posted</p> <p><input type="checkbox"/> 45. Other _____</p> <p><input type="checkbox"/> 46. Other _____</p>
---	--	--	---

ITEM NUMBERS	COMMENTS AND INSTRUCTIONS (continue on attached sheet)

HEALTH DEPARTMENT INSPECTOR: \_\_\_\_\_

PHONE: \_\_\_\_\_

COPY OF REPORT RECEIVED BY: \_\_\_\_\_

DATE: \_\_\_\_\_

## INSTRUCTIONS

**NOTE:** Complete this form in its entirety. Shade each applicable bubble in pen or pencil. The EXPLANATION CODE OF REFERENCES is for informational purposes only and is subject to change. The current Florida Administrative Code should be consulted for the official version of these references.

### EXPLANATION OF CODE REFERENCES

#### SITES

1. **Access Roads.** 64E-14.006(4), FS381.0086. The facility has an access road.
2. **Location.** 64E-14.006(1)(2). The camp or housing is located more than 200 feet from any sink hole, swamp, or pool of water and all sleeping quarters are more than 500 feet from livestock areas.
3. **Drainage.** 64E-14.006(1). The site provides a well drained area free from standing water.

#### BUILDING STRUCTURES

4. **Safe Egress.** 64E-14.007(1). All steps, porches, hallways and other means of egress are sturdy and safe.
5. **Utilities Operable/Electrical.** 64E-14.007(2). All buildings and structures have the corresponding utility connection for equipment required by this rule during occupancy.
6. **Occupant Space.** 64E-14.007(3). All private living quarters used for sleeping purposes provide a minimum of 50 square feet for each occupant.
7. **Clean/Painting.** 64E-14.007(4). All floors, roofs, walls and ceilings are clean and in good repair and painted with a lead-free paint.
8. **Windows/Screening.** 64E-14.007(5), 64E-14.010. All private living quarters and common areas have at least one window with screening opening directly to the outside.
9. **Ventilation.** 64E-14.007(5). At least one-half of each window is constructed so that it can be easily opened for ventilating the room.
10. **Ceiling/Floor/Wall.** 64E-14.007(1)(4). The building structure meets the minimum ceiling height requirement of 7 feet. The mobile home meets the minimum ceiling height requirement of 6 feet. The floors are constructed of wood, concrete, or other comparable material with a cleanable finish. The floors/walls/and ceiling are sound and in good repair.
11. **Construction/Repair.** 64E-14.007(4). The facility is constructed with decay resistant wood, or is covered with another type of protective coating.
12. **Heating.** 64E-14.011(1)(2)(3). Heating devices are provided. Other than electrical, vents or flu pipes are available. All devices contain controls to cut off the electricity or fuel to the devices.
13. **Lighting.** 64E-14.012. Each private living quarter of a camp or housing provides at least one ceiling or wall light fixture and one double electrical wall outlet.

#### WATER SUPPLY

14. **Approved System.** 64E-14.008(1). The water supply is an approved or permitted supply of potable water under pressure that conforms to the requirements of Chapter 62-550, 62-555, and 62-560, F.A.C., or Chapter 64E-8, F.A.C.
15. **Operation.** 64E-14.008(2). The water supply is capable of providing at least 50 gallons per person per day.
16. **Hot and Cold Supply.** 64E-14.008(3). The water supply provides hot water at a minimum 110 degrees Fahrenheit for bathing and dishwashing purposes.

#### GARBAGE AND REFUSE DISPOSAL

17. **Containers/Storage.** 64E-14.009(1). Watertight receptacles made of impervious material with tight fitting covers are being provided.
18. **Cleaned.** 64E-14.009(3). Garbage is disposed of in accordance with Chapter 62-700, F.A.C., or other applicable local code.

#### VECTOR CONTROL

19. **Extermination.** 64E-14.010. Effective measures are being taken to prevent infestation.
20. **Harborage.** 64E-14.010. Effective measures are being taken to prevent harborage of animal and insect vectors or pests.

#### SEWAGE WASTE DISPOSAL

21. **Plumbing.** 64E-14.014. All plumbing in migrant labor camps and residential migrant housing shall be in compliance with provisions of local plumbing codes.
22. **Approved.** 64E-14.013(1). Facilities are approved by the Department of Health and Rehabilitative Services or the Department of Environmental Protection.
23. **Operation/Maintenance.** 64E-14.013(1)(2). Facilities do provide satisfactory disposal and treatment of excreta and liquid waste.

#### TOILETS/URINALS

24. **Approved.** 64E-14.015(6). The system meets all the requirements.
25. **Ratios.** 64E-14.015(1). An adequate number of toilets/urinals are being provided.
26. **Location.** 64E-14.015(2). Toilet rooms are within 200 feet of each sleeping area in a migrant labor camp and are located where no occupant is required to pass through a sleeping area other than his own in a residential migrant housing facility.
27. **Operation/Maintenance.** 64E-14.015. Toilets/urinals operate and are clean.

#### FIELD SANITATION FACILITIES

28. **Handwashing.** 64E-14.016(1). Handwashing facilities are provided at the place of work or in the field and are located within a one-quarter mile walk of each employee.
29. **Toilets.** 64E-14.016(1)(2). Toilet facilities are provided at the place of work or in the field and are located within a one-quarter mile walk of each employee.
30. **Drinking Water.** 64E-14.016(4). Drinking water is being provided at the place of work or in the field and is located within a one-quarter mile walk of each employee.

#### BATHING/LAUNDRY

31. **Clean.** 64E-14.015(3). Bathing and laundry facilities are cleaned with a disinfectant.
32. **Ratios.** 64E-14.015(1). The required number of sanitary facilities are available.
33. **Laundry Tubs/Washers.** 64E-14.015(1). Laundry tubs and washers are supplied according to the ratios.
34. **Soap/Towels.** 64E-14.015(6). Soap and towels are provided in communal type facilities.
35. **Operation/Maintenance.** 64E-14.015. Bathing and laundry facilities are operable and kept in good repair.

#### FOOD SERVICE

36. **Facilities Provided.** 64E-14.017(1). An operating range, sink, and refrigerator-freezer are available, central mess is operated and equipped in compliance with Chapter 64E-11.
37. **Refrigerator/Freezer.** 64E-14.017(1). An operating refrigerator-freezer is available.
38. **Operation/Maintenance.** 64E-14.017(1)(2)(3). The refrigerator maintains a temperature at or below 45 degrees Fahrenheit. The freezer maintains a temperature at or below 0 degrees Fahrenheit.

#### BEDS/BEDDING

39. **Available/Condition.** 64E-14.018. Bedding is available to each housing occupant and is kept clean and free from rips and holes.
40. **Separation Sexes/Spacing.** 64E-14.018(1)(3)(4). Separate facilities for each sex are provided in barrack type facilities, bedding is spaced not less than 36 inches laterally or end to end.

#### MISCELLANEOUS

41. **Fire Protection.** 64E-14.019. Operating smoke detection devices and fire extinguishers are installed in all facilities.
42. **Supervision.** 64E-14.021(3), 64E-14.022. 50 or more occupants require a resident supervisor on site.
43. **Telephone Availability.** 64E-14.022. A telephone is available and easily accessible to all occupants.
44. **Permit Posted**
45. **Other.**
46. **Other.**