



Charlie Crist
Governor

Ana M. Viamonte Ros, M.D., M.P.H.
State Surgeon General

INTEROFFICE MEMORANDUM

INFORMATION
HSES 08-007

DATE: November 18, 2008
TO: County Health Department Directors/Administrators
ATTN: Environmental Health and Engineering Directors
THROUGH: Lisa Conti, D.V.M., M.P.H., Dipl. ACVPM, Director
Division of Environmental Health
FROM: 
Gerald Briggs, Chief,
Bureau of Onsite Sewage Programs
SUBJECT: ANSI/NSF Standard 40, Class I, Aerobic Treatment Unit (new listing)

INFORMATION ONLY

JET, Inc. with the Models J-500, J-600, J-750, J-1000, J-1250, and J-1500 Wastewater Treatment System Aerobic Treatment Unit (ATU) have been certified as meeting all of the requirements of ANSI/NSF Standard 40 - Residential Wastewater Treatment Systems for Class I classification and JET, Inc. has provided documentation showing that it meets the requirements of 64E-6.012, Florida Administrative Code. Please add it to the listing of ATUs acceptable for use in the State of Florida.

Attached, you will find a PDF file of the performance testing and evaluation certification report conducted by NSF International.

The following septic tanks have been approved for use in the State of Florida with the above listed aerobic treatment units.

Baker Septic Installations, Inc.

TANK NUMBER	CATEGORY	LIQUID DEPTH	WALL THICKNESS	EFFECTIVE GALLONS	TOTAL GALLONS	APPROVAL DATE
28-031-J1-C3	C-3	50.00	3.00	1160	1494	10/30/2006

REMARKS: Houses Jet Models J-500 through J-1500 ATU's



Division of Environmental Health, Bureau of Onsite Sewage Programs
4052 Bald Cypress Way, Bin #A08, Tallahassee, Florida 32399-1713

Page 2

Caribe Jet, Inc.

TANK NUMBER	CATEGORY	LIQUID DEPTH	WALL THICKNESS	EFFECTIVE GALLONS	TOTAL GALLONS	APPROVAL DATE
53-131-J1-C3	C-3	50.00	3.00	1160	1494	8/22/2005

REMARKS: Houses Jet Models J-500 through J-1500 ATU's

Pinewood Industries

TANK NUMBER	CATEGORY	LIQUID DEPTH	EFFECTIVE GALLONS	TOTAL GALLONS	APPROVAL DATE
44-058-J1	C-3	52.00			3/22/2002

REMARKS: Houses Jet Models J-500 through J-1500 ATU's

Please provide a copy of this memorandum to all licensed septic tank contractors and plumbers performing septic tank contracting services in your county.

If you have any questions about this memo please contact Kim Duffek at (850) 245-4070.

Attachment
cc: Jet, Inc.