




Charlie Crist
Governor

Ana M. Viamonte Ros, M.D., M.P.H.
State Surgeon General

INTEROFFICE MEMORANDUM

**INFORMATION
HSES 10-009**


DATE: July 21, 2010
TO: County Health Department Directors/Administrators
ATTN: Environmental Health and Engineering Directors
THROUGH: Lisa Conti, D.V.M., M.P.H., Dipl. ACVPM, Director
Division of Environmental Health
FROM: 
Gerald Briggs, Chief
Bureau of Onsite Sewage Programs
SUBJECT: ANSI/NSF Standard 40, Class I, Aerobic Treatment Unit (new listing)

INFORMATION ONLY

Aero-Tech models AT-500, AT-600, AT-750, and AT-1000 Wastewater Treatment System Aerobic Treatment Unit (ATU) have been certified as meeting all of the requirements of ANSI/NSF Standard 40. It has been added to the listing of ATUs acceptable for use in the State of Florida. Please note that the drawings in the NSF certification report do not show how the electrical lines will enter the unit. Upon inspection verify that they enter as per s. 64E-6.013(9)(c), FAC. Also per the manufacturer, the pre-treatment tank must be purchased with the unit from Aero-Tech. The following tanks manufactured by Aero-Tech have been approved for use with the above listed ATUs.

<u>Number</u>	<u>Comments</u>
70-147-AT500-C3	Houses Aero-Tech 500 GPD aerobic treatment units Also serves as 500 gallon pretreatment tank
70-147-AT600-C3	Houses Aero-Tech 600 GPD aerobic treatment units Also serves as 600 gallon pretreatment tank
70-147-AT750-C3	Houses Aero-Tech 750 GPD aerobic treatment units Also serves as 750 gallon pretreatment tank
70-147-AT1000-C3	Houses Aero-Tech 1000 GPD aerobic treatment units Also serves as 1000 gallon pretreatment tank

Please direct any questions to Kim Duffek at (407)317-7325.



Core Public Health at Your Service
Bureau of Onsite Sewage Programs
4052 Bald Cypress Way, Bin #A08, Tallahassee, FL 32399-1713
(850)245-4070 www.MyFloridaEH.com