



Charlie Crist
Governor

Ana M. Viamonte Ros, M.D., M.P.H.
State Surgeon General

November 24, 2008

Mr. James L. Lapin
Total Enviro Services, Inc.
3003 W. 40th Street
Orlando, FL 32839

Dear Mr. Lapin:

This letter is in response to your request to utilize the "Jaws-a Total Solution to Drain field Pollution" as an alternative repair method in onsite sewage treatment systems in Florida. You provided information that this alternative repair method will include the following:

1. Installation of a device that you manufacture and refer to as an aerobic bacteria generator. This device is cylindrical with a length of approximately 30" and a diameter of 12". You propose to position this device on the bottom of generally the second, or at the discretion of the installer the first, compartment of a septic tank. Air supply to a diffuser in this device will be accomplished through tubing passing through a riser.
2. Addition of a bacterial additive manufactured by others which the Department has reviewed for compliance with 381.0065(4)(m) and issued a letter of no-objection. Specifically, at this time, you intend to use the Pro-pump additive at the manufacturer's recommended and Department-reviewed application rates.
3. You recommend but do not require a service agreement.

The Department has no objection to the use of your product subject to the terms below:

1. No structural modifications to the existing tank or lid are allowed. The unit must be installed through the manholes in the treatment unit.
2. Installation of your unit shall be considered an alternative repair subject to s. 64E-6.015(3), FAC. Please note that alternative repair methods cannot be used where the absorption surface of the drainfield is within six inches of the wet season water table.
3. Installation and use shall be as detailed in the installation manual submitted with your request on May 19, 2008 and the maintenance manual submitted on August 26, 2008. Any changes to the manual must be reviewed by the Department prior to distribution.
4. The unit may be installed in all septic tank applications (new, modification, repair)

Be advised that the department is not a testing agency. This determination reflects only a review of the information submitted by you for compliance with Florida Statutes and Florida Administrative Code. The product evaluation does not investigate the validity of performance claims. The department acceptance must not be interpreted as certifying effectiveness, endorsing or recommending use of an additive. The product cannot be advertised as "state approved". The Florida Department of Health also does not assume liability for any promise,




Environmental Health is Core Public Health at your Service!
Division of Environmental Health
Bureau of Onsite Sewage Programs
4052 Bald Cypress Way, Bin #A08, Tallahassee, Florida 32399-1713

Mr. James L. Lapin
November 24, 2008
Page 2

guarantee, or expectation from purchasing or using an additive. The department reserves the right to withdraw acceptance if the product is modified after evaluation by the department or subsequently found not to be in compliance with the rule.

This letter of no-objection is limited to Department of Health jurisdictional circumstances as defined in Chapter 64E-6, Florida Administrative Code and Chapter 381.0065, Florida Statutes. If we may be of further assistance or should you have any additional questions regarding this letter, please contact Eberhard Roeder at (850) 245-4070.

Sincerely,



Gerald R. Briggs, Chief
Bureau of Onsite Sewage Programs