

**14137 Marion Investor Nation Residential Weitlund Construction, Agent
Capital LLC, Applicant**

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.23 ac, X ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-2 REI-Y ENG-N) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of s. 381.0065(4)(a), Florida Statutes. The structure shall comply with the authorized sewage flow provisions of s. 381.0065(4)(a),
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

**14138 Marion Investor Nation Residential Weitlund Construction, Agent
Capital LLC, Applicant**

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.29 ac, X ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-2 REI-Y ENG-N) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of s. 381.0065(4)(a), Florida Statutes. The structure shall comply with the authorized sewage flow provisions of s. 381.0065(4)(a),
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14139 Marion D32 Wholesale LLC, Applicant Davis, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-2 REI-Y ENG-N) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of s. 381.0065(4)(a), Florida Statutes. The structure shall comply with the authorized sewage flow provisions of s. 381.0065(4)(a),
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14140 Marion D32 Wholesale LLC, Applicant Davis, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-2 REI-Y ENG-N) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of s. 381.0065(4)(a), Florida Statutes. The structure shall comply with the authorized sewage flow provisions of s. 381.0065(4)(a),
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14141 Marion D32 Wholesale LLC, Applicant Davis, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.23 ac, X ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-2 REI-Y ENG-N) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of s. 381.0065(4)(a), Florida Statutes. The structure shall comply with the authorized sewage flow provisions of s. 381.0065(4)(a),
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14142 Marion D32 Wholesale LLC, Applicant Davis, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.23 ac, X ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-2 REI-Y ENG-N) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of s. 381.0065(4)(a), Florida Statutes. The structure shall comply with the authorized sewage flow provisions of s. 381.0065(4)(a),
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14143 Marion Ocala 36 LLC, Applicant Schuster, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.47 ac, X ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-N STI-Y HBI-Y REI-1 ENG-2) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of s. 381.0065(4)(a), Florida Statutes. The structure shall comply with the authorized sewage flow provisions of s. 381.0065(4)(a), FS.
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14144 Marion Adams Homes of Northwest Florida, Inc., Applicant Riale, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.26 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-2 HBI-Y REI-1 ENG-N) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of s. 381.0065(4)(a), Florida Statutes. The structure shall comply with the authorized sewage flow provisions of s. 381.0065(4)(a),
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14145 Marion Adams Homes of Northwest Florida, Inc., Applicant Riale, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-N) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of s. 381.0065(4)(a), Florida Statutes. The structure shall comply with the authorized sewage flow provisions of s. 381.0065(4)(a),
The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14146 Marion Quiga, Inc., Applicant Lumsden, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-1 STI-N HBI-N REI-N ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system.

This variance applies only to the lot size requirements of s. 381.0065(4)(a), Florida Statutes. The structure shall comply with the authorized sewage flow provisions of s. 381.0065(4)(a),

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14147 Marion A Plus Homes, Inc., Applicant

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.23 ac, X ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-N) Health Officer: P

Approved subject to the following conditions:

This variance applies only to the lot size requirements of s. 381.0065(4)(a), Florida Statutes. The structure shall comply with the authorized sewage flow provisions of s. 381.0065(4)(a),

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14148 Marion Castillo, Applicant

Rejected (up)

STATUTE/RULE CITATION:

381.0065(4)(g)2.b., FS - Estimated sewage flow exceeds 1500 gpd/acre (300 gpd requested, 293 gpd required)

RECOMMENDATIONS: Variance Committee: D (SHO-2 CHD-Y DEP-Y STI-N HBI-Y REI-N ENG-1) Health Officer: P

Approved subject to the following conditions:

The single-family residence shall have no more than 3-bedrooms and 1,330 square feet of building area as proposed in the application.

The onsite sewage treatment and disposal system shall include either an in-ground nitrogen reducing biofilter (INRB), an NSF 245 aerobic treatment unit, or a nitrogen-reducing performance-based treatment system.

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14149 Lee Bmibs LLC, Applicant J. Patrick Construction, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.23 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-1 HBI-2 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include an NSF 245 aerobic treatment unit with drip irrigation as proposed in the application.

This variance applies only to the lot size requirements of s. 381.0065(4)(a), Florida Statutes. The structure shall comply with the authorized sewage flow provisions of s. 381.0065(4)(a),

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14150 Lee Cay Homes, Applicant

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.28 ac, 80 ft requested, 0.5 ac, 100 ft required)

RECOMMENDATIONS: Variance Committee: P (SHO-Y CHD-Y DEP-Y STI-1 HBI-2 REI-Y ENG-Y) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include an NSF 245 aerobic treatment unit as proposed in the application.

This variance applies only to the lot size requirements of s. 381.0065(4)(a), Florida Statutes. The structure shall comply with the authorized sewage flow provisions of s. 381.0065(4)(a),

The single-family residence shall be connected to the public drinking water system within 180 days of notification of the availability of such a system.

14151 Bay Schreiber, Applicant Wilson, Agent

STATUTE/RULE CITATION:

64E-6.015, Table V, FAC - Setback to irrigation well (18 ft requested, 25 ft required)

RECOMMENDATIONS: Variance Committee: T (SHO-2 CHD-Y DEP-Y STI-1 HBI-Y REI-Y ENG-Y) Health Officer: T

Tabled and asked to provide the following information

A site plan prepared in accordance with s. 64E-6.004(3)(a), Florida Administrative Code, showing the location of the irrigation well.

14152 Bay Whitaker, Applicant Wilson, Agent

STATUTE/RULE CITATION:

381.0065(4)(g)2., FS - Setback to surface water body (37 ft requested, 50 ft required)

RECOMMENDATIONS: Variance Committee: T (SHO-2 CHD-Y DEP-Y STI-Y HBI-Y REI-Y ENG-1) Health Officer: T

Tabled and asked to provide the following information

A site plan prepared in accordance with ss. 64E-6.004(3)(a), Florida Administrative Code, drawn to scale and showing all required features, including the boundary of the surface water

It appears the applicant is proposing to build a two-bedroom addition onto the existing single family residence. If this is the case, an onsite sewage treatment and disposal system modification permit is required.

Since the bottom the existing drainfield is less than 12 inches above the wet season high water table, the drainfield is required to be brought into compliance with all new system standards.

Please amend the application as necessary to determine all necessary variance requests.

14153 Duval Hardeland, Applicant Egans Environmental, Agent

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre and 100 ft wide (0.37 ac, 97 ft requested, 0.5 ac, 100 ft required)

64E-6.009(3)(f), FAC - Obstructions shall impact the slope no more than 50%

64E-6.009(3)(f), FAC - Separation from drainfield to obstruction (4 ft requested, 5 ft required)

RECOMMENDATIONS: Variance Committee: T (SHO-2 CHD-Y DEP-Y STI-Y HBI-Y REI-Y ENG-1) Health Officer: T

Tabled and asked to provide the following information

It appears the property has been subdivided since the 2017 variance request. Please provide the date the property was subdivided and an explanation of why the property was subdivided.

Rejected

14161 Sarasota Tatiana Realty Inc., Applicant Crane, Agent

STATUTE/RULE CITATION:

381.0065(4)(e)3., FS - Setback to a public well producing <=2000 gpd (85 ft requested, 100 ft required)
64E-6.005(1)(b), FAC - Same as 381.0065(4)(e)3., FS
64E-6.005(4)(a), FAC - Inadequate unobstructed area available

RECOMMENDATIONS: Variance Committee: P (SHO-2 CHD-Y DEP-Y STI-1 HBI-Y REI-Y ENG-Y) Health Officer: T

Tabled and asked to provide the following information

It appears that the "sunrooms" were not included in the building area calculation.

Per subsection 64E-6.002(12), Florida Administrative Code, building area is "that enclosed habitable area of a dwelling unit, excluding the garage, carport, exterior storage shed, or open or screened patios or decks.

Calculations of building area shall be made by measurements of the outside building dimensions. The "sunrooms" appear to be building area and must be included in the building area

Based on this information, the total estimated sewage flow for the duplex is 400 gallons per day; not 300 gallons per day. Please amend the application as necessary to determine all necessary variance requests.

14162 Palm Beach Humble, Applicant

STATUTE/RULE CITATION:

64E-6, Table III, FAC - Inadequate drainfield size (315 sf requested, 334 sf required)
64E-6.001(4), FAC - Reuse system that was never approved

RECOMMENDATIONS: Variance Committee: A (SHO-2 CHD-Y DEP-Y STI-1 HBI-Y REI-Y ENG-Y) Health Officer: A

Approved

SHO: The county health department inspected the system and all other violations had been corrected.

14163 Duval Cassaro, Applicant

STATUTE/RULE CITATION:

64E-6.001(4)(e)2., FAC - Building addition without system upgrade (existing drainfield requested, current df sizing required)

RECOMMENDATIONS: Variance Committee: A (SHO-Y CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-Y) Health Officer: A

Approved

14164 Dixie Watson, Applicant A&B Construction, Agent

STATUTE/RULE CITATION:

381.0065(4)(g)2., FS - Setback to surface water body (35 ft requested, 50 ft required)
64E-6.005(4)(a), FAC - Inadequate unobstructed area available

RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-N DEP-Y STI-2 HBI-Y REI-1 ENG-N) Health Officer: P

Approved subject to the following conditions:

The onsite sewage treatment and disposal system shall include an NSF 245 aerobic treatment unit as proposed in the application.

The onsite sewage treatment and disposal system shall be set back from the surface water by the maximum distance attainable, but not less than 35 feet when installed.