





**12345 St. Johns Korey, Applicant Lake, Agent**  
**STATUTE/RULE CITATION:**  
64E-6.015, Table V, FAC - Setback to irrigation well (25 ft requested, 50 ft required)  
**RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-2 REI-Y ENG-Y) Health Officer: P**  
Approved subject to the following conditions:  
The onsite sewage treatment and disposal system shall be set back from the irrigation well on the adjacent property (Lot 127) by the maximum distance attainable but not less than 25 feet when installed.

**12346 Orange Tierney, Applicant Woodruff, Agent**  
**STATUTE/RULE CITATION:**  
64E-6.015, Table V, FAC - Setback to building (0 ft requested, 2 ft required)  
**RECOMMENDATIONS: Variance Committee: A (SHO-N CHD-N DEP-Y STI-Y HBI-2 REI-1 ENG-Y) Health Officer: A**  
Approved

**12347 Holmes The Ruth Dockery & Deizel J. Revocable Trust, Applicant Baker Engineers, LLC, Agent**  
**STATUTE/RULE CITATION:**  
381.0065(3)(b), FS - Take jurisdiction for flow > 10,000 gpd (14,310 gpd requested, <=10,000 gpd required)  
381.0065(4)(b), FS - Estimated sewage flow exceeds 2500 gpd/acre  
**RECOMMENDATIONS: Variance Committee: A (SHO-1 CHD-Y DEP-Y STI-2 HBI-Y REI-Y ENG-Y) Health Officer: A**  
Approved

**12348 Orange Banfield, Applicant Perez, Agent**  
**STATUTE/RULE CITATION:**  
381.0065(4)(i), FS - System likely to dispose of hazardous/toxic/industrial waste (Ind, tox, haz waste requested, Domestic, Commercial required)  
**RECOMMENDATIONS: Variance Committee: P (SHO-1 CHD-Y DEP-Y STI-2 HBI-Y REI-Y ENG-Y) Health Officer: P**  
Approved subject to the following conditions:  
The applicant shall obtain and maintain an annual onsite sewage treatment and disposal system operating permit in accordance with subsection 64E-6.003(5), FAC.  
The onsite sewage treatment and disposal system septic tank outlet shall have an approved commercial grade filter device to minimize the quantity of solids entering the drainfield.

**12349 Pasco Erickson, Applicant**  
**STATUTE/RULE CITATION:**  
64E-6.001(4)(d), FAC - Commercial sewage flow increase without system upgrade (existing system requested, current standards required)  
**RECOMMENDATIONS: Variance Committee: P (SHO-N CHD-Y DEP-Y STI-1 HBI-Y REI-2 ENG-Y) Health Officer: P**  
Approved subject to the following conditions:  
The onsite sewage treatment and disposal system septic tank outlet shall have an approved filter device to minimize the quantity of solids entering the drainfield.  
The onsite sewage treatment and disposal system drainfield shall maintain a 12" separation to the estimated wet season water table.

**12350 Nassau Wade, Applicant Wade, Agent**  
**STATUTE/RULE CITATION:**  
64E-6.005(2), FAC - Setback to property line/building foundation (2 ft requested, 5 ft required)  
**RECOMMENDATIONS: Variance Committee: A (SHO-Y CHD-Y DEP-Y STI-Y HBI-2 REI-1 ENG-Y) Health Officer: A**  
Approved