

## ADVISORY REVIEW BOARD'S VARIANCE AGENDA

DATE: May 9, 2018 MEETING LOCATION: DOH-Orange County, Orlando

RECOMMENDATIONS  
BOARD MOTION      DOH FINAL ACTION

AP #	APPLICANT'S NAME AND ADDRESS	COUNTY OF PROJECT	SECTION OF LAW OR RULE AND SPECIFIC VARIANCE(S) REQUESTED	T a b l e	A P P r o v e	D E N Y	Y E S	N O	A P P r o v e	D E N Y	PROVISOS RECOMMENDED BY BOARD	PROVISOS REQUIRED BY DOH	DATE LETTER MAILED
3049 Rehear	Aloft – Airport Hotel 7220 NW 36 <sup>th</sup> Street Miami, Florida 33166	Miami Dade	454.1.3.1.2 FBC: Pool wet decks shall be uniformly sloped at a minimum of 2 percent to a maximum of 4 percent away from the pool or to deck drains to prevent standing water.										
3085	Specialty Surfaces for The Place IWF 19900 The Place Blvd Estero, Florida 33928	Lee	454.1.2.1 FBC: Pools shall be constructed of concrete or other impervious and structurally rigid material.										
3086	Specialty Surfaces for Wakulla Suites 3550 N. Atlantic Avenue Cocoa Beach, FL 32931	Brevard	454.1.2.1 FBC: Pools shall be constructed of concrete or other impervious and structurally rigid material.										
3087	Cox Pools for Evergreen at Southwood Pool 221 Orange Ave Tallahassee, FL 32301	Leon	454.1.2.2.2 FBC: All pool walls shall have a clearance of 15 feet (4572 mm) perpendicular to the wall (as measured at design water level from gutter lip to gutter lip, or on skimmer pools, from vertical wall to vertical wall).										

## ADVISORY REVIEW BOARD'S VARIANCE AGENDA

DATE: May 9, 2018 MEETING LOCATION: DOH-Orange County, Orlando

RECOMMENDATIONS  
BOARD MOTION      DOH FINAL ACTION

AP #	APPLICANT'S NAME AND ADDRESS	COUNTY OF PROJECT	SECTION OF LAW OR RULE AND SPECIFIC VARIANCE(S) REQUESTED	T a b l e	A P P r o v i d e	D E N y	Y E S	N O	A P P r o v i d e	D E N y	PROVISOS RECOMMENDED BY BOARD	PROVISOS REQUIRED BY DOH	DATE LETTER MAILED
------	------------------------------	-------------------	---	-----------------------	---	------------------	-------------	--------	---	------------------	-------------------------------	--------------------------	--------------------

3088	Frederick Adams for  Wyndham Preserve Pool 2343 Blue Grouse Lane Sanford, FL	Seminole	<p>454.1.1.1 FBC: The filtration system for swimming pools shall be capable of meeting all other requirements of these rules while providing a flow rate of at least 1 gpm (0.06 L/s) for each living unit at transient facilities and ¾ gpm (0.04 L/s) at non-transient facilities.</p> <p>454.1.1.1 FBC: For the purpose of determining minimum pool size only, the pool turnover period used cannot be less than 3 hours.</p> <p>454.1.6.5.3.2FBC: Recessed automatic surface skimmers. Recessed automatic surface skimmers may be utilized when the pool water surface area is 1,000 square feet (93 m2) or less excluding offset stairs and swimouts and the width of the pool is not over 20 feet (6096 mm).</p> <p>454.1.6.5.3.2.2FBC: Location. Prevailing wind direction and the pool outline shall be considered by the designer in the selection of skimmer locations. The location of skimmers shall be such that the interference of adjacent inlets and skimmers is minimized.</p>										
------	--	----------	--	--	--	--	--	--	--	--	--	--	--



## ADVISORY REVIEW BOARD'S VARIANCE AGENDA

DATE: May 9, 2018 MEETING LOCATION: DOH-Orange County, Orlando

RECOMMENDATIONS  
BOARD MOTION      DOH FINAL ACTION

AP #	APPLICANT'S NAME AND ADDRESS	COUNTY OF PROJECT	SECTION OF LAW OR RULE AND SPECIFIC VARIANCE(S) REQUESTED	BOARD MOTION		DOH FINAL ACTION		PROVISOS RECOMMENDED BY BOARD	PROVISOS REQUIRED BY DOH	DATE LETTER MAILED
				T a b l e	A P P r o v e	D E N Y	Y E S			
3092	Echo at Brickell North Spa Pool 1451 Brickell Avenue Miami, Florida 33131	Miami-Dade	454.1.3.1.2 FBC: Pool wet decks shall be uniformly sloped at a minimum of 2 percent to a maximum of 4 percent away from the pool or to deck drains to prevent standing water.							
3093	Echo at Brickell South Spa Pool 1451 Brickell Avenue Miami, Florida 33131	Miami-Dade	454.1.3.1.2 FBC: Pool wet decks shall be uniformly sloped at a minimum of 2 percent to a maximum of 4 percent away from the pool or to deck drains to prevent standing water.							
3094	Specialized Swim and Wellness 100 NW 88 <sup>th</sup> Street Boca Raton, FL 33432	Palm Beach	Aboveground Pool ISR Style Self-Rescue Facility Variance Request							
3095	California Float Concepts 229 6 <sup>th</sup> Street Marysville, CA 95901	STATE	Float Pod, Manf's Blanket Variance							











## ADVISORY REVIEW BOARD'S VARIANCE AGENDA

DATE: May 9, 2018 MEETING LOCATION: DOH-Orange County, Orlando

RECOMMENDATIONS  
BOARD MOTION      DOH FINAL ACTION

AP #	APPLICANT'S NAME AND ADDRESS	COUNTY OF PROJECT	SECTION OF LAW OR RULE AND SPECIFIC VARIANCE(S) REQUESTED	T	A	D	Y	N	A	D	PROVISOS RECOMMENDED BY BOARD	PROVISOS REQUIRED BY DOH	DATE LETTER MAILED
				a	P	E	E	O	P	E			
				b	R	N	S		R	N			
				l	V	Y			V	Y			
				e									
3100	Knights Key Resort Pool E 1 Knights Boulevard Marathon, FL 33050	Monroe	454.1.3.1.6 FBC: Twenty percent of the deck along the pool perimeter may be obstructed as long as any one obstruction does not exceed 10 percent of the pool perimeter or 20 feet (6096 mm), whichever is less, in any one area where water depth is 5 feet (1524 mm) or less.										





