Florida HEALTH

Florida Onsite Sewage Nitrogen Reduction Strategies Study

Task B.7 B-HS3 Field System Monitoring Report No. 8

Progress Report

December 2014



In association with:



Otis Environmental Consultants, LLC

Florida Onsite Sewage Nitrogen Reduction Strategies Study

TASK B.7 PROGRESS REPORT

B-HS3 Field System Monitoring Report No. 8

Prepared for:

Florida Department of Health Division of Disease Control and Health Protection Bureau of Environmental Health Onsite Sewage Programs 4042 Bald Cypress Way Bin #A-08 Tallahassee, FL 32399-1713

FDOH Contract CORCL

December 2014

Prepared by:



In Association With:





B-HS3 Field System Monitoring Report No. 8

1.0 Background

Task B of the Florida Onsite Sewage Nitrogen Reduction Strategies Study (FOSNRS) includes performing field experiments to critically evaluate the performance of nitrogen removal technologies that were identified in FOSNRS Task A.9 and pilot tested in PNRS II. To meet this objective, full scale treatment systems are being installed at various residential sites in Florida and monitored over an extended timeframe under actual onsite conditions. The Task B Quality Assurance Project Plan (Task B.5) documents the objectives, monitoring framework, sample frequency and duration, and analytical methods to be used at the home sites. This report documents the eighth and final sample event of a passive nitrogen reduction system at home site B-HS3 in Seminole County, Florida.

2.0 Purpose

Operation of the B-HS3 system was initiated on July 12, 2013. This monitoring report documents data collected from the eighth monitoring and sampling event conducted on December 17, 2014 (Day 523). The monitoring event consisted of collecting flow measurements from the household water use meter and the treatment system flow meters, recording electricity use, monitoring of field parameters, collection of water samples from eleven points in the treatment system, and chemical analyses of water samples by a NELAC certified laboratory.


3.0 Materials and Methods

3.1 Project Site

The B-HS3 field site is located in Seminole County, FL. The nitrogen reducing onsite treatment system for the single family residence was installed in June 2013. Design and construction details were presented previously in the Task B.6 document. A system schematic identifying the system components and layout of the installation is shown in Figure 1. A flow schematic of the system is shown in Figure 2. The B-HS3 system consists of a 1,500 gallon two chamber concrete primary treatment (septic) tank that replaced the former septic tank; a 600 gallon concrete septic tank effluent (STE) dose tank; a two zone drip system; and a 1,050 gallon concrete tank enclosing a Stage 2

saturated sulfur media biofilter. The two zone drip system consists of a Stage 1&2a lined drip zone (Zone 1), that receives primary effluent and a drip zone that receives treated effluent from the Stage 2b biofilter (Zone 2).

FLORIDA ONSITE SEWAGE NITROGEN REDUCTION STRATEGIES STUDY B-HS3 FIELD SYSTEM MONITORING REPORT NO. 8




Plan View of B-HS3 System Layout

FLORIDA ONSITE SEWAGE NITROGEN REDUCTION STRATEGIES STUDY B-HS3 FIELD SYSTEM MONITORING REPORT NO. 8

PAGE 1-3 HAZEN AND SAWYER, P.C.






locs\Report\Final

Т

3.2 Monitoring and Sample Locations and Identification

3.2.1 Treatment System Monitoring Points

This monitoring event included sample collection from eleven points within the treatment system (Figure 3). In the treatment system, household wastewater enters the 1st chamber of the primary tank and exits the second chamber as septic tank effluent through an effluent screen into the STE dose tank. The first monitoring point, B-HS3-STE, is the effluent sampled approximately 1.5 feet below the surface of the second chamber of the primary tank (Figure 4) before the effluent filter, which is referred to as primary effluent or septic tank effluent (STE). Samples from monitoring point B-HS3-STE are of whole household wastewater after it has had some residence time in the primary tank and represent the influent to the remainder of the onsite nitrogen reduction system.



FLORIDA ONSITE SEWAGE NITROGEN REDUCTION STRATEGIES STUDY B-HS3 FIELD SYSTEM MONITORING REPORT NO. 8 PAGE 1-6 HAZEN AND SAWYER, P.C.



Figure 4 Second Chamber of Primary Tank (B-HS3-STE Sample)

The STE dose tank effluent is pumped through the drip system hydraulic unit and discharged to the Stage 1&2a drip system (Zone 1). In the Stage 1&2a drip area, wastewater percolates downward through an 18-inch layer of unsaturated sand and a layer of lignocellulosic and sand media (9-inch maximum thickness) placed above a 30 mil PVC liner. The second and third sampling points are two suction lysimeters (BHS3-LY01 and BHS3-LY02) located at the interface of the overlying sand (Stage 1) and underlying lignocellulosic/sand mixture (Stage 2a). The suction lysimeters were installed with the bottom of the 9-inch ceramic placed at the interface of the two media layers. These sample locations ostensibly represent wastewater that has been nitrified by passage through the overlying sand layer (Figure 5).

FLORIDA ONSITE SEWAGE NITROGEN REDUCTION STRATEGIES STUDY B-HS3 FIELD SYSTEM MONITORING REPORT NO. 8





Figure 5 Stage 1 Suction Lysimeter (BHS3-LY01 and –LY02)

The Stage 1&2a drip system area was prepared by grading a V-shape so that effluent would collect on the liner and flow to the center where a perforated pipe within a gravel underdrain conveys the effluent to the Stage 2b denitrification tank through a pipe boot within the liner. The fourth sampling point (BHS3-LINER) is a sample port of the Stage 1&2a lined area effluent prior to the Stage 2b sulfur biofilter. At the BHS3-LINER sample point, wastewater should be denitrified by passage through the lignocellulosic media mixture (Stage 2a).

The liner effluent is conveyed to a Stage 2b biofilter, a concrete 1,050 gallon tank, containing elemental sulfur reactive media for additional treatment (denitrification). Wastewater flow is in an upward direction. The fifth sampling point, BHS3-SULFUR-6, is a stainless steel drivepoint sampler positioned 6-inches above the bottom of the sulfur media. The sixth sampling point, B-HS3-ST2, is the Stage 2b sulfur media biofilter effluent which is sampled approximately 6 inches below the water surface of the Stage 2b biofilter tank (Figure 6).

o:\44237-001R004\Wpdocs\Report\Final



Figure 6 Second Chamber of Stage 2b Biofilter (B-HS3-ST2 Sample)

The Stage 2b biofilter effluent is pumped through the drip system hydraulic unit and discharged through the treated effluent drip system emitters (Zone 2) to natural soil. Monitoring points 7 through 11 were placed below the Zone 2 drip emitters. Their locations are shown in Figure 3. Sampling points seven and eight are suction lysimeters (BHS3-LY03 and BHS3-LY04) located in the treated effluent drip area with the top of the 9 inch ceramic cup located 24 inches below the drip emitters to represent treatment through 24-inches of unsaturated soil (Figure 7). Sampling points nine, ten and eleven are also located within the treated effluent drip area; these are standpipe piezometers (BHS3-PZ07, BHS3-PZ08, and BHS3-PZ09) positioned so that the top of the 5-foot screen is 24-inches below the drip emitters (Figure 8).

FLORIDA ONSITE SEWAGE NITROGEN REDUCTION STRATEGIES STUDY B-HS3 FIELD SYSTEM MONITORING REPORT NO. 8





Figure 7 Treated Effluent Suction Lysimeter (B-HS3-LY03 and –LY04 sample)



Figure 8 Treated Effluent Area Standpipe Piezometers (B-HS3-PZ07, -PZ08 and –PZ09)

FLORIDA ONSITE SEWAGE NITROGEN REDUCTION STRATEGIES STUDY B-HS3 FIELD SYSTEM MONITORING REPORT NO. 8


PAGE 1-10 HAZEN AND SAWYER, P.C.

3.2.2 Groundwater Monitoring Points


For this monitoring event, five of the sixty-seven downgradient groundwater monitoring points that were installed as part of the C-HS2 groundwater monitoring network were included. A sampling grid for groundwater screening was developed downgradient of the original OSTDS as depicted in Figure 9. A 10-foot by 40-foot grid was staked then locations surveyed (x, y, and z). Transect lines A through D were located perpendicular to the groundwater flow direction (southwest) and increase (higher letter identification) moving southward from the mound. Transect lines 0 through 15 were located parallel to the groundwater flow direction and increase moving from southeast to northwest. Groundwater monitoring points were installed in June and July 2011. One type of monitoring point was installed using either hand or drilling methods: standpipe piezometers. Standpipe piezometers consist of either ³/₄-inch or 2-inch diameter PVC with a 1-foot, 2-foot, or 4-foot screen (0.010-inch slots) and riser extending to the ground surface (refer to the Task C QAPP and Task C.23 C-HS2 Instrumentation Report for additional detail).


Each monitoring location was assigned a unique identification indicating grid location (self explanatory), and depth below ground surface (bottom of the drive point or well screen in feet). For example A07-6 is a standpipe piezometer sampler located on the grid at A07 at approximately 6-feet below ground surface.

Groundwater level measurements are used to determine hydraulic gradients and directions of flow. Groundwater levels were measured using a flat tape water level meter graduated in feet (measurement accuracy is 0.01 feet). The groundwater level within the standpipe piezometers sampled was measured for this sampling event. Figure 10 illustrates the surficial groundwater contours as measured within the standpipe piezometers.



FLORIDA ONSITE SEWAGE NITROGEN REDUCTION STRATEGIES STUDY B-HS3 FIELD SYSTEM MONITORING REPORT NO. 8 PAGE 1-12 HAZEN AND SAWYER, P.C.





0' 10' 20' 30' 40'

Figure 10 Groundwater Sampling Locations and Surficial Groundwater Contours December 17, 2014

3.3 Operational Monitoring

Start-up of the system occurred on July 12, 2013 (Experimental Day 0) and the system has operated almost continually since that date. Between September 10, 2013 and September 17, 2013 the system was not operating because a replacement part for the hydraulic unit was required.

FLORIDA ONSITE SEWAGE NITROGEN REDUCTION STRATEGIES STUDY B-HS3 FIELD SYSTEM MONITORING REPORT NO. 8 Regular maintenance includes checking and cleaning, as necessary, the primary tank effluent screen and the STE dose tank effluent screen installed within the outlet tees. During sample event site visits, this is done after sampling. The cleaning of the disc filters in the hydraulic unit is an automated process. A backflush of the filters occurs at the beginning of each dose cycle, and the backflush flow is directed to the primary tank.

3.4 Flow Monitoring

The eighth formal sampling event was conducted December 17, 2014 (Experimental Day 523). For the eighth formal sampling event, the water meter for the house and the treatment system flow meters were read and recorded on December 17, 2014. The household potable water use is recorded via a water meter (Meter 1) located in the front yard which includes indoor and outdoor water use. The household has a separate irrigation well which supplies the irrigation system; however the metered potable water use includes filling the pool, car washing, etc. The combined pump flow meter is located inside the hydraulic unit following the hydraulic unit filters prior to the split between the two zones, and records the cumulative pumped flow in gallons pumped from both the STE dose tank and Stage 2b biofilter tank (Meter 2). Therefore, the measurement of the combined flow meter includes both the STE flow from the household and the treated effluent flow from the Stage 2b biofilter. The Stage 2b treated effluent flow meter (Meter 3) is located following the split on the line from the pump to the treated effluent drip system and records the cumulative flow in gallons pumped from the Stage 2b biofilter tank. The control panel includes telemetry which logs alarms, cumulative pump cycles, and cumulative field flush cycles.

The daily wastewater volume supplied to the passive nitrogen removal system was the volume that was pumped to the lined Stage 1&2a biofilter (Drip Zone 1); it was estimated by calculating the difference between the volume readings of Meter 2 and Meter 3. This calculation does not account for water entering or leaving the Stage 1/2a biofilter (Drip Zone 1) through hydrologic processes such as precipitation, irrigation, and evapotranspiration.

Flow calculations using the metered data: Combined pumped flow = Meter 2 Treated effluent flow (Zone 2) = Meter 3 Stage 1&2a biofilter wastewater flow (Zone 1) = Meter 2 – Meter 3 Additional Zone 1 inputs/outputs = Meter 3 - [Meter 2- Meter 3]

3.5 Energy, Chemical and/or Additives Consumption

Energy consumption was monitored using an electrical meter installed between the main power box for the house and the control panel. The electrical meter records the cumulative power usage of the system in kilowatt-hours. The power usage of the system is primarily due to the single pump, although a small amount of power is used by the control panel itself. There are no chemicals added to the system. However, the denitrification media (lignocellulosic and sulfur) are "reactive" media which will be consumed during operation. The Stage 1&2a lined area was initially filled with 9 inches of lignocellulosic and sand media mixture and the Stage 2b biofilter was initially filled with 12 inches of sulfur and oyster shell media mixture, which ostensibly will last for many years without replenishment or replacement.

3.6 Water Quality Sample Collection and Analyses

The eighth formal sample event was conducted on December 17, 2014 and included a full suite of influent, intermediate and effluent water quality samples from the system. Samples were collected at each of the sixteen monitoring points described previously in Section 3.2 and illustrated in Figures 3 and 10: eleven treatment system monitoring points and six groundwater sampling points. A peristaltic pump was used to collect the treatment system samples and route them directly into analysis-specific containers after sufficient flushing of the tubing had occurred. Field parameters were then recorded.

Groundwater samples were obtained using a peristaltic pump, which was attached directly to dedicated standpipe piezometer tubing. Samples were collected after sufficient purging (the sample was clear and field readings had stabilized) had occurred.

In addition, a field blank, equipment blank (EB), and field sample duplicates were taken. The field blank was collected by filling sample containers with deionized water that had been transported into the field along with other sample containers. The equipment blank was collected by pumping deionized water through the cleaned pump tubing. The field sample duplicates (B-HS3-ST2 and PZ-B8-5) were collected immediately subsequent to the regular samples. These samples were then analyzed for the same parameters as the monitoring samples.

The analysis-specific containers were supplied by the analytical laboratory and contained appropriate preservatives. The analysis-specific containers were labeled, placed in coolers and transported on ice to the analytical laboratories. Each sample container was secured in packing material as appropriate to prevent damage and spills, and was recorded on chain-of-custody forms supplied by the laboratory. Chain of custody forms, provided in Appendix A, were used to document the transfer of samples from field personnel to the analytical laboratory.

Field parameters were measured using portable electronic probes and included temperature (Temp), dissolved oxygen (DO), oxidation-reduction potential (ORP), pH, and specific conductance. The field parameters were measured by placing the analytical probes in a container overflowing with sample water. The influent, intermediate, and effluent samples were analyzed by the laboratory for: total alkalinity, chemical oxygen demand (COD), Carbonaceous Biological Oxygen Demand (CBOD₅), total Kjeldahl nitrogen (TKN-N), ammonia nitrogen (NH₃-N), nitrate nitrogen (NO₃-N), nitrite nitrogen (NO₂-N), total phosphorus (TP), orthophosphate (Ortho P), total suspended solids (TSS), volatile suspended solids (VSS), total organic carbon (TOC), chloride, fecal coliform (fecal), and E. coli. The influent and sulfur media samples included sulfate, sulfide, and hydrogen sulfide (unionized). All analyses were performed by an independent and fully NELAC certified analytical laboratory (Southern Analytical Laboratory). Table 1 lists the analytical parameters, analytical methods, and detection limits for these analyses.

Analytical Parameter	Method of Analysis	Method Detection Limit (mg/L)
Total Alkalinity as CaCO ₃	SM 2320B	2 mg/L
Chemical Oxygen Demand (COD)	EPA 410.4	10 mg/L
Total Kjeldahl Nitrogen (TKN-N)	EPA 351.2	0.05 mg/L
Ammonia Nitrogen (NH ₃ -N)	EPA 350.1	0.005 mg/L
Nitrate Nitrogen (NO3-N)	EPA 300.0	0.01 mg/L
Nitrite Nitrogen (NO ₂ -N)	EPA 300.0	0.01 mg/L
Nitrate+Nitrite Nitrogen (NOX-N)	EPA 300.0	0.02 mg/L
Total Phosphorus (TP)	SM 4500P-E	0.01 mg/L
Orthophosphate as P (Ortho P)	EPA 300.0	0.01 mg/L
Carbonaceous Biological Oxygen Demand (CBOD ₅)	SM5210B	2 mg/L
Total Suspended Solids (TSS)	SM 2540D	1 mg/L
Volatile Suspended Solids (VSS)	SM 2540E	1 mg/L
Total Organic Carbon (TOC)	SM5310B	0.06 mg/L
Chloride	EPA 300.0	0.50 mg/L
Sulfate	EPA 300.0	2.0 mg/L
Sulfide	SM 4500SF	0.10 mg/L
Hydrogen Sulfide (unionized)	SM 4550SF	0.01 mg/L
Fecal Coliform (fecal)	SM 9222D	2 ct/100mL
E.coli	SM 9223B	2 ct/100mL

 Table 1

 Analytical Parameters, Method of Analysis, and Detection Limits

4.0 Results and Discussion

4.1 Operational Monitoring

Table 2 provides a summary of the household water use since July 13, 2011. The treatment system flow meter readings for the B-HS3 field site are summarized in Table 3. The operation and maintenance log which includes actions taken since start-up is provided in Appendix B.

	Summary of Household Water Use					
Date	Cumulative Volume (gallons)	Average Daily Household Flow, Q Between read- ings (gpd)	Comments			
7/13/2011 14:45	5302677.9		Installed			
7/20/2011 17:50	5304207.8	214.6				
7/26/2011 15:19	5305257.9	178.1				
10/27/2011 15:19	5327920.4	243.7				
11/30/2011 8:00	5355610.4	821.8				
3/13/2012 8:10	5378780.2	222.8				
7/10/2012 16:15	5453899.3	629.5				
10/18/2012 15:30	5470593.1	167.0				
3/7/2013 14:00	5488517.4	128.1				
6/7/2013 14:00	5504725.9	176.2				
7/9/2013 12:50	5508873.0	129.8				
7/12/13			PNRS start-up			
7/12/13 14:01	5509172.1	98.1				
7/17/13 13:55	5509884.1	142.5				
7/29/13 9:50	5510830.9	80.0				
8/6/13 10:40	5511588.8	94.3				
8/12/13 11:07	5512244.8	109.0				
8/15/13 8:48	5513128.8	304.5	Prelim Event No. 1			
9/5/13 15:31	5514810.2	79.0				
9/10/13			Septic tank pumped			
9/17/13			System running again			
9/27/13 8:00	5517331.9	116.3				
9/30/13 8:00	5517622.5	96.9	Sample Event No. 1			
10/11/13 8:30	5518421.6	72.5				
10/17/13 11:00	5519187.0	125.4				
11/15/2013 10:00	5524455.0	181.9				
11/27/2013 9:10	5525784.8	111.1				
12/2/2013 8:30	5527623.5	369.8	Several guests stayed in the home over the Thanksgiving holiday			
12/4/2013 8:51	5527809.2	92.2	Sample Event No. 2			
12/23/2013 11:45	5529755.3	101.8				
1/23/2014 11:00	5532487.5	88.2				
1/30/2014 9:00	5533156.8	96.8				
2/3/2014 8:00	5533482.0	82.2	Sample Event No. 3			
2/4/2014 8:15	5533499.6	17.4	Sample Event No. 4			

Table 2Summary of Household Water Use

Summary of Household Water Use						
Date	Cumulative Volume (gallons)	Average Daily Household Flow, Q Between readings (gpd)	Comments			
2/5/2014 10:45	5533558.4	53.3	Sample Event No. 5			
2/6/2014 10:45	5533690.6	132.2	Sample Event No. 6			
2/7/2014 8:00	5533788.6	110.7	Sample Event No. 7			
2/12/14 10:00	5534282.7	97.2				
3/14/14 8:24	5537363.8	102.9				
4/3/14 8:45	5539932.0	128.3	Sample Event No. 8 (formal No. 4)			
4/29/14 10:10	5544794.2	186.6				
5/29/14 10:00	5549396.9	153.5	Sample Event No. 9 (formal No. 5)			
6/9/14 12:45	5550719.1	119.0				
7/29/14 9:30	5555927.1	104.4				
8/22/14 7:30	5557593.9	69.7	Sample Event No. 10 (formal No. 6)			
9/19/2014 12:48	5560271.5	94.9				
10/23/2014 15:45	5564131.1	113.1	Sample Event No. 11 (formal No. 7)			
12/17/2014 8:00	5570112.8	109.4	Sample Event No. 12 (formal No. 8)			
Total average PNRS start-up to 12/17/14		116.6				

Table 2 Summary of Household Water Use

Date and Time Read	Meter 2 Combined Pumped Flow Cum	Average Daily Combined Pumped Flow between readings	Calc Flow to Stage 1&2a [Meter 2 – Meter 3] ² Cum	Average Daily Calculated Flow to Stage 1&2a between readings ²	Meter 3 Treated Effluent Flow Cum	Aver- age Daily Treated Effluent Flow be- tween read- ings	Stage 1&2a Area Water Input or Output ¹
	Vol. (gal)	Gal/ Day	Vol. (gal)	Gal/ Day	Vol. (gal)	Gal/ Day	Gal/ Day
7/12/13 14:01	206.9	Start-up	Start-up	Start-up	58.6	Start-up	Start-up
7/17/13 11:57	423.0	44.0	40.6		234.2	35.7	
7/29/13 9:52	3,345.1	245.3	765.3	60.8	2,431.6	184.5	123.6
8/6/13 9:45	6,541.1	399.7	1,045.1	35.0	5,347.8	364.8	329.8
8/12/13 11:07	8,953.1	398.2	2,360.0	217.1	6,444.9	181.1	-36.0
8/15/13 8:48	10,131.2	405.8	3,084.3	249.4	6,898.7	156.3	-93.1
9/5/13 15:31	18,696.5	402.5	7,734.4	218.5	10,813.8	184.0	-34.5
9/9/13 9:00	19,884.6	318.7	8,287.6	148.4	11,448.8	170.3	22.0
9/17/13 10:12	20,912.4	127.7	8,785.2	61.8	11,979.0	65.9	4.0
9/27/13 8:00	22,142.0	124.1	9,239.3	45.8	12,754.5	78.3	32.4
9/30/13 8:00	22,885.0	247.7	9,692.2	151.0	13,044.6	96.7	-54.2
10/11/13 8:30	26,428.9	321.6	11,417.0	156.5	14,863.7	165.1	8.5
10/17/13 11:00	28,781.4	385.4	12,823.8	230.5	15,809.4	154.9	-75.5
11/8/13 12:30	34,278.1	249.1	15,844.0	136.9	18,285.9	112.2	-24.6
11/27/13 9:10	39,031.1	252.0	18,656.6	149.1	20,226.3	102.9	-46.2
12/2/13 8:30	42,081.5	613.5	20,437.6	358.2	21,495.7	255.3	-102.9
12/4/13 8:51	42,599.8	257.3	20,729.5	144.9	21,722.1	112.4	-32.6
12/23/13 11:45	47,135.0	237.2	23,346.3	136.9	23,640.5	100.3	-44.3
1/23/14 11:00	54,702.9	244.4	27,486.2	133.7	27,068.4	110.7	-23.0
1/30/14 9:00	56,954.9	325.6	28,619.7	163.9	28,187.0	161.7	-2.2
2/3/14 8:00	58,390.4	362.7	29,205.1	147.9	29,037.1	214.8	66.9
2/4/14 8:15	58,688.7	295.2	29,298.1	92.0	29,242.4	203.2	111.1
2/5/14 10:45	58,870.7	164.8	29,393.9	86.7	29,328.6	78.1	-8.6
2/6/14 10:45	59,118.7	248.0	29,553.8	159.9	29,416.7	88.1	-71.9
2/7/14 8:00	59,354.0	265.8	29,704.7	170.4	29,501.1	95.4	-75.0

Table 3Summary of System Flow

FLORIDA ONSITE SEWAGE NITROGEN REDUCTION STRATEGIES STUDY B-HS3 FIELD SYSTEM MONITORING REPORT NO. 8

PAGE 1-20 HAZEN AND SAWYER, P.C.

Date and Time Read	Meter 2 Combined Pumped Flow	Average Daily Combined Pumped Flow between readings	Calc Flow to Stage 1&2a [Meter 2 – Meter 3] ²	Average Daily Calculated Flow to Stage 1&2a between readings ²	Meter 3 Treated Effluent Flow	Average Daily Treated Effluent Flow between readings	Stage 1&2a Area Water Input or Output ¹
	Cum Vol. (gal)	Gal/ Day	Cum Vol. (gal)	Gal/ Day	Cum Vol. (gal)	Gal/ Day	Gal/ Day
2/12/14 10:00	61,023.9	328.5	30,135.7	84.8	30,739.9	243.7	158.9
3/14/14 8:24	67,901.2	229.8	34,391.1	142.2	33,361.9	87.6	-54.6
4/3/14 8:45	73,953.4	302.4	37,466.0	153.6	36,339.2	148.8	-4.9
4/29/14 10:10	81,273.0	280.9	41,710.4	162.9	39,414.4	118.0	-44.9
5/29/14 10:00	86,833.4	185.4	44,628.2	97.3	42,057.0	88.1	-9.2
6/9/14 12:45	90,633.4	341.9	46,511.8	169.5	43,973.4	172.4	3.0
7/11/14 14:45	98,858.8	256.4	50,797.4	133.6	47,913.2	122.8	-10.8
7/29/14 9:30	105,444.4	370.4	54,191.1	190.9	51,105.1	179.5	-11.3
8/22/14 7:30	110,175.4	197.8	56,565.4	99.3	53,461.8	98.5	-0.7
9/19/2014 12:48	118,258.6	286.4	60,754.3	148.4	57,356.1	138.0	-10.4
10/23/2014 15:45	130,079.5	346.4	65,886.9	150.4	64,044.4	196.0	45.6
11/21/2014 9:30	139,036.3	311.7	71,279.4	187.6	67,608.7	124.0	-63.6
12/17/2014 8:00	147,921.6	342.6	75,970.7	180.9	71,802.7	161.7	-19.2
Avg start-up to 12/17/14		282.6		145.3		137.2	-8.1

Table 3 (con't)

¹This value is the difference between the calculated flow to Stage 1&2a and metered Treated Effluent flow (Meter 3) from the Stage 2b biofilter. A positive value indicates an additional water input to the Stage 1&2a area (precipitation, irrigation, etc.) whereas a negative value indicates a water output (evapotranspiration, etc.).

²The additional volume in the Stage 1&2a flow as compared to the household water use meter is the volume returned to the septic tank during field flushing of the drip lines.

FLORIDA ONSITE SEWAGE NITROGEN REDUCTION STRATEGIES STUDY B-HS3 FIELD SYSTEM MONITORING REPORT NO. 8 The average household water use since the PNRS system start-up was 116.6 gallons per day with periods of higher and lower flows. Since the PNRS system start-up, the average combined pumped flow (flow to the Stage 1&2a drip system and treated effluent drip system) was 282.6 gallons per day, the average calculated Stage 1&2a drip system (STE) flow was 145.3 gallons per day and the average treated effluent drip system (STE) flow was 145.3 gallons per day and the average treated effluent drip system (Stage 2b biofilter effluent) flow was 137.2 gallons per day. The calculated Stage 1&2a drip system (STE) flow includes pumped water used for field flushing of the drip lines, which is returned to the septic tank after flushing. This is the reason that the calculated STE flow is considerably higher than the flow measured by the household potable water meter. Actual system treated flow is probably closer to the potable water meter flow value.

The difference between the flow to the Stage 1&2a drip system (STE) and the treated effluent drip system (Stage 2b biofilter effluent) are due to water inputs and outputs. Water inputs include precipitation, applied STE, and any lawn irrigation water collected in the Stage 1&2a lined area. Water outputs include evapotranspiration. The last column in Table 3 summarizes the difference in the Stage 1&2a and treated effluent flows for each time period. The positive values indicate higher treated effluent flow (water inputs) which are likely attributed to precipitation and irrigation water collected in the lined area. The negative values indicate higher Stage 1&2a flow (water outputs) which is likely attributed to evapotranspiration. Overall, there was a net loss of water equal to approximately 8.1 gallons per day.

A weather station (Lake Wayman Heights, Longwood, FL) is located approximately 5 miles from the site. Data from this weather station is available at the following website: http://www.wunderground.com. Recorded meteorological data is provided in Appendix C, Table C.1 from this weather station. Table 4 provides daily precipitation totals leading up to and during the sample event. There was approximately 0.01 inches of rain in the 5 days ending on December 17th.

FLORIDA ONSITE SEWAGE NITROGEN REDUCTION STRATEGIES STUDY B-HS3 FIELD SYSTEM MONITORING REPORT NO. 8

Table 4
Precipitation Data Daily Totals Measured December 1, 2014 through December 17, 2014
Sample Event No. 8

Date	Precipitation (inches)				
12/1/2014	0				
12/2/2014	0.01				
12/3/2014	0				
12/4/2014	0				
12/5/2014	0.01				
12/6/2014	0.01				
12/7/2014	0.11				
12/8/2014	0.11				
12/9/2014	0				
12/10/2014	0				
12/11/2014	0				
12/12/2014	0				
12/13/2014	0.01				
12/14/2014	0				
12/15/2014	0				
12/16/2014	0				
12/17/2014	0				

4.2 Energy, Chemical and/or Additives Consumption

Energy consumption is monitored using an electrical meter installed between the main power box for the house and the control panel to record cumulative power usage of the pump in kilowatt-hours. The recorded electrical use for the system is summarized in Table 5. The total average electrical use through December 17, 2014 was 0.90 kWh per day. The average electrical use per 1,000 gallons treated was 6.168 kWh per 1,000 gallons, and this parameter varies based on the amount of additional pumped flow attributed to precipitation.

Summary of System Electrical Use						
Date and Time Read	Electrical Meter Reading	Average Daily Electrical Use between readings	Average Electrical Use Per Treated Gallon between readings	Average Electrical Use Per 1,000 Gallons Treated between readings		
	Cumulative (kWh)	(kWh/day)	(kWh/gal)	(kWh/ 1,000 gal)		
7/12/13 14:01	0.6	Start-up	Start-up	Start-up		
7/17/13 11:57	1.1	0.10	0.011	10.763		
7/29/13 9:52	8.9	0.65	0.036	36.456		
8/6/13 9:45	19.1	1.28	0.007	6.692		
8/12/13 11:07	27.9	1.45	0.006	6.351		
8/15/13 8:48	32.5	1.58	0.008	7.978		
9/5/13 15:31	69.6	1.74	0.023	22.959		
9/9/13 9:00	82.3	3.41	0.008	7.838		
9/17/13 10:12	86.2	0.48	0.006	5.725		
9/27/13 8:00	88.8	0.26	0.004	3.975		
9/30/13 8:00	90.6	0.60	0.005	4.580		
10/11/13 8:30	98.5	0.72	0.004	4.407		
10/17/13 11:00	104.7	1.02	0.005	5.430		
11/8/13 12:30	121.1	0.74	0.005	5.155		
11/27/13 9:10	135.6	0.77	0.005	5.334		
12/2/13 8:30	145.1	1.91	0.006	5.823		
12/4/13 8:51	146.8	0.84	0.000	0.000		
1/23/14 11:00	185.1	0.76	0.006	5.720		
1/30/14 9:00	192.3	1.04	0.006	6.352		
2/3/14 8:00	197.0	1.19	0.008	8.029		
2/4/14 8:15	198.0	0.99	0.011	10.753		
2/5/14 10:45	198.6	0.54	0.006	6.266		
2/6/14 10:45	199.3	0.73	0.005	4.556		
2/7/14 8:00	200.2	0.98	0.006	5.776		
2/12/14 10:00	205.7	1.08	0.013	12.760		
3/14/14 8:24	228.2	0.75	0.005	5.287		
4/3/14 8:45	248.3	1.00	0.007	6.537		
4/29/14 10:10	272.5	0.93	0.006	5.702		
5/29/14 10:00	290.2	0.59	0.006	6.066		
6/9/14 12:45	302.0	1.06	0.006	6.265		
7/11/14 14:45	327.3	0.79	0.006	5.903		
7/29/14 9:30	347.3	1.12	0.006	5.893		
8/22/14 7:30	361.4	0.59	0.006	5.939		
9/19/14 12:48	385.1	0.84	0.006	5.658		

Table 5 Summary of System Electrical Use

Table 5 (con't) Summary of System Electrical Use							
Date and Time Read	Electrical Meter Reading	Average Daily Electrical Use between readings	Average Electrical Use Per Treated Gallon between readings	Average Electrical Use Per 1,000 Gallons Treated between readings			
	Cumulative (kWh)	(kWh/day)	(kWh/gal)	(kWh/ 1,000 gal)			
10/23/14 15:45	420.7	1.04	0.007	6.936			
11/21/14 9:30	442.5	0.76	0.004	4.043			
12/17/14 8:00	469.2	1.03	0.006	5.691			
Total average start-up to 12/17/14		0.90	0.006	6.168			

FLORIDA ONSITE SEWAGE NITROGEN REDUCTION STRATEGIES STUDY B-HS3 FIELD SYSTEM MONITORING REPORT NO. 8

4.3 Water Quality

Water quality analytical results, for Sample Event No. 8 are listed in Table 6 and graphically displayed in Figure 11. The laboratory report containing the raw analytical data is included in Appendix A. The following discussion summarizes the water quality analytical results for the Sample Event No. 8. The performance of the various system components was compared by considering the changes through treatment of nitrogen species (TKN, NH₃-N, and NO_X-N), as well as supporting water quality parameters.

۵ 🗖	STE		AGE 1	STAGE 1&2a LINER	STAGE 2b SULFUR
Parameter	STE	Stage 1 effluent LY01	Stage 1 effluent LYO2	Stage 1/2a lignocellulosic effluent	Stage 2b sulfur effluent
CBOD ₅ mg/L	57	24	4	Non-detect	15
TKN mg N/L	52	3.6	4.9	4.2	1.5
NH ₃ mg N/L	43	Non-detect	Non-detect	0.7	0.43
NO _x mg N/L	0.4	30.0	40.0	11.0	0.03
TN mg N/L	52.4	33.6	44.9	15.2	1.5
Sulfate mg/L	22	68	77	69	250
Fecal Coliform (Ct/100mL)	68,000	Not analyzed	Not analyzed	3	7

Figure 11 Graphical Representation of Water Quality Results Sample Event No. 8, December 17, 2014

Septic Tank Effluent (STE) Quality: The water quality characteristics of STE collected in Sample Event 8 were within the typical range generally expected for domestic STE. The measured STE total nitrogen (TN) concentration was 52 mg/L, which is within the range that has been typically reported for Florida single family residence STE. The measured STE CBOD₅ was 57 mg/L which is in the low end of the typical range.

Stage 1 (Bottom of Sand Layer) Soil Suction Lysimeters (LY01 and LY02): The soil suction lysimeters LY01 and LY02 effluent NH₃-N levels were below the method detection limit of 0.009 mg/L (Table 6). The NO_x-N was 30 mg/L and 40 mg/L for LY01 and LY02, respectively. The Stage 1 biofilter sand layer showed nearly complete ammonium removal and significant removal of total nitrogen with an effluent concentration equal to

or less than: NH_3 -N below the method detection limit of 0.009 mg/L, NO_x-N of 40 mg/L and TKN of 4.9 mg/L.

Stage 1&2a (Bottom of Lignocellulosic Layer) Liner Effluent (Liner): The lignocellulosic (Stage 1&2a) effluent NH₃-N level was 0.66 mg/L with a DO level at 2.00 mg/L (Table 6). TSS was 2 mg/L, and CBOD₅ was below the method detection limit of 2 mg/L. The Stage 1&2a effluent NO_x-N was 11 mg/L. These results indicate nitrate removal by passage through the lignocellulosic/sand layer in the Stage 1&2a lined area (between 63 and 73% reduction of NO_x-N). The combined Stage 1&2a liner area biofilter showed ammonium removal and removal of NO_x-N with an effluent NH₃-N of 0.66 mg/L, NOx-N of 11 mg/L and TKN of 4.2 mg/L.

Stage 2b Biofilter (Sulfur) Effluent (ST2): Effluent NO_x-N from the Stage 2b sulfur media biofilter was 0.03 mg/L with a DO level at 0.1 mg/L and ORP at -215 mV. Final total nitrogen (TN) in the passive nitrogen removal system effluent was 1.53 mg/L. The Stage 2b biofilter effluent CBOD₅ concentration was 15 mg/L, TSS was below the method detection limit of 1 mg/L and sulfate was 250 mg/L.

As previously discussed in Section 3.3, Sample Event 8 also included a Stage 2b biofilter sample taken 6 inches within the sulfur media. The BHS3-SULFUR-6 stainless steel drivepoint sampler results from this event indicate that the NO_x-N was effectively reduced to 0.08 mg/L and sulfate concentration was 170 mg/L after passage through 6 inches of the sulfur media.

Treated Effluent Soil Suction Lysimeters (LY03 and LY04): The treated effluent drip system monitoring devices LY03 and LY04 NO_x-N concentrations were 5.6 mg/L and 2 mg/L, respectively, which is higher than the Stage 2b effluent concentration. This has been noted in each sampling event since system start-up. It appears that there must be another source of nitrogen to the effluent irrigation area, and it is suspected that fertilizer from the new sod installed in the area is still contributing to this result. The NO_x-N concentrations did appear to decrease with time following sod installation and in the winter months with less rainfall; however in March and June the NO_x-N concentrations increased possibly from sod fertilizer runoff in the rainy season (Figure 12).

Field Blank and Equipment Blank (FB & EB): Described in Section 3.5, the equipment blank (EB) and field blank (FB) results for most of the parameters measured were at or below the method detection limit. The slightly elevated parameters were TKN, total phosphorus and total organic carbon in both samples.




Figure 12 LY03 and LY04 NO_x-N Time Series

o:\44237-001R004\Wpdocs\Report\Final

Table 6Sample Event 8 Water Quality Results

BHS3-STE 12/17/2014 9:26 18.27 7.26 1055 0.19 -244.3 18 57 140 52.4 52 9 43 0.06 0.4 43.4 4.6 BHS3-ST1-LY01 12/17/2014 9:05 15.00 6.90 652 5.73 95.4 1 24 16 33.61 3.6 3.591 0.009 30 0.01 30.01 30.01 0.02 0.01 11.0 0.04 11.0 11.0 0.46 0.02 0.02 0.02 0.02 0.02 0.02 0.03 0.04 0.02 0.02 0.03 0.04 0.02 0.02 0.03 0.04 <	22 0.5 68 77 69 170	5 1.4	4 68000	61000	33
BHS3-ST1-LY02 12/17/2014 9:20 16.20 6.41 737 6.23 129.9 1 4 31 44.92 4.9 4.891 0.009 40 0.02 40.02 40.029 2.7 BHS3-ST1&2a-LINER 12/17/2014 8:35 18.50 6.80 810 2.00 89.5 2 2 22 15.24 4.2 3.54 0.66 11 0.04 11.0 11.7 0.46 BHS3-ST2b-SULFUR-6 12/17/2014 9:06 18.96 6.53 986 1.11 -241.6 38 2.58 2.5 1.77 0.73 0.06 0.02 0.08 0.81 BHS3-ST2b 12/17/2014 8:20 18.49 6.39 1067 0.10 -214.5 1 15 47 1.53 1.5 1.07 0.43 0.02 0.01 0.03 0.46 0.62 39 BHS3-ST2b 12/17/2014 8:20 18.49 6.39 1067 0.10 -214.5 1 15 47 1.53 1.57 1.07 0.43 0.02 0.01 0.03 0.46 0.62	77 69				
BHS3-ST1&2a-LINER 12/17/2014 8:35 18.50 6.80 810 2.00 89.5 2 2 2 15.24 4.2 3.54 0.66 11 0.04 11.7 0.46 BHS3-ST2b-SULFUR-6 12/17/2014 9:06 18.96 6.53 986 1.11 -241.6 38 2.58 2.5 1.77 0.73 0.06 0.02 0.08 0.81 BHS3-ST2b 12/17/2014 8:20 18.49 6.39 1067 0.10 -214.5 1 15 47 1.53 1.5 1.07 0.43 0.02 0.01 0.03 0.46 0.62 39	69				15
BHS3-ST2b-SULFUR-6 12/17/2014 9:06 18.96 6.53 986 1.11 -241.6 38 2.58 2.5 1.77 0.73 0.06 0.02 0.08 0.81 0.02 0.08 0.81 0.02 0.03 0.46 0.62 39 BHS3-ST2b 12/17/2014 8:20 18.49 6.39 1067 0.10 -214.5 1 15 47 1.53 1.5 1.07 0.43 0.02 0.01 0.03 0.46 0.62 39					
BHS3-ST2b 12/17/2014 8:20 18.49 6.39 1067 0.10 -214.5 1 15 47 1.53 1.5 1.07 0.43 0.02 0.01 0.03 0.46 0.62 39	170		3	2	12
BHS3-ST2b-DUP 12/17/2014 8:40 18.49 6.39 1067 0.10 -214.5 3 14 56 1.53 1.5 0.92 0.58 0.02 0.01 0.03 0.61 0.66 42	250 0.57	7 0.82	2 7	6.3	15
	240 0.57	7 0.82	2 4	3.1	12
BHS3-LY03 12/17/2014 11:10 18.30 6.64 760 6.05 181.0 1 2 16 7.21 1.6 1.18 0.42 5.6 0.01 5.61 6.03 0.33 25	160	0.1	1		1
BHS3-LY04 12/17/2014 9:30 15.40 6.80 753 6.75 153.8 1 2 12 2.92 0.91 0.901 0.009 2 0.01 2.01 2.01 0.33 27	160	0.1	1		1
BHS3-PZ07 12/17/2014 10:28 18.33 6.29 596 6.61 62.2 2 2 2 2.36 0.95 0.941 0.009 1.4 0.01 1.41 1.419 0.3 20	99 0.01	1 0.1	1 1	2	23
BHS3-PZ08 12/17/2014 10:04 18.54 6.56 658 4.01 55.9 91 2 33 1.65 0.83 0.821 0.009 0.81 0.01 0.82 0.829 0.59 24	140 0.01	1 0.1	1 1	2	19
BHS3-PZ09 12/17/2014 10:00 18.80 6.41 268 6.08 171.1 150 2 60 6.91 2.1 2.091 0.009 4.8 0.01 4.81 4.819 1.7 5.2	16 1.2	2 1.4	1 1	2	46
PZ-A7-6 12/17/2014 11:22 20.14 6.45 702 2.39 64.8 1.88 1.4 1.391 0.009 0.44 0.04 0.48 0.489 22	120				1
PZ-A7-8 12/17/2014 11:34 20.85 6.38 461 0.81 26.7 3.23 3.2 2.76 0.44 0.02 0.01 0.03 0.47 11	30				1
PZ-B8-5 12/17/2014 11:25 19.70 6.19 507 1.22 -2.8 16 1.64 1.6 1.43 0.17 0.03 0.01 0.04 0.21 23	55				1
PZ-B8-5-DUP 12/17/2014 11:30 20.00 6.13 505 1.22 -2.8 16 1.65 1.6 1.48 0.12 0.04 0.01 0.05 0.17 21	51				1
PZ-C06-5 12/17/2014 12:24 21.25 5.67 478 3.16 70.7 1.5 1.5 1.28 0.22 0.02 0.01 0.03 0.25 21	59				1
PZ-C10-6 12/17/2014 12:06 21.91 6.00 276 1.22 37.2 4.62 2.8 2.716 0.084 1.8 0.02 1.82 1.904 5.8	15				
EB 12/17/2014 10:40 17.50 6.00 1.94 8.41 15.0 1 2 10 0.23 0.2 0.191 0.009 0.01 0.03 0.039 0.18	0.2 0.01	1 0.1	1 1	2	3.1
FB 12/17/2014 10:50 18.40 6.01 2.47 8.29 144.8 1 2 10 0.18 0.15 0.141 0.009 0.02 0.01 0.03 0.03 0.2 0.15	0.2 0.01	1 0.1	1 1	2	0.64

Notes:

 $^1\text{Total}$ Nitrogen (TN) is a calculated value equal to the sum of TKN and NO $_{\chi}$

44237-001R004\Wpdc

²Organic Nitrogen (ON) is a calculated value equal to the difference of TKN and NH_{3.}

 3 Total Inorganic Nitrogen (TIN) is a calculated value equal to the sum of NH $_{3}$ and NO $_{\chi}$.


Gray-shaded data points indicate values below method detection level (mdl), mdl value used for statistical analyses.

Yellow-shaded data points indicate the reported value is between the laboratory method detection limit and the laboratory practical quantitation limit, value used for statistical analysis.

FLORIDA ONSITE SEWAGE NITROGEN REDUCTION STRATEGIES STUDY B-HS3 FIELD SYSTEM MONITORING REPORT NO. 8 PAGE 1-29 HAZEN AND SAWYER, P.C. **Groundwater Monitoring Standpipe Piezometers**: As discussed in Section 3.2.2, five downgradient groundwater monitoring points installed as part of the C-HS2 groundwater monitoring network were sampled during this event. Figure 13 depicts a site plan of maximum TN concentrations at all locations where groundwater samples were obtained during the four sample events (July 2011 through July 2012) conducted as part of the C-HS2 monitoring events (taken prior to PNRS installation). In addition, illustrated in Figure 13 are two transect cross sections A-A' and B-B'. For comparison, Figure 14 depicts the maximum TN concentration at all locations where groundwater samples were obtained during this sample event (December 17, 2014) along with similar transect cross section A-A'. Figure 15 is a time series plot of total nitrogen concentrations during the Task C monitoring. A significant decrease in total nitrogen concentration in the groundwater plume downgradient of the PNRS system has occurred since PNRS system installation (Figure 15).

FLORIDA ONSITE SEWAGE NITROGEN REDUCTION STRATEGIES STUDY B-HS2 FIELD SYSTEM MONITORING REPORT NO. 8

PAGE 1-30 HAZEN AND SAWYER, P.C.






Figure 14 B-HS3 TN Concentrations (December 17, 2014)

FLORIDA ONSITE SEWAGE NITROGEN REDUCTION STRATEGIES STUDY B-HS3 FIELD SYSTEM MONITORING REPORT NO. 8

PAGE 1-32 HAZEN AND SAWYER, P.C.




Figure 15 TN Time Series for Various Groundwater Wells

o:\44237-001R004\Wpdocs\Report\Final

FLORIDA ONSITE SEWAGE NITROGEN REDUCTION STRATEGIES STUDY B-HS3 FIELD SYSTEM MONITORING REPORT NO. 8

PAGE 1-33 HAZEN AND SAWYER, P.C.

4.4 Water Quality Monitoring Summary

A summary of the water quality data collected for the test system is presented in Table 7. Figure 16 provides a time series of influent and effluent TN over the study period. Figures 17 through 22 show box and whisker plots of the various monitoring points for the key parameters measured during the study period. Both Stage 1 monitoring points (LY01 and LY02) are shown separately, because the total nitrogen and NO_x-N results indicate consistent differences. The reason for the difference is unknown but could be attributed to the location of the ceramic cup relative to the lignocellulosic media, vicinity to a drip emitter, distribution of effluent, or other factors.




Figure 16 Total Nitrogen Time Series Graph August 15, 2013 through December 17, 2014

o:\44237-001R004\Wpdocs\Report\Final

 Table 7

 Summary of Water Quality Analytical Results

Sample ID	Statistic	Temp (°C)	рН	Specific Conducta nce (uS/cm)	DO (mg/L)	ORP (mV)	Total Alkalinity (mg/L)	TSS (mg/L)	VSS (mg/L)	CBOD₅ (mg/L)	COD (mg/L)	TN (mg/L N) ¹	TKN (mg/L N)	Organic N (mg/L N) ²	NH₃-N (mg/L N)	NO₃-N (mg/L N)	NO ₂ -N (mg/L N)	NOx (mg/L N)	TIN (mg/L N) ³	TP (mg/L)	Ortho P (mg/L P)	Chloride	Sulfate (mg/L)	Hydroge n Sulfide (mg/L)	Sulfide (mg/L)	Fecal (Ct/100 mL)	E-coli (Ct/100 mL)
	n	18	18	18	18	13	16	14	11	14	13			18	18	16		18	18	14	13	15	15	13	13	14	7
I H	MEAN	23.60	7.27		0.30	-288.82	414.38		21.27	78.29	178.46	59.99	59.83	10.78	49.06	0.09		0.16	49.22	5.59		54.20	20.75	3.28	7.91	62,180	28,671
	STD. DEV.	4.00		135.66	0.44	32.22	39.66	13.90	12.60	45.51	72.44	19.01	18.89	11.07	14.80	0.21	0.24	0.42	14.87	1.74	1.51	12.70	12.68	2.80	3.67		
I –	MIN	18.27	6.88		0.00	-341.70	330.00	12.00	9.00	42.00	120.00	30.05	30.00	0.00	27.00	0.01	0.01	0.02	27.05	3.50	2.20	39.00	0.82	0.01	1.00	20,000	10,000
	MAX	29.60	7.82	1322.00	1.20	-244.30	490.00	61.00	55.00	210.00	400.00	110.06	110.00	45.00	85.00	0.82	0.94	1.80	85.06	9.00	7.50	87.00	40.00	8.90	12.00	420,000	240,000
-	n	12	12		11	11	4	6	5	6	11	12		12	12	12		12	12	11	10	10	11	0	0	0	0
IStage 1	MEAN STD. DEV.	22.54 4.71	6.81	553.83 116.88	5.97 2.71	125.80 93.86	91.00 31.84	1.50 0.84	1.40 0.55	9.50 9.07	37.64 48.42	20.31 10.64	1.89 0.73	1.84 0.73	0.06	18.39 10.31	0.02	18.42 10.29	18.47 10.30	0.27	0.12	38.10 11.92	40.64				
ILY01	MIN	4.71	6.33	330.00	0.54	-75.00	55.00	1.00	1.00	2.00	10.00	2.50	0.73	0.73	0.08	1.30	0.03	1.30	1.38	0.29	0.21	11.92	21.00				
I –	MAX	30.90	7.24	711.00	9.92	301.90	130.00	3.00	2.00	2.00	180.00	34.30	3.60	3.59	0.01	33.00	0.01	33.00	33.01	0.03	0.01	61.00	68.00				
l i	n	13	13		13	13	130.00	3.00	2.00	24.00	100.00			13	13	13		13	13	12		11	12	0	0	1	1
i i	MEAN	22.59	6.55		4.48	113.04	134.80	2.00	1.63	6.00	24.25	30.45	2.34	2.16	0.17	27.99	0.08	28.12	28.29	2.10	1.56	42.27	45.00			1,000	2
Stage 1	STD. DEV.	4.56	0.00	90.31	2.84	79.46	45.88	1.50	1.41	6.87	11.92	12.04	1.27	1.41	0.43	11.69	0.15	11.76	11.82	0.97	0.95	7.70	14.27			1,000	
ILYU2	MIN	14.60	6.18		0.73	-25.30	74.00	1.00	1.00	2.00	10.00	9.90	1.00	0.10	0.01	7.10	0.01	7.10	7.12	0.18	0.01	23.00	26.00			1.000	2
	MAX	30.20	6.99		10.23	279.20	180.00	5.00	5.00	23.00	49.00	51.56	4.90	4.89	1.60	47.00	0.47	47.06	47.10	3.20	2.80	52.00	77.00			1,000	2
	n	13	13		13	13	11		11	12	12	-	13	13	13	13		13	13	12	11	11	11	5	5	12	11
Stage 1&2a	MEAN	22.91	6.72	730.54	2.66	-1.43	269.09	16.25	8.55	3.83	26.58	7.85	2.07	1.90	0.18	5.76	0.02	5.78	5.96	0.49	0.03	35.09	31.02	0.42	0.66	32	3
Lignoceullosic	STD. DEV.	4.44		101.04	2.43	93.98	42.06	34.47	12.34	3.66	13.53	4.72	0.82	0.68	0.21	4.36	0.02	4.36	4.44	0.83	0.06	7.78	18.15	0.42	0.60		
Effluent (Liner)	MIN	18.10	6.39	552.00	0.31	-199.70	210.00	1.00	1.00	2.00	10.00	0.99	0.93	0.89	0.04	0.01	0.01	0.02	0.07	0.01	0.01	15.00	5.50	0.01	0.10	1	2
	MAX	31.80	7.15	925.00	9.09	124.50	360.00	125.00	45.00	14.00	60.00	16.01	4.20	3.54	0.66	14.00	0.08	14.01	14.07	2.90	0.22	43.00	69.00	1.10	1.60	6,800	310
1	n	13	13	13	13	13	11	12	11	12	12	13	13	13	13	13	13	13	13	12	11	12	13	13	13	12	11
Stage 2b Sulfur	MEAN	22.40	6.79	860.15	0.25	-215.02	274.55	4.33	3.36	14.33	35.25	1.91	1.30	0.97	0.33	0.35	0.26	0.61	0.93	0.21	0.07	36.00	113.85	2.51	4.96	5	3
Effluent (ST2)	STD. DEV.	4.05		100.48	0.26	82.66	27.34	3.23	2.06	21.63	13.01	1.72	0.36	0.33	0.22	0.89	0.64	1.52	1.48	0.24	0.16	7.77	56.50	3.40	5.23		
1 · · ·	MIN	18.49	6.39	653.00	0.01	-299.90	240.00	1.00	1.00	2.00	10.00	0.84	0.82	0.44	0.02	0.01	0.01	0.02	0.04	0.01	0.01	15.00	27.00	0.01	0.10	1	2
[]	MAX	29.70	7.15	1067.00	0.91	38.20	310.00	12.00	6.00	81.00	50.00	7.10	1.80	1.58	0.87	3.20	2.10	5.30	5.52	0.62	0.51	45.00	250.00	12.00	16.00	300	10
<u> </u>	n	9	9	9	9	9	4	6	5	6	8	9	9	9	9	9	9	9	9	8	7	8	9	4	5	1	1
Ireated	MEAN	24.05	6.47	723.19	5.14	146.46	182.40	2.17	2.40	21.00	40.75	13.64	2.27	2.17	0.10	11.37	0.01	11.37	11.47	0.18		26.50	96.56	0.24	0.28	1	2
Effluent LY03	STD. DEV.	3.06		257.32	1.90	46.10	116.06	1.47	1.52	43.67	45.91	5.23	0.63	0.71	0.14	4.80	0.01	4.80	4.77	0.07	0.06	9.24	34.27	0.29	0.27		
	MIN	18.30	6.27	75.70	2.05	103.30	9.60	1.00	1.00	2.00	10.00	7.21	1.60	1.18	0.01	5.60	0.01	5.61	6.03	0.09	0.01	13.00	50.00	0.01	0.10	1	2
	MAX	29.00	6.64	934.00	9.09	248.70	250.00	4.00	4.00	110.00	150.00	21.60	3.60	3.57	0.42	18.00	0.05	18.00	18.04	0.33	0.13	38.00	160.00	0.60	0.71	1	2
	n MEAN	24.12	6.49	9 767.89	4.69	9 128.40	220.00	1.17	1.20	3.43	25.88	6.64	1.59	9 1.55	0.04	5.04	0.01	5.05	5.09	0.13	0.02	25.51	95.78	0.28	0.30	1	1
lireated –	STD. DEV.	3.93	0.49	68.47	2.52	58.10	38.99	0.41	0.45	2.70	13.87	5.89	1.03	1.01	0.04	4.89	0.01	4.89	4.91	0.13	0.02	13.49	37.48	0.28	0.30	1	2
IETTILIENT LY04	MIN	15.40	6.21	619.00	1.41	66.20	160.00	1.00	1.00	2.00	12.00	1.79	0.80	0.79	0.04	0.99	0.00	0.99	1.00	0.01	0.02	0.05	40.00	0.24	0.10	1	2
	MAX	29.40	6.80	821.00	9.98	265.50	270.00	2.00	2.00	9.00	56.00		4.00	3.91	0.01	17.00	0.01	17.00	17.09	0.33	0.01	42.00	160.00	0.01	0.60	1	2
t t	n	23.40		7	7	205.50	270.00	2.00	2.50	5.00	50.00	7	7	7	7	7	7	7	7	6.55	5		6	5	5	4	4
l b	MEAN	25.01	6.39	713.00	3.99	37.89	225.00	5.40	4.25	2.83	29.50	6.10	1.83	1.67	0.16	4.24	0.03	4.27	4.43	0.21	0.08	22.00	75.50	0.23	0.30	1	2
Groundwater	STD. DEV.	5.40	2.00	120.08	2.06	145.50	60.28	4.72	2.75	1.33	10.99	4.08	1.09	0.87	0.26	3.24	0.05	3.21	3.32	0.12	0.07	9.06	30.12	0.15	0.14		
IPZ07	MIN	18.33	6.18		0.59	-248.70	160.00	1.00	1.00	2.00	10.00	2.36	0.84	0.83	0.01	1.40	0.01	1.41	1.42	0.04	0.01	15.00	35.00	0.01	0.10	1	2
I –	MAX	34.70	6.74	833.00	6.61	189.60	290.00	11.00	7.00	5.00	43.00	12.30	4.00	3.26	0.74	10.00	0.15	10.00	10.08	0.37	0.17	40.00	120.00	0.35	0.41	1	2

FLORIDA ONSITE SEWAGE NITROGEN REDUCTION STRATEGIES STUDY B-HS2 FIELD SYSTEM MONITORING REPORT NO. 8 PAGE 1-35 HAZEN AND SAWYER, P.C.

 Table 7 (con't)

 Summary of Water Quality Analytical Results

	2			Specific		6	Total							Organic	5			17				2		Hydroge			
Sample ID	Statistic	Temp (°C)	рН	Conducta nce (uS/cm)	DO (mg/L)	ORP (mV)	Alkalinity (mg/L)	TSS (mg/L)	VSS (mg/L)	CBOD₅ (mg/L)	COD (mg/L)	TN (mg/LN) ¹	TKN (mg/L N)	N (mg/L N) ²	NH ₃ -N (mg/L N)	NO ₃ -N (mg/L N)	NO ₂ -N (mg/L N)	NOx (mg/L N)	TIN (mg/L N) ³	TP (mg/L)	Ortho P (mg/L P)	Chloride	Sulfate (mg/L)	n Sulfide (mg/L)	Sulfide (mg/L)	Fecal (Ct/100 mL)	E-coli (Ct/100 mL)
-	n	7	7	7	7	7	4	5	4	6	6	7	7	7	7	7	7	7	7	6	5	6	6	6	6	5	5
	MEAN	23.65	6.26	655.86	3.57	73.56	167.50	30.00	7.25	4.33	31.67	7.34	1.47	1.24	0.23	5.86	0.01	5.87	6.10	0.44	0.23	21.12	81.67	0.09	0.17	2	2
Groundwater	STD. DEV.	4.12		157.71	1.36	64.30	26.30	35.80	5.74	3.83	14.50	7.04	0.74	0.92	0.56	6.39	0.01	6.39	6.41	0.12	0.18	10.89	43.79	0.13	0.12	1	
PZ08	MIN	18.54	5.67	492.00	2.12	-21.90	130.00	4.00	2.00	2.00	10.00	1.65	0.83	0.00	0.01	0.81	0.01	0.82	0.83	0.29	0.05	7.70	35.00	0.01	0.10	1	2
	MAX	29.70	6.56	962.00	5.67	186.00	190.00	91.00	14.00	11.00	50.00	21.50	2.50	2.48	1.50	19.00	0.04	19.00	19.02	0.59	0.48	40.00	140.00	0.32	0.41	10	2
	n	6	6	6	6	6	3	4	3	4	5	6	6	6	6	6	6	6	6	5	4	5	5	5	5	4	4
Croundwater	MEAN	24.88	5.83	462.17	4.08	137.18	116.67	60.25	13.33	2.00	97.00	10.88	2.05	2.02	0.03	8.82	0.01	8.83	8.86	2.04	1.72	17.56	49.50	0.66	0.76	1	2
Groundwater PZ09	STD. DEV.	3.92		153.60	1.95	98.85	5.77	67.36	9.71	0.00	113.83	5.67	0.71	0.69	0.03	5.08	0.00	5.07	5.10	1.42	1.31	15.03	44.93	0.34	0.38		
F209	MIN	18.80	5.09	268.00	0.62	38.30	110.00	6.00	5.00	2.00	35.00	1.86	1.00	0.99	0.01	0.84	0.01	0.86	0.87	1.00	0.73	3.60	4.50	0.37	0.41	1	2
	MAX	28.90	6.41	629.00	6.08	256.40	120.00	150.00	24.00	2.00	300.00	17.10	3.10	3.03	0.07	14.00	0.02	14.00	14.07	4.50	3.50	41.00	110.00	1.20	1.40	1	2
13	n	12	12	12	12	8	9	0	0	0	3	12	12	12	12	9	8	12	12	2	1	10	9	0	0	1	1
Groundwater	MEAN	23.23	6.09	516.25	2.22	43.09	114.67				186.67	4.07	1.77	1.62	0.15	0.41	0.02	2.30	2.45	0.62	1.00	22.17	58.24			1	2
PZA7-6	STD. DEV.	3.23		178.44	1.87	99.17	49.59				15.28	5.80	1.07	1.03	0.11	0.57	0.02	5.03	5.07	0.51		10.05	40.90				
F 2A7-0	MIN	18.50	5.80	242.00	0.09	-51.40	58.00				170.00	0.58	0.56	0.44	0.01	0.01	0.01	0.02	0.04	0.26	1.00	5.70	0.20			1	2
	MAX	28.00	6.45	702.00	5.50	249.90	190.00				200.00	20.60	3.60	3.30	0.35	1.70	0.06	17.00	17.30	0.98	1.00	42.00	120.00			1	2
	n	13	13	13	13	8	10	0	0	0	4	13	13	13	13	11	11	13	13	2	2	11	10	0	0	1	1
Groundwater	MEAN	23.49	6.02	548.69	0.81	-14.08	108.30				90.50	12.42	3.05	2.27	0.78	6.07	0.03	9.38	10.16	5.00	3.00	22.45	46.90			1	2
PZA7-8	STD. DEV.	2.28		149.25	0.81	97.12	102.79	(57.88	12.16	1.48	1.24	1.19	8.25	0.04	11.85	11.97	0.42	1.41	11.53	21.05				
120,0	MIN	20.00	5.60	186.00	0.11	-200.20	2.00	1			36.00	1.24	0.89	0.58	0.01	0.02	0.01	0.03	0.47	4.70	2.00	3.90	14.00	1		1	2
	MAX	26.90	6.38	784.00	2.91	115.30	270.00				150.00	39.20	5.80	4.87	4.10	23.00	0.12	37.00	37.01	5.30	4.00	40.00	84.00			1	2
	n	13	13		13	8	10	0	0	0	5	13	13	13	13	12	11	13	13	2	3	11	12	0	0	1	1
Groundwater	MEAN	23.52	5.85	468.00	0.97	61.89	81.10				86.20	11.20	2.62	2.48	0.15	5.87	0.05	8.58	8.73	0.75	0.70	23.27	43.67			1	2
PZB8-5	STD. DEV.	2.84		80.98	0.94	86.19	46.30				51.74	13.67	1.09	1.18	0.16	9.16	0.06	12.84	12.77	0.92	0.26	6.50	22.01				
1200 5	MIN	19.70	5.50	296.00	0.10	-41.10	21.00				0.00	1.02	1.00	0.72	0.03	0.01	0.01	0.02	0.10	0.10	0.49	13.00	0.00			1	2
	MAX	29.00	6.19	586.00	3.51	213.30	180.00			Ç.	130.00	39.70	4.70	4.67	0.64	28.00	0.18	35.00	35.03	1.40	0.99	34.00	76.00			1	2
	n	12	12		11	7	9	. 0	0	0	4	12	12	12	12	8	8	12	12	2	0	10	7	0	0	1	1
Groundwater	MEAN	23.76	5.88	349.92	1.03	104.07					55.25	5.79	1.60	1.46	0.15	2.34	0.06	4.19	4.34	0.50		28.99	16.14			1	2
PZB8-7	STD. DEV.	2.24		87.33	1.75	68.30	25.17				23.82	6.38	0.57	0.60	0.21	5.54	0.10	5.92	5.93	0.38		11.60	10.68				
1200 /	MIN	20.84	5.46	249.00	0.10	32.10	2.00				36.00	0.77	0.75	0.60	0.01	0.01	0.01	0.02	0.10	0.23		6.90	4.00			1	2
	MAX	27.80	6.14	518.00	6.19	207.00	93.00				90.00	18.00	2.50	2.36	0.73	16.00	0.30	16.00	16.02	0.77		44.00	30.00			1	2
6	n	13	13		13	8	10	0	0	0	4	13	13	13	13	10	9	13	13	2	1	11	9	0	0	1	1
Groundwater	MEAN	24.15	5.92	364.90	1.18	26.61	119.20				97.75	5.40	3.48	2.86	0.62	1.19	0.02	1.92	2.54	0.10	0.01	15.83	13.93			1	2
PZC10-6	STD. DEV.	2.85		147.63	1.19	100.70	97.54		2		17.75	2.45	0.73	0.76	0.47	1.10	0.04	2.52	2.54	0.02		8.83	6.81				
	MIN	19.19	5.10	200.70	0.10	-70.70	15.00				77.00	2.98	2.70	1.50	0.08	0.01	0.01	0.02	0.21	0.08	0.01	5.80	4.00			1	2
	MAX	29.00	6.30	689.00	3.78	230.00	270.00				120.00	11.90	5.00	4.75	1.40	2.80	0.12	9.20	9.51	0.11	0.01	32.00	23.00			1	2

Notes:

 $^1\text{Total}$ Nitrogen (TN) is a calculated value equal to the sum of TKN and NO_{χ}

²Organic Nitrogen (ON) is a calculated value equal to the difference of TKN and NH_{3.}


 3 Total Inorganic Nitrogen (TIN) is a calculated value equal to the sum of NH $_{3}$ and NO $_{\chi}$.

Gray-shaded data points indicate values below method detection level (mdl), mdl value used for statistical analyses.

Yellow-shaded data points indicate the reported value is between the laboratory method detection limit and the laboratory practical quantitation limit, value used for statistical analysis.


FLORIDA ONSITE SEWAGE NITROGEN REDUCTION STRATEGIES STUDY B-BS3 FIELD SYSTEM MONITORING REPORT NO. 8

PAGE 1-36 HAZEN AND SAWYER, P.C.



FLORIDA ONSITE SEWAGE NITROGEN REDUCTION STRATEGIES STUDY B-HS3 FIELD SYSTEM MONITORING REPORT NO. 8

PAGE 1-37 HAZEN AND SAWYER, P.C.



o:\44237-001R004\Wpdocs\Report\Final

20

10

0

STE

Figure 20 Ammonia N (NH3-N) Box and Whisker Plot

Stage 1-LYO2

Stage 1-LYO1

FLORIDA ONSITE SEWAGE NITROGEN REDUCTION STRATEGIES STUDY B-HS3 FIELD SYSTEM MONITORING REPORT NO. 8

Stage 2b-Sulfur

Stage 2a-Ligno




Figure 21 Nitrate+Nitrite Nitrogen (NOx-N) Box and Whisker Plot




Figure 22 Sulfate (SO₄) Box and Whisker Plot

FLORIDA ONSITE SEWAGE NITROGEN REDUCTION STRATEGIES STUDY B-HS3 FIELD SYSTEM MONITORING REPORT NO. 8

PAGE 1-39 HAZEN AND SAWYER, P.C.

5.0 B-HS3 Sample Event No. 8: Summary and Recommendations

5.1 Summary

The results of the eighth sampling event indicate that the system is operating well and no adjustments are recommended at this time. The Sample Event No. 8 results indicate that:

- Septic tank effluent (STE) quality is characteristic of typical household STE quality. The total nitrogen concentration of 52 mg/L is within the range of values typically reported for Florida single family residence STE. However, the CBOD₅ concentration of 57 mg/L is in the low end of the typical range of values.
- The combined Stage 1&2a lined drip system with lignocellulosic media was effective in converting ammonium to oxidized nitrogen; effluent contained 4.2 mg/L TKN, of which 0.66 mg/L was ammonia. The Stage 2a layer of lignocellulosic media produced a reducing environment and effluent NO_x-N was 11 mg/L.
- The Stage 2b sulfur media biofilter effluent NO_x-N was 0.03 mg/L.
- The total nitrogen concentration in the final effluent from the total treatment system was approximately 1.5 mg/L, an approximately 97% reduction from STE.

5.2 Conclusions

Sample Event 8 was the last funded sample event for the B-HS3 treatment system. Section 4.4 summarized the water quality data collected over the 1.4 year monitoring period for this system. These results indicate that:

- The septic tank effluent average total nitrogen concentration of 60 mg/L is in the range of values typically reported for Florida single family residence STE.
- The combined Stage 1&2a lined drip system with lignocellulosic media provided significant ammonia removal with an average NH₃-N concentration of 0.2 mg/L and average TKN of 2.1 mg/L. The average Stage 1&2a biofilter effluent NO_x-N was 5.8 mg/L. These results indicate significant NO_x-N removal (approximately 87% total nitrogen reduction) was occurring.
- The Stage 2b biofilter with sulfur media was effective in producing a reducing environment and achieving significant NO_x-N removal (average NO_x-N concentration of 0.61 mg/L). The average final total nitrogen (TN) in the treatment sys-

tem effluent was 1.9 mg/L, primarily TKN (average TKN concentration of 1.3 mg/L). This represents a 96 percent average reduction in total nitrogen from STE for this PNRS system over the study period.

 Additional monitoring of the downgradient groundwater monitoring points installed as part of the C-HS2 groundwater monitoring network showed a significant decrease in total nitrogen concentration in the groundwater plume downgradient of the PNRS system following PNRS system installation.

Further analysis of the results obtained at this site will occur as Task B results are compiled and summarized. The results of the data collected to date have provided insights into the performance of a full-scale passive single pass nitrogen reduction system monitored over an extended timeframe (523 experimental days) under actual onsite conditions.



Appendix A: Laboratory Report

FLORIDA ONSITE SEWAGE NITROGEN REDUCTION STRATEGIES STUDY B-HS3 FIELD SYSTEM MONITORING REPORT NO. 8

PAGE A-1 HAZEN AND SAWYER, P.C.

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-2218



December 31, 2014

Work Order: 1412942

Hazen and Sawyer 10002 Princess Palm Ave, Suite 200

Tampa, FL 33619

Laboratory Report

Project Name		BHS	3 SE#12					
Parameters	Units	Results *	Method	PQL	MDL	Prepared	Analyzed Dilu	ution
Sample Description		BHS3-STE						
Matrix		Wastewater						
SAL Sample Number		1412942-01						
Date/Time Collected		12/17/14 09:26						
Collected by		Josefin Hirst						
Date/Time Received		12/17/14 13:50						
Inorganics								
Hydrogen Sulfide (Unionized)	mg/L	0.50	SM 4550SF	0.04	0.01	12/24/14 10:01	12/24/14 10:06	1
Ammonia as N	mg/L	43	EPA 350.1	4.0	0.95		12/18/14 18:15	100
Carbonaceous BOD	mg/L	57	SM 5210B	2	2	12/18/14 12:07	12/23/14 11:06	1
Chemical Oxygen Demand	mg/L	140	EPA 410.4	25	10	12/22/14 10:37	12/22/14 12:39	1
Nitrate+Nitrite (N)	mg/L	0.40	EPA 353.2	0.04	0.01		12/30/14 15:33	1
Nitrite (as N)	mg/L	0.06	SM 4500NO2-B	0.04	0.01		12/30/14 11:46	1
Phosphorous - Total as P	mg/L	4.6	SM 4500P-E	0.80	0.20	12/18/14 15:47	12/22/14 13:43	20
Sulfate	mg/L	22	EPA 300.0	0.60	0.20		12/23/14 18:58	1
Sulfide	mg/L	1.4	SM 4500SF	0.40	0.10		12/23/14 13:56	1
Total Kjeldahl Nitrogen	mg/L	52	EPA 351.2	4.0	1.0	12/18/14 15:47	12/22/14 13:43	20
Total Organic Carbon	mg/L	33	SM 5310B	10	0.60		12/19/14 14:08	10
Total Suspended Solids	mg/L	18	SM 2540D	1	1	12/18/14 08:28	12/19/14 16:06	1
Nitrate (as N)	mg/L	0.34	EPA 353.2	0.08	0.02		12/30/14 15:33	1
Microbiology								
E. Coli	MPN/100 mL	61,000	SM 9223B	2.0	2.0	12/17/14 14:42	12/18/14 09:47	1
Fecal Coliforms	CFU/100 ml	68,000	SM 9222D	1	1	12/17/14 14:41	12/18/14 14:03	1
Sample Description		BHS3-LY01						
Matrix		Wastewater						
SAL Sample Number		1412942-02						
Date/Time Collected		12/17/14 09:05						
Collected by		Josefin Hirst						
Date/Time Received		12/17/14 13:50						
Inorganics								
Ammonia as N	mg/L	0.009 U	EPA 350.1	0.040	0.009		12/18/14 16:37	1
Carbonaceous BOD	mg/L	24	SM 5210B	2	2	12/18/14 12:07	12/23/14 11:06	1
Chemical Oxygen Demand	mg/L	16 I	EPA 410.4	25	10	12/22/14 10:37	12/22/14 12:39	1
Nitrate+Nitrite (N)	mg/L	30	EPA 353.2	0.96	0.24		12/18/14 16:55	24
Nitrite (as N)	mg/L	0.01 U	SM 4500NO2-B	0.04	0.01		12/17/14 16:05	1
Phosphorous - Total as P	mg/L	0.92	SM 4500P-E	0.20	0.050	12/18/14 15:47	12/22/14 13:43	5
Sulfate	mg/L	68	EPA 300.0	0.60	0.20		12/23/14 19:09	1
Total Kjeldahl Nitrogen	mg/L	3.6	EPA 351.2	1.0	0.25	12/18/14 15:47	12/22/14 13:43	5
Total Organic Carbon	mg/L	15	SM 5310B	1.0	0.060		12/19/14 14:08	1
Total Suspended Solids	mg/L	171	SM 2540D	1	1	12/18/14 08:28	12/19/14 16:06	1
Nitrate (as N)	mg/L	30	EPA 353.2	1.0	0.25		12/18/14 16:55	24

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-2218



December 31, 2014

Work Order: 1412942

Hazen and Sawyer 10002 Princess Palm Ave, Suite 200

Tampa, FL 33619

Laboratory Report

Project Name		BHS	3 SE#12					
Parameters	Units	Results *	Method	PQL	MDL	Prepared	Analyzed [liution
Sample Description		BHS3-LY02						
Matrix		Wastewater						
SAL Sample Number		1412942-03						
Date/Time Collected		12/17/14 09:20						
Collected by		Josefin Hirst						
Date/Time Received		12/17/14 13:50						
Inorganics								
Ammonia as N	mg/L	0.009 U	EPA 350.1	0.040	0.009		12/18/14 16:3	91
Carbonaceous BOD	mg/L	4	SM 5210B	2	2	12/18/14 12:07	12/23/14 11:0	51
Chemical Oxygen Demand	mg/L	31	EPA 410.4	25	10	12/22/14 10:37	12/22/14 12:3	91
Nitrate+Nitrite (N)	mg/L	40	EPA 353.2	0.96	0.24		12/18/14 16:5	6 24
Nitrite (as N)	mg/L	0.02	SM 4500NO2-B	0.04	0.01		12/17/14 16:0	61
Phosphorous - Total as P	mg/L	2.7	SM 4500P-E	0.20	0.050	12/18/14 15:47	12/22/14 13:4	35
Sulfate	mg/L	77	EPA 300.0	0.60	0.20		12/23/14 19:2	0 1
Total Kjeldahl Nitrogen	mg/L	4.9	EPA 351.2	1.0	0.25	12/18/14 15:47	12/22/14 13:4	35
Total Suspended Solids	mg/L	1 U	SM 2540D	1	1	12/18/14 08:28	12/19/14 16:0	61
Nitrate (as N)	mg/L	40	EPA 353.2	1.0	0.25		12/18/14 16:5	6 24
Sample Description		BHS3-LINER						
Matrix		Wastewater						
SAL Sample Number		1412942-04						
Date/Time Collected		12/17/14 08:35						
Collected by		Josefin Hirst						
Date/Time Received		12/17/14 13:50						
Inorganics								
Ammonia as N	mg/L	0.66	EPA 350.1	0.040	0.009		12/18/14 16:4	
Carbonaceous BOD	mg/L	2 U	SM 5210B	2	2	12/18/14 12:07	12/23/14 11:0	
Chemical Oxygen Demand	mg/L	22 I	EPA 410.4	25	10	12/22/14 10:37	12/22/14 12:3	91
Nitrate+Nitrite (N)	mg/L	11	EPA 353.2	0.96	0.24		12/18/14 16:5	7 24
Nitrite (as N)	mg/L	0.04	SM 4500NO2-B	0.04	0.01		12/17/14 16:0	6 1
Phosphorous - Total as P	mg/L	0.46	SM 4500P-E	0.20	0.050	12/18/14 15:47	12/22/14 13:4	35
Sulfate	mg/L	69	EPA 300.0	0.60	0.20		12/23/14 19:3	21
Total Kjeldahl Nitrogen	mg/L	4.2	EPA 351.2	1.0	0.25	12/18/14 15:47	12/22/14 13:4	35
Total Organic Carbon	mg/L	12	SM 5310B	1.0	0.060		12/19/14 14:0	81
Total Suspended Solids	mg/L	2	SM 2540D	1	1	12/18/14 08:28	12/19/14 16:0	61
Nitrate (as N)	mg/L	11	EPA 353.2	1.0	0.25		12/18/14 16:5	7 24
Microbiology								
E. Coli	MPN/100 mL	2.0 U	SM 9223B	2.0	2.0	12/17/14 14:42	12/18/14 09:4	71
Fecal Coliforms	CFU/100 ml	3	SM 9222D	1	1	12/17/14 14:41	12/18/14 14:0	3 1

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-2218



December 31, 2014

Work Order: 1412942

Hazen and Sawyer 10002 Princess Palm Ave, Suite 200

Tampa, FL 33619

Laboratory Report

Project Name		BHS	3 SE#12					
Parameters	Units	Results *	Method	PQL	MDL	Prepared	Analyzed	lilution
Sample Description Matrix SAL Sample Number		BHS3-SULFUR-6 Wastewater 1412942-05						
Date/Time Collected Collected by		12/17/14 09:06 Josefin Hirst						
Date/Time Received		12/17/14 13:50						
Inorganics								
Ammonia as N	mg/L	0.73	EPA 350.1	0.040	0.009		12/18/14 16:4	31
Carbonaceous BOD	mg/L	38	SM 5210B	2	2	12/18/14 12:07	12/23/14 11:0	61
Nitrate+Nitrite (N)	mg/L	0.08	EPA 353.2	0.04	0.01		12/19/14 14:5	91
Nitrite (as N)	mg/L	0.02	SM 4500NO2-B	0.04	0.01		12/17/14 16:0	7 1
Sulfate	mg/L	170	EPA 300.0	6.0	2.0		12/26/14 10:1	7 10
Total Kjeldahl Nitrogen	mg/L	2.5	EPA 351.2	1.0	0.25	12/18/14 15:47	12/22/14 13:4	35
Nitrate (as N)	mg/L	0.06 I	EPA 353.2	0.08	0.02		12/19/14 14:5	9 1
Sample Description Matrix SAL Sample Number Date/Time Collected Collected by Date/Time Received		BHS3-ST2 Wastewater 1412942-06 12/17/14 08:20 Josefin Hirst 12/17/14 13:50						
Inorganics		0.57	014 455005	0.04	0.04			
Hydrogen Sulfide (Unionized)	mg/L	0.57	SM 4550SF	0.04	0.01	12/24/14 10:01	12/24/14 10:0	
Ammonia as N	mg/L	0.43	EPA 350.1	0.040	0.009		12/18/14 16:4	
Carbonaceous BOD	mg/L	15	SM 5210B	2	2	12/18/14 12:07	12/23/14 11:0	
Chemical Oxygen Demand	mg/L	47	EPA 410.4	25	10	12/22/14 10:37	12/22/14 12:3	
Chloride	mg/L	39	EPA 300.0	0.20	0.050		12/23/14 19:5	
Nitrate+Nitrite (N)	mg/L	0.01 I	EPA 353.2	0.04	0.01		12/19/14 14:5	91
Nitrite (as N)	mg/L	0.01 l	SM 4500NO2-B	0.04	0.01		12/17/14 16:0	8 1
Phosphorous - Total as P	mg/L	0.62	SM 4500P-E	0.040	0.010	12/18/14 15:47	12/22/14 13:4	31
Sulfate	mg/L	250	EPA 300.0	6.0	2.0		12/26/14 10:2	6 10
Sulfide	mg/L	0.82	SM 4500SF	0.40	0.10		12/23/14 13:5	61
Total Kjeldahl Nitrogen	mg/L	1.5	EPA 351.2	0.20	0.05	12/18/14 15:47	12/22/14 13:4	31
Total Organic Carbon	mg/L	15	SM 5310B	1.0	0.060		12/19/14 14:0	81
Total Suspended Solids	mg/L	1 U	SM 2540D	1	1	12/18/14 08:28	12/19/14 16:0	61
Nitrate (as N)	mg/L	0.02 U	EPA 353.2	0.08	0.02		12/19/14 14:5	91
Microbiology	-							
E. Coli	MPN/100 mL	6.3	SM 9223B	2.0	2.0	12/17/14 14:42	12/18/14 09:4	7 1
Fecal Coliforms	CFU/100 ml	7	SM 9222D	1	1	12/17/14 14:41	12/18/14 14:0	3 1

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-2218



December 31, 2014

Work Order: 1412942

Hazen and Sawyer 10002 Princess Palm Ave, Suite 200

Tampa, FL 33619

Laboratory Report

Project Name		BHS	3 SE#12					
Parameters	Units	Results *	Method	PQL	MDL	Prepared	Analyzed Dil	ution
Sample Description		BHS3-ST2-DUP						
Matrix		Wastewater						
SAL Sample Number		1412942-07						
Date/Time Collected		12/17/14 08:40						
Collected by		Josefin Hirst						
Date/Time Received		12/17/14 13:50						
Inorganics								
Hydrogen Sulfide (Unionized)	mg/L	0.57	SM 4550SF	0.04	0.01	12/24/14 10:01	12/24/14 10:06	1
Ammonia as N	mg/L	0.58	EPA 350.1	0.040	0.009		12/18/14 16:46	1
Carbonaceous BOD	mg/L	14	SM 5210B	2	2	12/18/14 12:07	12/23/14 11:06	1
Chemical Oxygen Demand	mg/L	56	EPA 410.4	25	10	12/22/14 10:37	12/22/14 12:39	1
Chloride	mg/L	42	EPA 300.0	0.20	0.050		12/23/14 20:05	1
Nitrate+Nitrite (N)	mg/L	0.01 U	EPA 353.2	0.04	0.01		12/19/14 15:00	1
Nitrite (as N)	mg/L	0.01 I	SM 4500NO2-B	0.04	0.01		12/17/14 16:09	1
Phosphorous - Total as P	mg/L	0.66	SM 4500P-E	0.040	0.010	12/18/14 15:47	12/22/14 13:43	1
Sulfate	mg/L	240	EPA 300.0	6.0	2.0		12/23/14 20:05	10
Sulfide	mg/L	0.82	SM 4500SF	0.40	0.10		12/23/14 13:56	1
Total Kjeldahl Nitrogen	mg/L	1.5	EPA 351.2	0.20	0.05	12/18/14 15:47	12/22/14 13:43	1
Total Organic Carbon	mg/L	12	SM 5310B	1.0	0.060		12/19/14 14:08	1
Total Suspended Solids	mg/L	3	SM 2540D	1	1	12/18/14 08:28	12/19/14 16:06	1
Nitrate (as N)	mg/L	0.02 U	EPA 353.2	0.08	0.02		12/19/14 15:00	1
Microbiology								
E. Coli	MPN/100 mL	3.1	SM 9223B	2.0	2.0	12/17/14 14:42	12/18/14 09:47	1
Fecal Coliforms	CFU/100 ml	4	SM 9222D	1	1	12/17/14 14:41	12/18/14 14:03	1
Sample Description		BHS3-LY03						
Matrix		Wastewater						
SAL Sample Number		1412942-08						
Date/Time Collected		12/17/14 11:10						
Collected by		Josefin Hirst						
Date/Time Received		12/17/14 13:50						
Inorganics								
Ammonia as N	mg/L	0.42	EPA 350.1	0.040	0.009		12/18/14 16:48	1
Carbonaceous BOD	mg/L	2	SM 5210B	2	2	12/18/14 12:07	12/23/14 11:06	1
Chemical Oxygen Demand	mg/L	16 I	EPA 410.4	25	10	12/22/14 10:37	12/22/14 12:39	1
Chloride	mg/L	25	EPA 300.0	0.20	0.050		12/23/14 20:16	1
Nitrate+Nitrite (N)	mg/L	5.6	EPA 353.2	0.20	0.05		12/19/14 15:01	5
Nitrite (as N)	mg/L	0.01 U	SM 4500NO2-B	0.04	0.01		12/17/14 16:10	1
Phosphorous - Total as P	mg/L	0.33	SM 4500P-E	0.040	0.010	12/18/14 15:47	12/22/14 13:43	1
Sulfate	mg/L	160	EPA 300.0	6.0	2.0		12/23/14 20:16	10
Sulfide	mg/L	0.10 U	SM 4500SF	0.40	0.10		12/23/14 13:56	1
Total Kjeldahl Nitrogen	mg/L	1.6	EPA 351.2	0.20	0.05	12/18/14 15:47	12/22/14 13:43	1

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-2218



December 31, 2014

Work Order: 1412942

Hazen and Sawyer

10002 Princess Palm Ave, Suite 200

Tampa, FL 33619

Laboratory Report

Project Name		BHS	3 SE#12					
Parameters	Units	Results *	Method	PQL	MDL	Prepared	Analyzed Dilu	ution
Sample Description		BHS3-LY03						
Matrix		Wastewater						
SAL Sample Number		1412942-08						
Date/Time Collected		12/17/14 11:10						
Collected by		Josefin Hirst						
Date/Time Received		12/17/14 13:50						
Total Suspended Solids	mg/L	1	SM 2540D	1	1	12/18/14 08:28	12/19/14 16:06	1
Nitrate (as N)	mg/L	5.6	EPA 353.2	0.24	0.06		12/19/14 15:01	5
Sample Description		BHS3-LY09						
Matrix		Wastewater						
SAL Sample Number		1412942-09						
Date/Time Collected		12/17/14 09:30						
Collected by		Josefin Hirst						
Date/Time Received		12/17/14 13:50						
Inorganics								
Ammonia as N	mg/L	0.009 U	EPA 350.1	0.040	0.009		12/18/14 16:56	1
Carbonaceous BOD	mg/L	2 U	SM 5210B	2	2	12/18/14 12:07	12/23/14 11:06	1
Chemical Oxygen Demand	mg/L	12 I	EPA 410.4	25	10	12/22/14 10:37	12/22/14 12:39	1
Chloride	mg/L	27	EPA 300.0	0.20	0.050		12/23/14 21:01	1
Nitrate+Nitrite (N)	mg/L	2.0	EPA 353.2	0.20	0.05		12/19/14 15:02	5
Nitrite (as N)	mg/L	0.01 U	SM 4500NO2-B	0.04	0.01		12/17/14 16:14	1
Phosphorous - Total as P	mg/L	0.33	SM 4500P-E	0.040	0.010	12/18/14 15:47	12/22/14 13:43	1
Sulfate	mg/L	160	EPA 300.0	6.0	2.0		12/23/14 21:01	10
Sulfide	mg/L	0.10 U	SM 4500SF	0.40	0.10		12/23/14 13:56	1
Total Kjeldahl Nitrogen	mg/L	0.91	EPA 351.2	0.20	0.05	12/18/14 15:47	12/22/14 13:43	1
Total Suspended Solids	mg/L	1	SM 2540D	1	1	12/18/14 08:28	12/19/14 16:06	1
Nitrate (as N)	mg/L	2.0	EPA 353.2	0.24	0.06		12/19/14 15:02	5
Sample Description		BHS3-PZ-07						
Matrix		Wastewater						
SAL Sample Number		1412942-10						
Date/Time Collected		12/17/14 10:28						
Collected by		Josefin Hirst						
Date/Time Received		12/17/14 13:50						
Inorganics								
Hydrogen Sulfide (Unionized)	mg/L	0.01 U	SM 4550SF	0.04	0.01	12/24/14 10:01	12/24/14 10:06	1
Ammonia as N	mg/L	0.009 U	EPA 350.1	0.040	0.009		12/18/14 16:58	1
Carbonaceous BOD	mg/L	2 U	SM 5210B	2	2	12/18/14 12:07	12/23/14 11:06	1
Chemical Oxygen Demand	mg/L	27	EPA 410.4	25	10	12/22/14 10:37	12/22/14 12:39	1
Chloride	mg/L	20	EPA 300.0	0.20	0.050		12/23/14 21:12	1
Nitrate+Nitrite (N)	mg/L	1.4	EPA 353.2	0.04	0.01		12/19/14 15:03	1

Florida Certification Number: E84129 NELAP Accredited

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-2218



December 31, 2014

Work Order: 1412942

Hazen and Sawyer 10002 Princess Palm Ave, Suite 200

Tampa, FL 33619

Laboratory Report

Project Name		BHS	3 SE#12					
Parameters	Units	Results *	Method	PQL	MDL	Prepared	Analyzed D	ilution
Sample Description Matrix SAL Sample Number Date/Time Collected Collected by		BHS3-PZ-07 Wastewater 1412942-10 12/17/14 10:28 Josefin Hirst						
Date/Time Received		12/17/14 13:50						
Nitrite (as N)	mg/L	0.01 U	SM 4500NO2-B	0.04	0.01		12/17/14 16:1	51
Phosphorous - Total as P	mg/L	0.30	SM 4500P-E	0.040	0.010	12/18/14 15:47	12/22/14 13:43	31
Sulfate	mg/L	99	EPA 300.0	0.60	0.20		12/23/14 21:12	2 1
Sulfide	mg/L	0.10 U	SM 4500SF	0.40	0.10		12/23/14 13:50	31
Total Kjeldahl Nitrogen	mg/L	0.95	EPA 351.2	0.20	0.05	12/18/14 15:47	12/22/14 13:43	31
Total Organic Carbon	mg/L	23	SM 5310B	1.0	0.060		12/19/14 14:08	31
Total Suspended Solids	mg/L	2	SM 2540D	1	1	12/18/14 08:28	12/19/14 16:0	51
Nitrate (as N)	mg/L	1.4	EPA 353.2	0.08	0.02		12/19/14 15:03	31
Microbiology								
E. Coli	MPN/100 mL	2.0 U	SM 9223B	2.0	2.0	12/17/14 14:42	12/18/14 09:4	7 1
Fecal Coliforms	CFU/100 ml	1 U	SM 9222D	1	1	12/17/14 14:41	12/18/14 14:03	31
Matrix SAL Sample Number Date/Time Collected Collected by Date/Time Received		Wastewater 1412942-11 12/17/14 10:04 Josefin Hirst 12/17/14 13:50						
Inorganics								
Hydrogen Sulfide (Unionized)	mg/L	0.01 U	SM 4550SF	0.04	0.01	12/24/14 10:01	12/24/14 10:00	51
Ammonia as N	mg/L	0.009 U	EPA 350.1	0.040	0.009		12/18/14 17:0	D 1
Carbonaceous BOD	mg/L	2 U	SM 5210B	2	2	12/18/14 12:07	12/23/14 11:06	5 1
Chemical Oxygen Demand	mg/L	33	EPA 410.4	25	10	12/22/14 10:37	12/22/14 12:39	91
Chloride	mg/L	24	EPA 300.0	0.20	0.050		12/23/14 21:24	4 1
Nitrate+Nitrite (N)	mg/L	0.83	EPA 353.2	0.04	0.01		12/19/14 15:04	
Nitrite (as N)	mg/L	0.01 l	SM 4500NO2-B	0.04	0.01		12/17/14 16:1	5 1
Phosphorous - Total as P	mg/L	0.59	SM 4500P-E	0.040	0.010	12/18/14 15:47	12/22/14 13:43	31
Sulfate	mg/L	140	EPA 300.0	6.0	2.0		12/26/14 10:30	
Sulfide	mg/L	0.10 U	SM 4500SF	0.40	0.10		12/23/14 13:50	
Total Kjeldahl Nitrogen	mg/L	0.83	EPA 351.2	0.20	0.05	12/18/14 15:47	12/22/14 13:43	
Total Organic Carbon	mg/L	19	SM 5310B	1.0	0.060		12/19/14 14:08	
Total Suspended Solids	mg/L	91	SM 2540D	1	1	12/18/14 08:28	12/19/14 16:0	
Nitrate (as N)	mg/L	0.81	EPA 353.2	0.08	0.02		12/19/14 15:04	4 1
<u>Microbiology</u>								
E. Coli	MPN/100 mL	2.0 U	SM 9223B	2.0	2.0	12/17/14 14:42	12/18/14 09:4	71
			SM 9222D					

Florida Certification Number: E84129 NELAP Accredited

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-2218



December 31, 2014

Work Order: 1412942

Hazen and Sawyer 10002 Princess Palm Ave, Suite 200

Tampa, FL 33619

Laboratory Report

Project Name		BHS3	SE#12					
Parameters	Units	Results *	Method	PQL	MDL	Prepared	Analyzed D	ilution
Sample Description		BHS3-PZ09						
Matrix		Wastewater						
SAL Sample Number		1412942-12						
Date/Time Collected		12/17/14 10:00						
Collected by		Josefin Hirst						
Date/Time Received		12/17/14 13:50						
Inorganics								
Hydrogen Sulfide (Unionized)	mg/L	1.2	SM 4550SF	0.04	0.01	12/24/14 10:01	12/24/14 10:06	3 1
Ammonia as N	mg/L	0.009 U	EPA 350.1	0.040	0.009		12/18/14 17:0 [.]	1 1
Carbonaceous BOD	mg/L	2 U	SM 5210B	2	2	12/18/14 12:07	12/23/14 11:06	6 1
Chemical Oxygen Demand	mg/L	60	EPA 410.4	25	10	12/22/14 10:37	12/22/14 12:39	ə 1
Chloride	mg/L	5.2	EPA 300.0	0.20	0.050		12/23/14 21:3	5 1
Nitrate+Nitrite (N)	mg/L	4.8	EPA 353.2	0.20	0.05		12/19/14 15:0	55
Nitrite (as N)	mg/L	0.01 I,J5	SM 4500NO2-B	0.04	0.01		12/17/14 16:10	6 1
Phosphorous - Total as P	mg/L	1.7	SM 4500P-E	0.040	0.010	12/18/14 15:47	12/22/14 13:43	31
Sulfate	mg/L	16	EPA 300.0	0.60	0.20		12/23/14 21:3	51
Sulfide	mg/L	1.4	SM 4500SF	0.40	0.10		12/23/14 13:56	6 1
Total Kjeldahl Nitrogen	mg/L	2.1	EPA 351.2	0.20	0.05	12/18/14 15:47	12/22/14 13:43	3 1
Total Organic Carbon	mg/L	46	SM 5310B	10	0.60		12/19/14 14:08	3 10
Total Suspended Solids	mg/L	150	SM 2540D	1	1	12/18/14 08:28	12/19/14 16:00	3 1
Nitrate (as N)	mg/L	4.8	EPA 353.2	0.24	0.06		12/19/14 15:0	55
Microbiology								
E. Coli	MPN/100 mL	2.0 U	SM 9223B	2.0	2.0	12/17/14 14:42	12/18/14 09:47	7 1
Fecal Coliforms	CFU/100 ml	1 U	SM 9222D	1	1	12/17/14 14:41	12/18/14 14:03	3 1
								-
Sample Description		PZ-A7-6						
Matrix		Wastewater						
SAL Sample Number Date/Time Collected		1412942-13						
Collected by		12/17/14 11:22						
Date/Time Received		Josefin Hirst 12/17/14 13:50						
Date/ fille Received		12/17/14 13:50						
Inorganics								
Ammonia as N	mg/L	0.009 U	EPA 350.1	0.040	0.009		12/18/14 17:03	
Chloride	mg/L	22	EPA 300.0	0.20	0.050		12/23/14 21:40	
Nitrate+Nitrite (N)	mg/L	0.48	EPA 353.2	0.04	0.01		12/19/14 13:08	
Nitrite (as N)	mg/L	0.04	SM 4500NO2-B	0.04	0.01		12/17/14 16:17	
Sulfate	mg/L	120	EPA 300.0	6.0	2.0		12/26/14 10:4	5 10
Total Kjeldahl Nitrogen	mg/L	1.4	EPA 351.2	0.20	0.05	12/18/14 15:47	12/22/14 13:43	31
Nitrate (as N)	mg/L	0.44	EPA 353.2	0.08	0.02		12/19/14 13:08	3 1

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-2218



December 31, 2014

Work Order: 1412942

Hazen and Sawyer 10002 Princess Palm Ave, Suite 200

Tampa, FL 33619

Laboratory Report

Project Name		BHS3	3 SE#12					
Parameters	Units	Results *	Method	PQL	MDL	Prepared	Analyzed	Dilution
Sample Description	F	PZ-A7-8						
Matrix		Vastewater						
SAL Sample Number		412942-14						
Date/Time Collected		2/17/14 11:34						
Collected by Date/Time Received		losefin Hirst 2/17/14 13:50						
Inorganics								
Ammonia as N	mg/L	0.44	EPA 350.1	0.040	0.009		12/18/14 17:0)5 1
Chloride	mg/L	11	EPA 300.0	0.20	0.050		12/23/14 21:	57 1
Nitrate+Nitrite (N)	mg/L	0.02 I	EPA 353.2	0.04	0.01		12/19/14 13:	10 1
Nitrite (as N)	mg/L	0.01 U	SM 4500NO2-B	0.04	0.01		12/17/14 16:	18 1
Sulfate	mg/L	30	EPA 300.0	0.60	0.20		12/23/14 21:	57 1
Total Kjeldahl Nitrogen	mg/L	3.2	EPA 351.2	0.20	0.05	12/18/14 15:47	12/22/14 13:4	43 1
Nitrate (as N)	mg/L	0.02	EPA 353.2	0.08	0.02		12/19/14 13:	10 1
Sample Description		PZ-B8-5						
Matrix		Vastewater						
SAL Sample Number Date/Time Collected		412942-15						
Collected by		2/17/14 11:25 Iosefin Hirst						
Date/Time Received		12/17/14 13:50						
Inorganics								
Ammonia as N	mg/L	0.17 J5	EPA 350.1	0.040	0.009		12/18/14 17:0	07 1
Chloride	mg/L	23	EPA 300.0	0.20	0.050		12/23/14 22:0)9 1
Nitrate+Nitrite (N)	mg/L	0.03 I	EPA 353.2	0.04	0.01		12/19/14 13:	12 1
Nitrite (as N)	mg/L	0.01 U	SM 4500NO2-B	0.04	0.01		12/18/14 12:0)9 1
Sulfate	mg/L	55	EPA 300.0	0.60	0.20		12/23/14 22:0)9 1
Total Kjeldahl Nitrogen	mg/L	1.6	EPA 351.2	0.20	0.05	12/18/14 15:47	12/22/14 13:4	43 1
Nitrate (as N)	mg/L	0.03 I	EPA 353.2	0.08	0.02		12/19/14 13:	12 1
Sample Description		Z-B8-5-DUP						
Matrix SAL Sample Number		Vastewater 412942-16						
Date/Time Collected		2/17/14 11:30						
Collected by		losefin Hirst						
Date/Time Received		2/17/14 13:50						
Inorganics								
Ammonia as N	mg/L	0.12	EPA 350.1	0.040	0.009		12/18/14 17:0	08 1
Chloride	mg/L	21	EPA 300.0	0.20	0.050		12/23/14 22:2	20 1

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-2218



December 31, 2014

Work Order: 1412942

Hazen and Sawyer

10002 Princess Palm Ave, Suite 200

Tampa, FL 33619

Laboratory Report

Project Name		BHS	3 SE#12					
Parameters	Units	Results *	Method	PQL	MDL	Prepared	Analyzed Di	ilution
Sample Description		PZ-B8-5-DUP						
Matrix		Wastewater						
SAL Sample Number		1412942-16						
Date/Time Collected		12/17/14 11:30						
Collected by		Josefin Hirst						
Date/Time Received		12/17/14 13:50						
Nitrite (as N)	mg/L	0.01 U	SM 4500NO2-B	0.04	0.01		12/18/14 12:09) 1
Sulfate	mg/L	51	EPA 300.0	0.60	0.20		12/23/14 22:20) 1
Total Kjeldahl Nitrogen	mg/L	1.6	EPA 351.2	0.20	0.05	12/18/14 15:47	12/22/14 13:43	; 1
Nitrate (as N)	mg/L	0.04 I	EPA 353.2	0.08	0.02		12/19/14 13:14	. 1
Sample Description		EB						
Matrix		Reagent Water						
SAL Sample Number		1412942-19						
Date/Time Collected		12/17/14 10:40						
Collected by		Josefin Hirst						
Date/Time Received		12/17/14 13:50						
Inorganics								
Hydrogen Sulfide (Unionized)	mg/L	0.01 U	SM 4550SF	0.04	0.01	12/24/14 10:01	12/24/14 10:06	; 1
Ammonia as N	mg/L	0.009 U	EPA 350.1	0.040	0.009		12/18/14 17:13	5 1
Carbonaceous BOD	mg/L	2 U	SM 5210B	2	2	12/18/14 12:07	12/23/14 11:06	1
Chemical Oxygen Demand	mg/L	10 U	EPA 410.4	25	10	12/22/14 10:37	12/22/14 12:39) 1
Nitrate+Nitrite (N)	mg/L	0.01 U	EPA 353.2	0.04	0.01		12/22/14 16:00) 1
Nitrite (as N)	mg/L	0.01 U	SM 4500NO2-B	0.04	0.01		12/17/14 16:21	
Phosphorous - Total as P	mg/L	0.18	SM 4500P-E	0.040	0.010	12/18/14 15:47	12/22/14 13:43	; 1
Sulfate	mg/L	0.20 U	EPA 300.0	0.60	0.20		12/23/14 22:42	2 1
Sulfide	mg/L	0.10 U	SM 4500SF	0.40	0.10		12/23/14 13:56	
Total Kjeldahl Nitrogen	mg/L	0.20	EPA 351.2	0.20	0.05	12/18/14 15:47	12/22/14 13:43	
Total Organic Carbon	mg/L	3.1	SM 5310B	1.0	0.060		12/19/14 14:08	
Total Suspended Solids	mg/L	1 U	SM 2540D	1	1	12/18/14 08:28	12/19/14 16:06	
Nitrate (as N)	mg/L	0.02 U	EPA 353.2	0.08	0.02	12/10/14 00.20	12/22/14 16:00	
Microbiology	ing/L	0.02 0	217(000.2	0.00	0.02		12/22/14 10.00	, ,
E. Coli	MPN/100 mL	2.0 U	SM 9223B	2.0	2.0	12/17/14 14:42	12/18/14 09:47	' 1
Fecal Coliforms	CFU/100 ml	1 U	SM 9222D	1	1	12/17/14 14:41	12/18/14 14:03	
			0	•			12/10/14 14:00	· ·
Sample Description		FB						
Matrix		Reagent Water						
SAL Sample Number		1412942-20						
Date/Time Collected		12/17/14 10:50						

Collected by

Date/Time Received

Josefin Hirst

12/17/14 13:50

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-2218



December 31, 2014

Work Order: 1412942

Hazen and Sawyer 10002 Princess Palm Ave, Suite 200

Tampa, FL 33619

Laboratory Report

Project Name		BHS	3 SE#12					
Parameters	Units	Results *	Method	PQL	MDL	Prepared	Analyzed Di	ilution
Sample Description		FB						
Matrix		Reagent Water						
SAL Sample Number		1412942-20						
Date/Time Collected		12/17/14 10:50						
Collected by		Josefin Hirst						
Date/Time Received		12/17/14 13:50						
Inorganics								
Hydrogen Sulfide (Unionized)	mg/L	0.01 U	SM 4550SF	0.04	0.01	12/24/14 10:01	12/24/14 10:06	6 1
Ammonia as N	mg/L	0.009 U	EPA 350.1	0.040	0.009		12/18/14 17:15	5 1
Carbonaceous BOD	mg/L	2 U	SM 5210B	2	2	12/18/14 12:07	12/23/14 11:06	1
Chemical Oxygen Demand	mg/L	10 U	EPA 410.4	25	10	12/22/14 10:37	12/22/14 12:39) 1
Nitrate+Nitrite (N)	mg/L	0.01 U	EPA 353.2	0.04	0.01		12/18/14 15:41	1
Nitrite (as N)	mg/L	0.01 U	SM 4500NO2-B	0.04	0.01		12/17/14 16:21	1
Phosphorous - Total as P	mg/L	0.20	SM 4500P-E	0.040	0.010	12/18/14 15:47	12/22/14 13:43	3 1
Sulfate	mg/L	0.20 U	EPA 300.0	0.60	0.20		12/23/14 22:53	3 1
Sulfide	mg/L	0.10 U	SM 4500SF	0.40	0.10		12/23/14 13:56	6 1
Total Kjeldahl Nitrogen	mg/L	0.15 I	EPA 351.2	0.20	0.05	12/18/14 15:47	12/22/14 13:43	3 1
Total Organic Carbon	mg/L	0.64 I	SM 5310B	1.0	0.060		12/19/14 14:08	3 1
Total Suspended Solids	mg/L	1 U	SM 2540D	1	1	12/18/14 08:28	12/19/14 16:06	6 1
Nitrate (as N)	mg/L	0.02 U	EPA 353.2	0.08	0.02		12/18/14 15:41	1
Microbiology								
E. Coli	MPN/100 mL	2.0 U	SM 9223B	2.0	2.0	12/17/14 14:42	12/18/14 09:47	' 1
Fecal Coliforms	CFU/100 ml	1 U	SM 9222D	1	1	12/17/14 14:41	12/18/14 14:03	3 1

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-2218



December 31, 2014

Work Order: 1412942

Hazen and Sawyer

10002 Princess Palm Ave, Suite 200

Tampa, FL 33619

Analyte	Result	PQL	MDL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
Batch BL41724 - Nitrite SM 45	500NO2-B by se	eal								
Blank (BL41724-BLK1)					Prepared 8	Analyzed:	12/17/14 16	5:01		
Nitrite (as N)	0.01 U	0.04	0.01	mg/L						
Blank (BL41724-BLK2)					Prepared 8	Analyzed:	12/17/14 16	6:25		
Nitrite (as N)	0.01 U	0.04	0.01	mg/L						
LCS (BL41724-BS1)					Prepared 8	Analyzed:	12/17/14 16	5:01		
Nitrite (as N)	0.0765	0.04	0.01	mg/L	0.080		96	90-110		
LCS (BL41724-BS2)					Prepared 8	Analyzed:	12/17/14 16	6:26		
Nitrite (as N)	0.0817	0.04	0.01	mg/L	0.080		102	90-110		
Matrix Spike (BL41724-MS1)		Source: 1	412942-01		Prepared 8	Analyzed:	12/30/14 11	:46		
Nitrite (as N)	0.134	0.04	0.01	mg/L	0.10	0.0608	73	77-119		
Matrix Spike (BL41724-MS2)		Source: 1	412942-12		Prepared 8	Analyzed:	12/17/14 16	6:12		
Nitrite (as N)	0.0853 J2	0.04	0.01	mg/L	0.10	0.0124	73	77-119		
Matrix Spike (BL41724-MS3)		Source: 1	413254-03		Prepared 8	Analyzed:	12/17/14 16	6:26		
Nitrite (as N)	0.0724 J2	0.04	0.01	mg/L	0.10	ND	72	77-119		
Matrix Spike Dup (BL41724-MSD [,]	1)	Source: 1	412942-01		Prepared 8	Analyzed:	12/30/14 11	:46		
Nitrite (as N)	0.143 J2	0.04	0.01	mg/L	0.10	0.0608	82	77-119	6	20
Matrix Spike Dup (BL41724-MSD	2)	Source: 1	412942-12		Prepared 8	Analyzed:	12/17/14 16	6:13		
Nitrite (as N)	0.0844 J2	0.04	0.01	mg/L	0.10	0.0124	72	77-119	1	20
Matrix Spike Dup (BL41724-MSD	3)	Source: 1	413254-03		Prepared 8	Analyzed:	12/17/14 16	6:27		
Nitrite (as N)	0.0755 J2	0.04	0.01	mg/L	0.10	ND	76	77-119	4	20

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-2218



December 31, 2014

Work Order: 1412942

Hazen and Sawyer 10002 Princess Palm Ave, Suite 200

Tampa, FL 33619

Analuta	Result	PQL	MDL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
Analyte	Result	PQL	IVIDL	Units	Levei	Result	%REC	LIMIUS	RPD	LIIIII
Batch BL41728 - Sulfide prep										
Blank (BL41728-BLK1)					Prepared &	Analyzed:	12/23/14 13	8:56		
Sulfide	0.10 U	0.40	0.10	mg/L						
Blank (BL41728-BLK2)					Prepared &	Analyzed:	12/23/14 13	3:56		
Sulfide	0.10 U	0.40	0.10	mg/L						
LCS (BL41728-BS1)					Prepared &	Analyzed:	12/23/14 13	3:56		
Sulfide	4.92	0.40	0.10	mg/L	5.0		98	85-115		
LCS (BL41728-BS2)					Prepared &	Analyzed:	12/23/14 13	3:56		
Sulfide	4.92	0.40	0.10	mg/L	5.0		98	85-115		
Matrix Spike (BL41728-MS1)		Source: 1	412942-20		Prepared &	Analyzed:	12/23/14 13	3:56		
Sulfide	4.72	0.40	0.10	mg/L	5.0	ND	94	85-115		
Matrix Spike (BL41728-MS2)		Source: 1	412943-12		Prepared &	Analyzed:	12/23/14 13	3:56		
Sulfide	4.82	0.40	0.10	mg/L	5.0	ND	96	85-115		
Matrix Spike Dup (BL41728-MSD1)		Source: 1	412942-20		Prepared &	Analyzed:	12/23/14 13	3:56		
Sulfide	4.72	0.40	0.10	mg/L	5.0	ND	94	85-115	0	14
Matrix Spike Dup (BL41728-MSD2)		Source: 1	412943-12		Prepared &	Analyzed:	12/23/14 13	3:56		
Sulfide	4.82	0.40	0.10	mg/L	5.0	ND	96	85-115	0	14
Batch BL41802 - TSS prep										
Blank (BL41802-BLK1)					Prepared:	12/18/14 Ana	alyzed: 12/	19/14 16:06		
Total Suspended Solids	1 U	1	1	mg/L						

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-2218



December 31, 2014

Work Order: 1412942

Hazen and Sawyer 10002 Princess Palm Ave, Suite 200

Tampa, FL 33619

Analyte	Result	PQL	MDL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
Batch BL41802 - TSS prep										
Blank (BL41802-BLK2)					Prepared:	12/18/14 An	alyzed: 12/	/19/14 16:06		
Total Suspended Solids	1 U	1	1	mg/L						
LCS (BL41802-BS1)					Prepared:	12/18/14 An	alyzed: 12/	19/14 16:06		
Total Suspended Solids	45.5	1	1	mg/L	50		91	85-115		
LCS (BL41802-BS2)					Prepared:	12/18/14 An	alyzed: 12/	19/14 16:06		
Total Suspended Solids	51.5	1	1	mg/L	50		103	85-115		
Duplicate (BL41802-DUP1)		Source: 1	413251-01		Prepared:	12/18/14 An	alyzed: 12/	19/14 16:06		
Total Suspended Solids	197	1	1	mg/L		198			0.5	30
Duplicate (BL41802-DUP2)		Source: 1	413274-01		Prepared:	12/18/14 An	alyzed: 12/	19/14 16:06		
Total Suspended Solids	38.0	1	1	mg/L		35.0			8	30
Batch BL41803 - Nitrite SM 4	500NO2-B by s	eal								
Blank (BL41803-BLK1)					Prepared &	& Analyzed:	12/18/14 1	0:07		
Nitrite (as N)	0.01 U	0.04	0.01	mg/L						
LCS (BL41803-BS1)					Prepared &	& Analyzed:	12/18/14 1	0:08		
Nitrite (as N)	0.0803	0.04	0.01	mg/L	0.080		100	90-110		
Matrix Spike (BL41803-MS1)		Source: 1	413284-01		Prepared &	& Analyzed:	12/18/14 1	0:08		
Nitrite (as N)	0.170	0.04	0.01	mg/L	0.080	0.105	81	77-119		
Matrix Spike Dup (BL41803-MSD	1)	Source: 1	413284-01		Prepared &	& Analyzed:	12/18/14 1	6:29		
Nitrite (as N)	0.167	0.04	0.01	mg/L	0.080	0.105	78	77-119	2	20

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-2218



December 31, 2014

Work Order: 1412942

Hazen and Sawyer 10002 Princess Palm Ave, Suite 200

Tampa, FL 33619

Analyte	Result	PQL	MDL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
7 maryte	Reoun	T QL		Onito	Lever	rteoun	/01120	Linito		Linit
Batch BL41808 - TOC prep										
Blank (BL41808-BLK1)					Prepared 8	Analyzed:	12/19/14 14	4:08		
Total Organic Carbon	0.060 U	1.0	0.060	mg/L						
LCS (BL41808-BS1)					Prepared 8	Analyzed:	12/19/14 14	1:08		
Total Organic Carbon	9.12	1.0	0.060	mg/L	10		91	90-110		
Matrix Spike (BL41808-MS1)		Source: 1	412942-01		Prepared 8	Analyzed:	12/19/14 14	1:08		
Total Organic Carbon	12.2 L2	1.0	0.060	mg/L	10	33.0	NR	85-115		
Matrix Spike Dup (BL41808-MSD1)		Source: 1	412942-01		Prepared 8	Analyzed:	12/19/14 14	1:08		
Total Organic Carbon	12.6 L2	1.0	0.060	mg/L	10	33.0	NR	85-115	3	10
Batch BL41816 - Nitrate 353.2 b	y seal									
Blank (BL41816-BLK1)					Prepared 8	Analyzed:	12/18/14 15	5:24		
Nitrate+Nitrite (N)	0.01 U	0.04	0.01	mg/L						
LCS (BL41816-BS1)					Prepared 8	Analyzed:	12/18/14 15	5:26		
Nitrate+Nitrite (N)	0.820	0.04	0.01	mg/L	0.80		102	90-110		
Matrix Spike (BL41816-MS1)		Source: 1	412942-01		Prepared 8	Analyzed:	12/18/14 15	5:29		
Nitrate+Nitrite (N)	1.04 J2	0.04	0.01	mg/L	1.0	0.403	64	90-110		
Matrix Spike (BL41816-MS2)		Source: 1	413281-01		Prepared 8	Analyzed:	12/18/14 15	5:56		
Nitrate+Nitrite (N)	0.953	0.04	0.01	mg/L	1.0	ND	95	90-110		
Matrix Spike Dup (BL41816-MSD1)		Source: 1	412942-01		Prepared 8	Analyzed:	12/18/14 15	5:31		
		000100.1				· · · · ·				

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-2218



December 31, 2014

Work Order: 1412942

Hazen and Sawyer 10002 Princess Palm Ave, Suite 200

Tampa, FL 33619

Analyte	Result	PQL	MDL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
Batch BL41816 - Nitrate 353.2 k	oy seal									
Matrix Spike Dup (BL41816-MSD2)		Source: 1	413281-01		Prepared &	Analyzed:	12/18/14 1	5:58		
Nitrate+Nitrite (N)	1.01	0.04	0.01	mg/L	1.0	ND	101	90-110	6	20
Batch BL41818 - BOD										
Blank (BL41818-BLK1)					Prepared:	12/18/14 An	alyzed: 12/	23/14 11:06		
Carbonaceous BOD	2 U	2	2	mg/L						
Blank (BL41818-BLK2)					Prepared:	12/18/14 An	alyzed: 12/	23/14 11:06		
Carbonaceous BOD	2 U	2	2	mg/L						
LCS (BL41818-BS1)					Prepared:	12/18/14 An	alyzed: 12/	23/14 11:06		
Carbonaceous BOD	188	2	2	mg/L	200		94	85-115		
LCS (BL41818-BS2)					Prepared:	12/18/14 An	alyzed: 12/	23/14 11:06		
Carbonaceous BOD	189	2	2	mg/L	200		94	85-115		
LCS Dup (BL41818-BSD1)					Prepared:	12/18/14 An	alyzed: 12/	23/14 11:06		
Carbonaceous BOD	175	2	2	mg/L	200		87	85-115	7	200
LCS Dup (BL41818-BSD2)					Prepared:	12/18/14 An	alyzed: 12/	23/14 11:06		
Carbonaceous BOD	187	2	2	mg/L	200		93	85-115	1	200
Duplicate (BL41818-DUP1)		Source: 1	412942-01		Prepared:	12/18/14 An	alyzed: 12/	23/14 11:06		
Carbonaceous BOD	51	2	2	mg/L		57			9	25
Duplicate (BL41818-DUP2)		Source: 1	413274-01		Prepared:	12/18/14 An	alyzed: 12/	23/14 11:06		
Carbonaceous BOD	240	2	2	mg/L		240			0.6	25

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-2218



December 31, 2014

Work Order: 1412942

Hazen and Sawyer 10002 Princess Palm Ave, Suite 200

Tampa, FL 33619

• • • •		DOI	MDI		Spike	Source	0/ DE0	%REC		RPD
Analyte	Result	PQL	MDL	Units	Level	Result	%REC	Limits	RPD	Limit
Batch BL41823 - Ammonia b	y SEAL									
Blank (BL41823-BLK1)					Prepared &	& Analyzed:	12/18/14 16	6:29		
Ammonia as N	0.009 U	0.040	0.009	mg/L						
LCS (BL41823-BS1)					Prepared &	& Analyzed:	12/18/14 16	6:31		
Ammonia as N	0.51	0.040	0.009	mg/L	0.50		103	90-110		
Matrix Spike (BL41823-MS1)		Source: 1	412942-01		Prepared &	& Analyzed:	12/18/14 18	3:12		
Ammonia as N	40 L2	4.0	0.95	mg/L	0.50	43	NR	90-110		
Matrix Spike (BL41823-MS2)		Source: 1	412942-15		Prepared &	& Analyzed:	12/18/14 16	6:53		
Ammonia as N	0.75 J2	0.040	0.009	mg/L	0.50	0.17	116	90-110		
Matrix Spike Dup (BL41823-MSI	01)	Source: 1	412942-01		Prepared &	& Analyzed:	12/18/14 18	3:13		
Ammonia as N	40 L2	4.0	0.95	mg/L	0.50	43	NR	90-110	0.4	10
Matrix Spike Dup (BL41823-MSI	02)	Source: 1	412942-15		Prepared &	& Analyzed:	12/18/14 16	6:55		
Ammonia as N	0.74 J2	0.040	0.009	mg/L	0.50	0.17	113	90-110	2	10
Batch BL41828 - Digestion for	or TP and TKN									
Blank (BL41828-BLK1)					Prepared:	12/18/14 An	alyzed: 12/	22/14 13:43		
Phosphorous - Total as P	0.010 U	0.040	0.010	mg/L						
Total Kjeldahl Nitrogen	0.05 U	0.20	0.05	mg/L						
Blank (BL41828-BLK2)					Prepared:	12/18/14 An	alyzed: 12/	22/14 13:43		
Total Kjeldahl Nitrogen	0.05 U	0.20	0.05	mg/L						
Phosphorous - Total as P	0.010 U	0.040	0.010	mg/L						

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-2218



December 31, 2014

Work Order: 1412942

Hazen and Sawyer 10002 Princess Palm Ave, Suite 200

Tampa, FL 33619

Analyte	Result	PQL	MDL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
Batch BL41828 - Digestion fo	or TP and TKN									
LCS (BL41828-BS1)					Prepared:	12/18/14 An	alyzed: 12/2	22/14 13:43		
Phosphorous - Total as P	1.09	0.040	0.010	mg/L	1.0		109	90-110		
Total Kjeldahl Nitrogen	1.01	0.20	0.05	mg/L	1.0		101	90-110		
LCS (BL41828-BS2)					Prepared:	12/18/14 An	alyzed: 12/2	22/14 13:43		
Phosphorous - Total as P	0.996	0.040	0.010	mg/L	1.0		100	90-110		
Total Kjeldahl Nitrogen	1.08	0.20	0.05	mg/L	1.0		108	90-110		
Matrix Spike (BL41828-MS1)		Source: 1	412942-19		Prepared:	12/18/14 An	alyzed: 12/2	22/14 13:43		
Phosphorous - Total as P	1.27	0.040	0.010	mg/L	1.0	0.183	109	90-110		
Total Kjeldahl Nitrogen	1.28	0.20	0.05	mg/L	1.0	0.203	108	90-110		
Matrix Spike (BL41828-MS2)		Source: 1	412942-20		Prepared:	12/18/14 An	alyzed: 12/2	22/14 13:43		
Phosphorous - Total as P	1.19	0.040	0.010	mg/L	1.0	0.201	99	90-110		
Total Kjeldahl Nitrogen	1.10	0.20	0.05	mg/L	1.0	0.148	95	90-110		
Matrix Spike (BL41828-MS3)		Source: 1	413273-01		Prepared:	12/18/14 An	alyzed: 12/2	22/14 13:43		
Phosphorous - Total as P	1.30	0.040	0.010	mg/L	1.0	0.374	93	90-110		
Total Kjeldahl Nitrogen	1.52	0.20	0.05	mg/L	1.0	0.594	93	90-110		
Matrix Spike (BL41828-MS4)		Source: 1	413274-07		Prepared:	12/18/14 An	alyzed: 12/2	22/14 13:43		
Phosphorous - Total as P	1.28	0.040	0.010	mg/L	1.0	0.357	92	90-110		
Matrix Spike Dup (BL41828-MSD	1)	Source: 1	412942-19		Prepared:	12/18/14 An	alyzed: 12/2	22/14 13:43		
Phosphorous - Total as P	1.21	0.040	0.010	mg/L	1.0	0.183	103	90-110	5	25
Total Kjeldahl Nitrogen	1.19	0.20	0.05	mg/L	1.0	0.203	99	90-110	7	20
Matrix Spike Dup (BL41828-MSD	2)	Source: 1	412942-20		Prepared:	12/18/14 An	alyzed: 12/2	22/14 13:43		
Total Kjeldahl Nitrogen	1.09	0.20	0.05	mg/L	1.0	0.148	94	90-110	0.5	20
Phosphorous - Total as P	1.20	0.040	0.010	mg/L	1.0	0.201	100	90-110	0.7	25

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-2218



December 31, 2014

Work Order: 1412942

Hazen and Sawyer

10002 Princess Palm Ave, Suite 200

Tampa, FL 33619

Analyte	Result	PQL	MDL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
Batch BL41828 - Digestion for	or TP and TKN									
Matrix Spike Dup (BL41828-MSE	03)	Source: 1	413273-01		Prepared:	12/18/14 An	alyzed: 12/2	22/14 13:43		
Phosphorous - Total as P	1.33	0.040	0.010	mg/L	1.0	0.374	96	90-110	2	25
Total Kjeldahl Nitrogen	1.51	0.20	0.05	mg/L	1.0	0.594	92	90-110	0.5	20
Matrix Spike Dup (BL41828-MSD	04)	Source: 1	413274-07		Prepared:	12/18/14 An	alyzed: 12/2	22/14 13:43		
Total Kjeldahl Nitrogen	1.83	0.20	0.05	mg/L	1.0	0.841	99	90-110	1	20
Phosphorous - Total as P	1.38	0.040	0.010	mg/L	1.0	0.357	102	90-110	8	25
Batch BL41916 - Nitrate 353.	2 by seal									
Blank (BL41916-BLK1)					Prepared &	Analyzed:	12/19/14 12	2:35		
Nitrate+Nitrite (N)	0.0160 l	0.04	0.01	mg/L						
LCS (BL41916-BS1)					Prepared &	Analyzed:	12/19/14 12	2:37		
Nitrate+Nitrite (N)	0.833	0.04	0.01	mg/L	0.80		104	90-110		
Matrix Spike (BL41916-MS1)		Source: 1	412942-05		Prepared &	& Analyzed:	12/19/14 14	1:56		
Nitrate+Nitrite (N)	1.02	0.04	0.01	mg/L	1.0	0.0800	94	90-110		
Matrix Spike (BL41916-MS2)		Source: 1	412946-02		Prepared &	& Analyzed:	12/19/14 13	3:04		
Nitrate+Nitrite (N)	1.00	0.04	0.01	mg/L	1.0	0.0410	96	90-110		
Matrix Spike Dup (BL41916-MSD	01)	Source: 1	412942-05		Prepared 8	Analyzed:	12/19/14 14	1:58		
Nitrate+Nitrite (N)	0.985	0.04	0.01	mg/L	1.0	0.0800	90	90-110	3	20
Matrix Spike Dup (BL41916-MSE	02)	Source: 1	412946-02		Prepared &	& Analyzed:	12/19/14 13	3:06		
Nitrate+Nitrite (N)	0.951	0.04	0.01	mg/L	1.0	0.0410	91	90-110	6	20

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-2218



December 31, 2014

Work Order: 1412942

Hazen and Sawyer 10002 Princess Palm Ave, Suite 200 Tampa, FL 33619

Analyte	Result	PQL	MDL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
Batch BL42212 - COD prep										
Blank (BL42212-BLK1)					Prepared 8	Analyzed:	12/22/14 12	2:39		
Chemical Oxygen Demand	10 U	25	10	mg/L						
Blank (BL42212-BLK2)					Prepared 8	Analyzed:	12/22/14 12	2:39		
Chemical Oxygen Demand	10 U	25	10	mg/L						
Blank (BL42212-BLK3)					Prepared 8	Analyzed:	12/22/14 12	2:39		
Chemical Oxygen Demand	10 U	25	10	mg/L						
LCS (BL42212-BS1)					Prepared 8	Analyzed:	12/22/14 12	2:39		
Chemical Oxygen Demand	49	25	10	mg/L	50		98	90-110		
LCS (BL42212-BS2)					Prepared 8	Analyzed:	12/22/14 12	2:39		
Chemical Oxygen Demand	47	25	10	mg/L	50		94	90-110		
LCS (BL42212-BS3)					Prepared 8	Analyzed:	12/22/14 12	2:39		
Chemical Oxygen Demand	45	25	10	mg/L	50		90	90-110		
Matrix Spike (BL42212-MS1)		Source: 1	412942-19		Prepared 8	Analyzed:	12/22/14 12	2:39		
Chemical Oxygen Demand	45	25	10	mg/L	50	ND	90	85-115		
Matrix Spike (BL42212-MS2)		Source: 1	412944-11		Prepared 8	Analyzed:	12/22/14 12	2:39		
Chemical Oxygen Demand	47	25	10	mg/L	50	ND	94	85-115		
Matrix Spike (BL42212-MS3)		Source: 1	412946-21		Prepared 8	Analyzed:	12/22/14 12	2:39		
Chemical Oxygen Demand	45	25	10	mg/L	50	ND	90	85-115		
Matrix Spike Dup (BL42212-MSD1)		Source: 1	412942-19		Prepared 8	Analyzed:	12/22/14 12	2:39		
Chemical Oxygen Demand	45	25	10	mg/L	50	ND	90	85-115	0	32

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-2218



December 31, 2014

Work Order: 1412942

Hazen and Sawyer

10002 Princess Palm Ave, Suite 200

Tampa, FL 33619

Analyte	Result	PQL	MDL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
Batch BL42212 - COD prep										
Matrix Spike Dup (BL42212-MSD	2)	Source: 1	412944-11		Prepared 8	Analyzed:	12/22/14 12	2:39		
Chemical Oxygen Demand	45	25	10	mg/L	50	ND	90	85-115	4	32
Matrix Spike Dup (BL42212-MSD	3)	Source: 1	412946-21		Prepared 8	Analyzed:	12/22/14 12	2:39		
Chemical Oxygen Demand	43	25	10	mg/L	50	ND	86	85-115	5	32
Batch BL42306 - Ion Chroma	tography 300.0	Prep								
Blank (BL42306-BLK1)					Prepared 8	Analyzed:	12/23/14 18	3:02		
Chloride	0.050 U	0.20	0.050	mg/L						
Sulfate	0.20 U	0.60	0.20	mg/L						
Surrogate: Dichloroacetate	0.847			mg/L	1.0		85	78-120		
Surrogate: Dichloroacetate	0.847			mg/L	1.0		85	78-120		
LCS (BL42306-BS1)					Prepared 8	Analyzed:	12/23/14 18	3:13		
Chloride	3.09	0.20	0.050	mg/L	3.0		103	85-115		
Sulfate	9.27	0.60	0.20	mg/L	9.0		103	85-115		
Surrogate: Dichloroacetate	0.979			mg/L	1.0		98	78-120		
Surrogate: Dichloroacetate	0.979			mg/L	1.0		98	78-120		
LCS Dup (BL42306-BSD1)					Prepared 8	Analyzed:	12/23/14 18	3:24		
Chloride	3.23	0.20	0.050	mg/L	3.0		108	85-115	4	200
Sulfate	9.56	0.60	0.20	mg/L	9.0		106	85-115	3	200
Surrogate: Dichloroacetate	1.09			mg/L	1.0		109	78-120		
Surrogate: Dichloroacetate	1.09			mg/L	1.0		109	78-120		
Matrix Spike (BL42306-MS1)		Source: 1	412942-06		Prepared 8	Analyzed:	12/23/14 20):28		
Chloride	41.2	0.20	0.050	mg/L	3.0	38.7	83	80-120		
Sulfate	269 L	0.60	0.20	mg/L	9.0	253	180	85-115		
Surrogate: Dichloroacetate	0.845			mg/L	1.0		84	78-120		
Surrogate: Dichloroacetate	0.845			mg/L	1.0		84	78-120		

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-2218



December 31, 2014

Work Order: 1412942

Hazen and Sawyer

10002 Princess Palm Ave, Suite 200

Tampa, FL 33619

		5.01	MDI		Spike	Source		%REC		RPD
Analyte	Result	PQL	MDL	Units	Level	Result	%REC	Limits	RPD	Limit
Batch BL42306 - Ion Chroma	tography 300.0	Prep								
Matrix Spike (BL42306-MS2)		Source: 1	412942-16		Prepared &	Analyzed:	12/23/14 22	2:31		
Chloride	23.5	0.20	0.050	mg/L	3.0	20.7	92	80-120		
Sulfate	59.0	0.60	0.20	mg/L	9.0	51.2	87	85-115		
Surrogate: Dichloroacetate	1.12			mg/L	1.0		112	78-120		
Surrogate: Dichloroacetate	1.12			mg/L	1.0		112	78-120		
Batch BL42414 - Ion Chroma	tography 300.0	Prep								
Blank (BL42414-BLK1)					Prepared &	Analyzed:	12/24/14 17	7:26		
Sulfate	0.20 U	0.60	0.20	mg/L						
Surrogate: Dichloroacetate	0.966			mg/L	1.0		97	78-120		
LCS (BL42414-BS1)					Prepared &	Analyzed:	12/24/14 17	7:35		
Sulfate	8.76	0.60	0.20	mg/L	9.0		97	85-115		
Surrogate: Dichloroacetate	1.05			mg/L	1.0		105	78-120		
LCS Dup (BL42414-BSD1)					Prepared &	Analyzed:	12/24/14 17	7:53		
Sulfate	9.16	0.60	0.20	mg/L	9.0		102	85-115	4	200
Surrogate: Dichloroacetate	1.04			mg/L	1.0		104	78-120		
Matrix Spike (BL42414-MS1)		Source: 1	413401-01		Prepared &	Analyzed:	12/24/14 19	9:37		
Sulfate	453	6.0	2.0	mg/L	90	372	90	85-115		
Surrogate: Dichloroacetate	1.10			mg/L	1.0		110	78-120		
Matrix Spike (BL42414-MS2)		Source: 1	412944-10		Prepared &	Analyzed:	12/26/14 11	1:40		
Sulfate	395	6.0	2.0	mg/L	90	314	90	85-115		
Surrogate: Dichloroacetate	1.07			mg/L	1.0		107	78-120		
-				•						

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-2218



December 31, 2014

Work Order: 1412942

Hazen and Sawyer 10002 Princess Palm Ave, Suite 200 Tampa, FL 33619

-

Microbiology - Quality Control

Analyte	Result	PQL	MDL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
Batch BL41721 - FC-MF										
Blank (BL41721-BLK1)					Prepared:	12/17/14 An	alyzed: 12/	18/14 14:03		
Fecal Coliforms	1 U	1	1	CFU/100 m	l					
Duplicate (BL41721-DUP1)		Source: 1	412942-2	20	Prepared:	12/17/14 An	alyzed: 12/	18/14 14:03	i	
Fecal Coliforms	1 U	1	1	CFU/100 m	I	ND				200

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-2218



December 31, 2014

Work Order: 1412942

Hazen and Sawyer 10002 Princess Palm Ave, Suite 200 Tampa, FL 33619

* Qualifiers, Notes and Definitions

Results followed by a "U" indicate that the sample was analyzed but the compound was not detected. Results followed by "I" indicate that the reported value is between the laboratory method detection limts and the laboratory practical quantitation limit.

A statement of estimated uncertainty of test results is available upon request.

For methods marked with **, all QC criteria have been met for this method which is equivalent to a SAL certified method.

Test results in this report meet all the requirements of the NELAC standards. Any applicable qualifiers are shown below.

- L2 Analyte level in sample invalidated Matrix Spike.
- L Off-scale high. Result exceeded highest calibration standard.
- J5 Matrix spike of this sample was outside typical range. All other QC criteria were acceptable.
- J2 Quality control value for accuracy was outside control limits.

Questions regarding this report should be directed to :

Kathryn Nordmark Telephone (813) 855-1844 FAX (813) 855-2218 Kathryn@southernanalyticallabs.com



110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 fax 813-855-2218

Client Name Hazan and Sawyer												Contact / Phone: Josefin Hirst 813-630-4498										
Projec	ct Name / Location				<u>.</u>										·							
Samp	(m) (m)	3 SE#1:	2												·····							
Classion of										1	PARAMET	ER / CONT		SCRIPTI	DN I		·	r	`			
SAL	Matrix Codes: DW-Drinking Water WW-Wastewater SW-SurfaceWater SL-Sludge SO-Soil GW-Groundwater SA-Saline Water O-Other R-Reagent Water					te		125mLP, Sterile, Na ₂ S ₂ O ₃ FC-MF, FC-QT	500mLP, Cool TSS, CBOD, NOX, SO4	125mLP, H₂SO₄ COD, TKN, NH₃, TP	500mLP, NaOH, Zn Acetate H ₂ S	40mLaV, HCI TOC	500mLP, Cool CBOD, NOx, SO₄	125mLP, H₂SO₄ TKN, NH₃	500mLP, Cool TSS, CBOD, NOX, SO ₄ , CI		Temperature	Conductivity				
Use Only					×	posi		년 발 (월 월	G F	μ,Ψ,Ψ	ate .	, aV,		μĘ	<u>و</u> م		ber	onp				
Sample No.	Sample Description		Date	Time	Matrix	Composite	Grab	125n FC-N	500r TSS	125n COD	500n Acet H ₂ S	40m 10C	500 CBO	125n TKN	500n TSS,	Hd	Tem	Con	8			
01	BHS3-STE 12-N	111	hah	9.26	ww		x	4	2	1	1	2				7.26	18.27	1055	0.19			
	BHS3-LY01		ب برد ۲	9:05	ww		x		2	1		2				6,90	15.0	652	5.73			
03	BHS3-LY02			9:20	ww		x		2	1		2				6,41	16.2	737	6.23			
04	BHS3-LINER		1	8:35	ww		x	4	2	1		2				6.80	18.5	815	2.00			
05	BHS3-SULFUR-6			9:06	ww		x						1	1		6.53	18.96	986	1.11			
06	BHS3-ST2			\$:20	ŴŴ		x	4		1	1	2			2	6.59	18:49		0.10			
07	BHS3-ST2-DUP		1	8:40	ww		x	4		1	1	2			2	6.59	13,44	1067	0,0			
08	BHS3-LY03			11:10	ww		x			1	1				Of 2 A	16.80	15.4	753	675			
09	BHS3-LY04		and the second se	9:30	ww		х			1	1				2	6.67	18,3	760	6.05			
10	BHS3-PZ07			10:28	ww		х	4		1	1				2	6:29	1833	596	6.61			
11	BHS3-PZ08			10.04	ww		х	4		1	1				2	6.56	19.54	65B	4.01			
12	BHS3-PZ09		V	10:0D	ww		x	4		1	1				2	6.41	18.8	268	6.08			
Relinq	ners Prepared/ uished: WDM 120914	<u> </u>	Jose	both	2	12	Date/Time: Seal intact? 2017 13:00 Samples intact upo						n nya N nya		Instructio	ns / Rema	ırks					
Relinguished: Doubs up 121714 121714			falt	McCul	log	()	e/Time	<u>14 ¹¹</u>	د۳:		tion ice? Ter	•	Ø N NA									
Relinquished: Date Time 14			Au	Mell	Ŭ.	Date/Time:				Proper preservatives indicated? 💋 N N/A Rec'd within holding time? 🔗 N N/A												
Relinquished: Date/Time:			Received:			DataTime 7-14 1350				Volatiles rec'd w/out headspace Y N												
Relinq	uished: Date/Time:	Rece	Receive				Date/Time:											1412942				

Chain of Custody.xts Rev.Date 11/19/01

SAL Project No. 1412942

Chain of Custody

110 BAYVIEW BOULEVARD, OLDSMAR FL 34677 813-855-1844 fax 813-855-2218

Clien	Name Hazan		Contact / Phone: Josefin Hirst 813-630-4498															
Proje	ct Name / Location BHS3 S	°C#40																
Samp	lers: (Signature)	DE#12					T			l								
	Matrix Codes:			<u> </u>	↓		PARAMET	ER / CONT	FAINER DE	SCRIPTIC	N.	1						
	DW-Drinking Water WW-Wastewater SW-SurfaceWater SL-Sludge SO-Soil GW-Groundwater SA-Saline Water O-Other R-Reagent Water					Sterile, Na ₂ S ₂ O ₃ C-QT	500mLP, Cool TSS, CBOD, NOX, SO4 CI	2 ^{SO4} NH ₃ , TP	aOH, Zn	ō	oot <, SO 4	2SO4	20l		ure	vity		
SAL Use Only Sample	Sample Description	Date	Time	Matrix	Composite Grab		500mLP, C TSS, CBOE CI	125mLP, H ₂ SO, COD, TKN, NH ₃ , TP	500mLP, NaOH, Zn Acetate H ₂ S	40mLaV, HCI TOC	500mLP, Cool CBOD, NOX, SOA	125mLP, H ₂ SO4 TKN, NH ₃	500mLP, Cool Nox, CI, SQ4	Hd	Temperature	Conductivity	Q	
13	PZ-A7-6	12/13/14	11:22	ww	x							1	1	6.45	20.14	702	2.39	
	PZ-A7-8	12/14/14	11:34	ww	x							1	1	6.38	20.85	461	0.81	
	PZ-B8-5	12/17/14	11:25	ww	x							1	1	6.19	19.7	507	1.22	
16	PZ-B8-5-DUP	12/17/1		ww	x	-						1	1	6.19	19,7	507	1.22	
17	PZ-C06-5			ww	x							1	1					
18	PZ-C10-6			ww	x							1	1					
19	ЕВ	12/12/19	10:40	R	x	4	2	1	1	2				6.00	17.5	194	ક,મા	
20	FB	18/17/17	10:50	R	x	4	2	1	1	2				6.01	18.4	2,47	8,28	
					┠													
-																		
Containers Prepared/ Relinquished					Date/Tir	ne: ••••••••••••••••••••••••••••••••••••	13:00	Seal inta Samples	ct? intact upon a	Instructions / Remarks								
Relinquished: Relinquished: X Date/Time: Date/Time: Date/Time: Date/Time: Date/Time: 121714 Date/T		Received			Date/Time:			Proper p	d on ice? Ter reservatives thin holding ti	emp ON N/A s indicated? ()N N/A								
Relinquished: Date/Time:		Received:				1352 1352	~	Volatiles rec'd w/out headspaci Y N K/A Proper containers used?					14	412942				

Chain of Custody xis Rev.Date 11/19/01

Page 25 of 25

Chain of Custody

SAL Project No. 1412942



Appendix B: Operation & Maintenance Log

	Table B.1
-	Operation and Maintenance Log
Date	Description
7/25/2011	C-HS2 Groundwater Sample Event 1
11/30/2011	C-HS2 Groundwater Sample Event 2
3/13/2012	C-HS2 Groundwater Sample Event 3
7/10/2012	C-HS2 Groundwater Sample Event 4
6/14/2013	PNRS Pre-construction sample event
6/17/2013	PNRS construction. Old septic tank removed, new septic tank installed
	Stage 2 biofilter installed
6/18/2013	PNRS construction - backfill to set tanks, anchor trench for liner area
6/19/2013	PNRS construction - liner installed by Comanco
	Ligno and sand 50/50 filled to toe of lined area, fill dirt to grade
6/24/2013	New piezometers PZ-07, PZ-08, and PZ-09 installed and developed
	4 Lysimeters installed
6/26/2013	Both drip systems covered
7/9/2013	Electrician installed panel for system
7/11/2013	Electrician set up panel for hydraulic unit
	Dose times and volumes set
7/12/2013	System start-up
	Installed priming tee on pump. Installed treated effluent flowmeter
7/17/2013	Site visit. System ok.
7/22/2013	Repaired leaks in feed and return drip lines
	Installed new fittings for air release valves
7/29/2013	Site visit. System ok.
7/31/2013	Sod installation
8/15/2013	Preliminary SE#1
9/5/2013	Site visit. System ok.
9/8/2013	Homeowner reported alarm went off at 9 pm
9/9/2013	System check - high water level in STE dose tank
	Both hydraulic unit disc filters severely clogged - not able to dose
9/10/2013	System check, still high alarm - high water level in STE dose tank

Date	Description
9/10/2013	Not able to fix system - need replacement part for hydraulic unit
	Septic tank was pumped at 4 pm
9/11/2013	Homeowner reported no alarms
9/13/2013	Site visit. System ok.
9/17/2013	Installed replacement solenoid coil on backwash filter valve #2
	System operational again, septic tank very low volume still after pump-out
9/27/2013	SE#1 prep
	Applied vacuum to lysimeters
	Cleaned primary tank effluent screen
9/30/2013	Sample Event No. 1
10/11/2013	Site visit. System ok. Uploaded new program
10/17/2013	System check
	Bio solenoid valve ahead of pump had sand under the diaphragm in valve
11/8/2013	Site visit. System ok.
11/15/2013	Site visit. System ok.
11/27/2013	Site visit. System ok.
12/2/2013	Sample Event No. 2 preparation
12/4/2013	Sample Event No. 2
12/23/2013	Site visit. System ok.
1/23/2014	Site visit. System ok.
1/30/2014	Sample Event No. 3 preparation
2/3/2014	Sample Event No. 3
2/4/2014	Sample Event No. 4
2/5/2014	Sample Event No. 5
2/6/2014	Sample Event No. 6
2/7/2014	Sample Event No. 7
2/12/2014	Site visit. System ok.
3/14/2014	Site visit. System ok.
4/3/2014	Sample Event No. 8 (formal No. 4)
4/25/2014	Site visit. System ok.
4/29/2014	Site visit. System ok.
5/28/2014	Sample Event No. 9 (formal No. 5)
5/29/2014	Sample Event No. 9 (formal No. 5)
	Collected additives testing samples.
6/9/2014	Re-sampled BHS3-STE for toxicity testing.

Date	Description
7/11/2014	Site visit. Primary tank water level elevated.
	Cleaned primary tank effluent screen; severely clogged.
	Pumped down STE dose tank to below high level float.
7/29/2014	Site visit. System ok.
8/21/2014	Sample Event No. 10 (formal No. 6)
8/22/2014	Sample Event No. 10 (formal No. 6)
9/19/2014	Site visit. System ok.
10/21/2014	Sample Event No. 11 (formal No. 7) preparation.
10/23/2014	Sample Event No. 11 (formal No. 7)
10/24/2014	Sample Event No. 11 (formal No. 7)
11/21/2014	Site visit. System ok.
12/16/2014	Sample Event No. 12 (formal No. 8) preparation.
12/17/2014	Sample Event No. 12 (formal No. 8)
	Cleaned primary tank and STE dose tank effluent screens.
	Replaced treated effluent drip feed air relief valve.



Appendix C: Weather Station Data

Table C.1 Weather Station Data

2014		Te	emp. (°F)		1	Dew Point (°	E)	L L	Humidity (%	.)	Seal	evel Press	ire (in)		Wind (mph		Precip (i
Oct	hiah					hiah	ava	low	hiah	avg	low	hiah	sum				
10/25/2014	5	31	vy 68	56	nign 6	0	10w 54	93	avy 73	-	30.04	avy 30	29.95	5	avg 0	gust	7
10/26/2014		33	67	53	6		50			32	30.06	30.01	29.97	5	0)	5
10/27/2014	8	35	68	54	6		53		80	44	30.14	30.09	30.04	11	1	1	1
10/28/2014	8	37	71	57	7	0 64	57	99	82	46	30.21	30.16	30.11	8	0)	8
10/29/2014	8	38	72	61	7	64	59	99	79	40	30.15	30.08	30.01	5	0)	5
10/30/2014	8	36	72	61	7	64	61	99	80	51	30.04	29.97	29.89	6	0)	6
10/31/2014	8	30	69	57	6	5 58	45	97	70	33	29.92	29.86	29.81	8	0)	9
2014		Te	emp. (°F)			Dew Point (°	F)	ŀ	Humidity (%	5)	Sea L	evel Press	ure (in)		Wind (mph	i)	Precip (i
Nov	high	a١	vg	low	high	avg	low	high	avg	low	high	avg	low	high	avg	gust	sum
11/1/2014	6	62	56	43	5	3 39	26	90	58	27	30.2	30.05	29.89	15	1	1	5
11/2/2014		66	51	39	4		33		68		30.35	30.27	30.19	9	-		
11/3/2014	7	74	58	42	5	5 50	40	92	74	48	30.41	30.36	30.31	12	1	1	4
11/4/2014		30	65	53	6		52			-	30.36	30.3	30.23	12	1		3
11/5/2014	8	32	69	59	6	61	58				30.29	30.23	30.16	13	1	1	3
11/6/2014	8	34	70	58	6	3 61	58	99	78	46	30.2	30.1	29.99	6	0)	6
11/7/2014	7	76	66	52	6	55	48	98	72	42	30.04	30	29.95	8	0)	8
11/8/2014	7	78	63	50	6	5 57	49	98	82	56	30.02	29.94	29.87	8	0)	8 0.0
11/9/2014	6	69	63	58	6	60	57	98	91	75	29.98	29.93	29.88	7	0)	7 0.2
11/10/2014	6	69	63	58	6	61	56	98	93	85	29.98	29.95	29.93	6	0)	8 0.1
11/11/2014	8	30	66	56	6	60	53	95	81	57	30	29.95	29.9	10	0) 1	0
11/12/2014	7	78	63	51	6	2 55	50	98	78	44	30.1	30.04	29.98	6	0)	6
11/13/2014	8	31	67	55	6	1 58	49	98	77	34	30.11	30.05	29.99	4	0)	4
11/14/2014	6	69	61	51	6	3 57	48	98	88	61	30.2	30.11	30.02	3	0)	5
11/15/2014	7	75	60	46	6	2 55	44	96	84	62	30.28	30.22	30.16	9	0)	9
11/16/2014	8	32	68	53	6	62	52	99	84	57	30.24	30.15	30.07	8	0)	8 0.0
11/17/2014	8	34	72	67	7	4 69	66	99	92	69	30.07	29.99	29.9	13	1	1	3 1
11/18/2014	6	68	50	42	6	7 45	34	98	83	55	30.35	30.17	29.98	8	0)	8 0.0
11/19/2014	Ę	59	48	38	5	0 40	31	93	77	63	30.41	30.35	30.29	9	1	1	0
11/20/2014	6	65	51	40	4	9 43	33	93	75	43	30.34	30.28	30.22	9	0)	9
11/21/2014	7	73	61	49	5	3 52	42	89	72	51	30.34	30.29	30.24	14	1	1	5
11/22/2014	7	71	66	60	6	64	58	98	93	84	30.31	30.22	30.13	12	1	1	3 0.1
11/23/2014	8	34	76	69	7	5 72	67	98	89	67	30.13	30	29.88	13	2	. 1	3 0.1
11/24/2014	8	37	78	73	7	5 72	70	97	84	58	30.05	29.99	29.93	11	1	1	1
11/25/2014	7	75	72	68	7	3 71	68	99	97	89	30.04	29.97	29.89	15	0) 1	5 4.6
11/26/2014	7	72	58	46	7	56	46	99	94	74	30.24	30.05	29.85	13	1	1	3 0.2
11/27/2014	7	70	54	41	5	45	39	99	73	40	30.32	30.26	30.19	9	0) 1	1 0.0
11/28/2014	6	61	50	40	4	5 41	34	90	73	52	30.37	30.33	30.28	14	1	1	4
11/29/2014	7	71	55	42	5	7 50	41	98	83	55	30.36	30.32	30.28	10	0) 1	0
11/30/2014	7	76	61	48	6	2 55	48	99	84	54	30.38	30.33	30.29	10	1	1	1

o:\44237-001\\Wpdd

FLORIDA ONSITE SEWAGE NITROGEN REDUCTION STRATEGIES STUDY B-HS3 FIELD SYSTEM MONITORING REPORT NO. 8

PAGE C-1 HAZEN AND SAWYER, P.C. Appendix C

Table C.1Weather Station Data (continued)

2014		Temp. (°F)	9	D	ew Point (°	F)	ŀ	Humidity (%)	Sea L	evel Pressu	ure (in)		Precip (in)		
Dec	high	avg	low	high	avg	low	high	avg	low	high	avg	low	high	avg	gust	sum
12/1/2014	79	66	54	66	60	53	99	85	63	30.38	30.32	30.26	20	1	20	0
12/2/2014	78	68	58	68	64	58	99	88	70	30.29	30.24	30.18	14	1	15	0.01
12/3/2014	80	68	59	68	63	59	99	86	57	30.25	30.2	30.16	. 11	1	. 11	0
12/4/2014	81	70	62	67	65	62	99	84	57	30.26	30.22	30.17	8	1	12	0
12/5/2014	80	70	64	69	66	64	98	88	67	30.3	30.26	30.22	11	1	11	0.01
12/6/2014	81	71	65	70	67	64	99	89	64	30.26	30.19	30.12	5	0	5	0.01
12/7/2014	71	65	59	66	62	56	98	89	74	30.16	30.12	30.09	12	1	12	0.11
12/8/2014	66	60	54	65	59	52	98	96	91	30.15	30.11	30.07	11	1	11	0.11
12/9/2014	65	55	46	53	48	43	93	79	51	30.12	30.07	30.02	7	0	9	0
12/10/2014	63	50	38	46	42	37	98	78	41	30.18	30.13	30.08	6	0	6	0
12/11/2014	62	50	37	47	43	36	99	81	50	30.24	30.18	30.13	10	0	10	0
12/12/2014	64	49	40	46	42	33	98	80	34	30.31	30.26	30.21	2	0	4	0
12/13/2014	68	50	38	48	40	27	99	74	22	30.25	30.19	30.12	5	0	6	0.01
12/14/2014	70	52	38	46	40	36	98	72	29	30.15	30.1	30.06	5	0	5	0
12/15/2014	70	51	38	51	41	32	99	76	25	30.18	30.14	30.09	4	0	4	0
12/16/2014	74	56	40	58	47	40	99	77	32	30.24	30.18	30.13	4	0	7	0
12/17/2014	72	60	48	58	53	45	98	80	40	30.25	30.18	30.11	5	0	5	0
			9.5		·							1			1911 - 1913 - 1914 - 1914 - 1914 - 1914 - 1914 - 1914 - 1914 - 1914 - 1914 - 1914 - 1914 - 1914 - 1914 - 1914 -	

FLORIDA ONSITE SEWAGE NITROGEN REDUCTION STRATEGIES STUDY B-HS3 FIELD SYSTEM MONITORING REPORT NO. 8

o:\44237-001\\\Wpdocs\Report\Draft